

Grahme Walsh

From: Mark Fritz
Sent: Tuesday, July 28, 2009 8:49 AM
To: Grahme Walsh
Subject: RE:

*we
310
Sales file*

Grahme: I had Miriam from KMK check the caulking from the outside of there unit and make any necessary repairs when he was here I have also had Satish from Allan windows come in and investigate the window system from the inside and we could not find anything wrong, Hot hot water issue was a building wide issue when there was not that many people in the building to circulate the hot water Dino from Lisi and me have investigated this many time in the early stages of occupancy, He also boosted the hot water to 140 degrees. I never herd about there toilet issue. I can not recall having a issue with the toilet in 510 but it might have been at the beginning of the project and I have had Lubin from Barwood assess there floor and the floor was normal to me and him, We should have Danny come and assess and than draw up a letter stating his findings>

From: Grahme Walsh
Sent: Tue 7/28/2009 8:36 AM
To: Mark Fritz
Cc: Moe Santos
Subject: RE:

Any comment on the e-mail I sent yesterday regarding eve 310

From: Grahme Walsh
Sent: Monday, July 27, 2009 3:34 PM
To: Mark Fritz
Cc: Moe Santos
Subject:

Mark/ Moe:

Review the attached and let us set up to review the leak among other issues

Thanks

Grahme

*310
Send a letter
in response
to their letter.*