

THE RESIDENCES AT PARKSIDE VILLAGE- TOWER ONE
COLOUR SELECTION REQUEST FORM

4065 BRICKSTONE MEWS, MISSISSAUGA, ONTARIO SUITE: 305 UNIT: 5 LEVEL: 5 FLPN: 5

(02144C)

PURCHASER(S) REQUEST:

REQUEST DATE: Mar 13/11

① Purchaser requesting thickness of
sub floor under engineered hardwood.

VENDOR'S COMMENTS:

REQUEST REVIEW DATE: April 18 2011

① *for floating floor - 2 1/2 mm High Density foam on concrete slab
*for glue down floor (upgrade) 2 1/2 mm Cork on concrete slab.