CONSTRUCTION NOTES (unless otherwise noted)

ALL CONSTRUCTION TO ADHERE TO THESE PLANS AND SPECIFICATIONS AND TO CONFORM TO THE ONTARIO BUILDING CODE AND ALL OTHER APPLICABLE CODES AND AUTHORITIES HAVING JURISDICTION. THESE REQUIREMENTS ARE TO BE TAKEN AS MINIMUM SPECIFICATIONS: ONT. REG. 332/12-2012 OBC

1 **ROOF CONSTRUCTION**
NO.210 (10.25kg/m2) ASPHALT SHINGLES, 10mm (3/8") PLYWOOD SHEATHING WITH "H" CLIPS, APPROVED WOOD TRUSSES @ 600mm (24") O.C. MAX. APPROVED EAVES PROTECTION TO EXTEND 915mm (3'-0") FROM EDGE OF ROOF AND MIN. 300mm (12") BEYOND INNER FACE OF EXTERIOR WALL. (EAVES PROTECTION NOT REQD FOR ROOF SLOPES 8:12 OR GREATER) 38x89 (2"x4") TRUSS BRACING @ 1830mm (6'-0") O.C. AT BOTTOM CHORD. PRETFN. ALUM. EAVESTROUGH, FASCIA, RWL & VENTED SOFFIT. PROVIDE ICE & WATER SHIELD TO ALL ROOF/WALL SURFACES SUSCEPTIBLE TO ICE DAMMING. ROOF SHEATHING TO BE FASTENED 150 (6") c/c ALONG EDGES & INTERMEDIATE SUPPORTS WHEN TRUSSES SPACED GREATER THAN 400 (16"). ATTIC VENTILATION TO ACHIEVE OPTIMUM COOLING AREA WITH MIN. 25X AT EAVES & MIN. 25X AT ROOF (OBC 9.19.1.2).

2 **FRAME WALL CONSTRUCTION (2"x6")** (SB-12-TABLE 2.1.1.2.A)
SIDING AS PER ELEV., 19x28 (1"x2") VERTICAL WOOD FURRING, CONTIN. SHEATHING MEMBRANE, 9.5mm (3/8") EXT. TYPE SHEATHING, 38x140 (2"x6") STUDS @ 400mm (16") O.C. INSULATION AND APPR. VAPOUR BARRIER AND APPR. CONTIN. AIR BARRIER, 13mm (1/2") INC. DRYWALL FINISH. SIDING TO BE MIN. 200mm (8") ABOVE FINISH GRADE. FRAME WALL CONSTRUCTION TO BE DESIGNED TO SB-12, TABLE 2.1.1.2A FOR REQUIRED MINIMUM THERMAL INSULATION.

2A **FRAME WALL CONSTRUCTION (2"x6") (R28)**
SIDING AS PER ELEV., 19x28 (1"x2") VERTICAL WOOD FURRING, CONTIN. SHEATHING MEMBRANE, 28mm (1") EXTENDED STRUCTURAL INSULATED SHEATHING R5.0 (7.8kl) BY "BP" OR EQUAL, 38x140 (2"x6") STUDS @ 400mm (16") O.C., R19 4.23 (R24) INSUL. & APPR. VAPOUR BARRIER WITH APPR. CONTIN. AIR BARRIER. 13mm (1/2") INT. DRYWALL FINISH. PROVIDE WEEP HOLES @ 800mm (32") O.C. BOTTOM COURSE AND OVER OPENINGS. PROVIDE BASE FLASHING UP MIN. 150mm (6") BEHIND BUILDING PAPER. BRICK TO BE MIN. 150mm (6") ABOVE FINISH GRADE.

2B **FRAME WALL CONSTRUCTION (2"x4")- GARAGE WALLS**
SIDING AS PER ELEV., 19x28 (1"x2") VERTICAL WOOD FURRING, CONTIN. SHEATHING MEMBRANE, 9.5mm (3/8") EXT. TYPE SHEATHING, 38x89 (2"x4") STUDS @ 400mm (16") O.C. (MAX. HORIZONTAL DIMENSION (9'-10"), WITH APPR. DIAGONAL WALL BRACING. SIDING TO BE MIN. 200mm (8") ABOVE FINISH GRADE.

2C RESERVED

3 **STUCCO WALL CONSTRUCTION (2"x6")** (SB-12-TABLE 2.1.1.2.B)
STUCCO CLADDING SYSTEM CONFORMING TO O.B.C. 9.27.11.(2) & 9.28 THAT EMPLOYS A MINIMUM 10mm (3/8") AIR SPACE BEHIND THE CLADDING WITH POSITIVE DRAINAGE TO THE EXTERIOR AND APPLIED PER MANUFACTURERS SPECIFICATIONS OVER 25mm (1") MIN. EXPANDED OR EXTRUDED RIGID POLYSTYRENE ON APPROVED AIR/MOISTURE BARRIER ON 13mm (1/2") EXT. TYPE SHEATHING ON 38x89 (2"x4") STUDS @ 400 (16") O.C., INSULATION, VAPOUR BARRIER AND 13mm (1/2") INT. DRYWALL FINISH. PROVIDE EXTRUDED OR EXPANDED RIGID POLYSTYRENE ON APPR. CONTIN. AIR/MOISTURE BARRIER ON 13mm (1/2") EXT. TYPE SHEATHING ON 38x89 (2"x4") STUDS @ 400mm (16") O.C., INSULATION, VAPOUR BARRIER AND 13mm (1/2") INT. DRYWALL FINISH. PROVIDE EXTRUDED OR EXPANDED RIGID POLYSTYRENE ON APPR. CONTIN. AIR/MOISTURE BARRIER ON 13mm (1/2") EXT. TYPE SHEATHING ON 38x89 (2"x4") STUDS @ 400mm (16") O.C., INSULATION, VAPOUR BARRIER AND 13mm (1/2") INT. DRYWALL FINISH. STUCCO TO BE MIN. 200 (8") ABOVE FINISH GRADE.

4 **INTERIOR STUD PARTITIONS**
FOR BEARING PARTITIONS 38x89 (2"x4") @ 400mm (16") O.C. FOR 2 STORIES AND 200mm (12") O.C. FOR 3 STORIES. NON-BEARING PARTITIONS 38x89 (2"x4") @ 600mm (24") O.C. PROVIDE 38x89 (2"x4") BOTTOM PLATE AND 2/38x89 (2"x4") TOP PLATE. 13mm (1/2") INT. DRYWALL BOTH SIDES OF STUDS. PROVIDE 38x140 (2"x6") STUDS/PLATES WHERE NOTED.

5 FOUNDATION WALL/FOOTINGS [9.15.3, 9.15.4, 9.13.2, 9.14.2.1.(2)]
200mm (8") POURED CONC. FDTN. WALL 15MPa (2200psi) WITH DRYWALL FINISH. PROVIDE WEEP HOLES @ 800mm (32") O.C. BOTTOM COURSE AND OVER OPENINGS. PROVIDE BASE FLASHING UP MIN. 150mm (6") BEHIND BUILDING PAPER. BRICK TO OBC SB-12, TABLE 2.1.1.2A. FOR REQUIRED MINIMUM THERMAL INSULATION. TABLE 2.1.1.2A FOR REQUIRED MINIMUM THERMAL INSULATION.

5A **BRICK VENEER CONSTRUCTION (2"x6")** [SB-12-TABLE 2.1.1.2.A]
90mm (4") FACE BRICK, 25mm (1") AIR SPACE, 22x180x0.76mm (7/8"x7"x0.03") GALV. METAL TIES @ 400mm (16") O.C. HORIZONTAL, 60mm (2") O.C. VERTICAL, APPROVED SHEATHING PAPER, 9.5mm (3/8") EXT. TYPE SHEATHING, 38x140 (2"x6") STUDS @ 400mm (16") O.C., INSULATION & APPR. VAPOUR BARRIER WITH APPR. CONTIN. AIR BARRIER, 13mm (1/2") INTERIOR DRYWALL FINISH. PROVIDE WEEP HOLES @ 800mm (32") O.C. BOTTOM COURSE AND OVER OPENINGS. PROVIDE BASE FLASHING UP MIN. 150mm (6") BEHIND BUILDING PAPER. BRICK TO OBC SB-12, TABLE 2.1.1.2A. FOR REQUIRED MINIMUM THERMAL INSULATION. TABLE 2.1.1.2A FOR REQUIRED MINIMUM THERMAL INSULATION.

5B **BRICK VENEER CONSTRUCTION (2"x6")** [SB-12-TABLE 2.1.1.2.A]
90mm (4") FACE BRICK, 25mm (1") AIR SPACE, 22x180x0.76mm (7/8"x7"x0.03") GALV. METAL TIES @ 400mm (16") O.C. HORIZONTAL, 60mm (2") O.C. VERTICAL, APPR. SHEATHING PAPER, 28mm (1") EXT. STRUCT. INSULATED SHEATHING R5.0 (7.8kl) BY "BP" OR EQUAL, 38x140 (2"x6") STUDS @ 400mm (16") O.C., R19 4.23 (R24) INSUL. & APPR. VAPOUR BARRIER WITH APPR. CONTIN. AIR BARRIER. 13mm (1/2") INT. DRYWALL FINISH. PROVIDE WEEP HOLES @ 800mm (32") O.C. BOTTOM COURSE AND OVER OPENINGS. PROVIDE BASE FLASHING UP MIN. 150mm (6") BEHIND BUILDING PAPER. BRICK TO BE MIN. 150mm (6") ABOVE FINISH GRADE.

6 **FOUNDATION DRAINAGE** OBC 9.14.2. & 9.14.3.
100mm (4") DIA. FOUNDATION DRAINAGE TILE 150mm (6") PLASTIC FROM THE FOOTING TO THE SURFACE. THE SUBGRADE NOT MORE THAN 200mm (8") ABOVE THE FINISHED FLOOR & NO CLOSER THAN 50mm (2") OF THE BASEMENT SLAB. INSULATION TO HAVE APPROVED VAPOUR BARRIER. DAMPPROOF WITH BUILDING PAPER TO 300mm (12") BELOW GRADE. BACKFILL WITH 19mm (3/4") GRADE LEVEL NOTE: FULL HEIGHT INSULATION AT COLD CELLAR WALLS. REFER TO OBC SB-12, TABLE 2.1.1.2.A. FOR REQUIRED MINIMUM THERMAL INSULATION. AIR BARRIER TO BE SEALED TO FDTN. WALL WITH CAULKING.

7 **CONCRETE SLAB** OBC 9.16.4.
38x89 (2"x4") STUDS @ 400mm (16") O.C. 38x89 (2"x4") SILL PLATE ON DAMPPROOFING MATERIAL. 13mm (1/2") DIA. ANCHOR BOLTS 200mm (8") LONG, EMBEDDED MIN. 100mm (4") INTO CONC. @ 2400mm (7'-10") O.C. 100mm (4") THICK CONC. CURB ON 30x105 (1"x4") CONC. FOOTING. ADD HORIZ. BLOCKING AT MID-HEIGHT IF WALL IS UNFINISHED.

8 **STEEL BASEMENT COLUMN.** (SEE O.B.C. 9.15.3.5)
89mm(3-1/2") DIA x 3.0mm(0.118") SINGLE WALL TUBE TYPE 2 ADJUSTABLE STL. COL. W/ MIN. CAPACITY OF 71.2kN (16,000lbs.) AT A MAX. EXTENSION OF 2318mm (7'-7 1/2") WITH A MIN. OF 1905mm (6'-2") OR AS PER SHOP DRAWINGS. (6"x6"x0.5") STL. PLATE TOP & BOTTOM. 87x87x10x10 (3"x3"x3/8") STL. PLATE BOTTOM. 152x152x6.4 (6"x6") STL. PLATE TOP. ADJUSTABLE TO 152mm (6") MIN. OF ENGINEERED FILL CAPABLE OF SUSTAINING A PRESSURE OF 150 kpa. MINIMUM AND AS PER SOILS REPORT.

9 **STEEL BASEMENT COLUMN.** (SEE O.B.C. 9.15.3.5)
89mm(3-1/2") DIA x 4.78mm(.188") THICK STL. COL. WITH 305x305x6.35 (6"x6"x1/4") STL. TOP & BOTTOM PLATE ON 1370x1370x457 (54"x54"x18"). CONC. FOOTING ON UNDISTURBED SOIL OR ENGINEERED FILL CAPABLE OF SUSTAINING A PRESSURE OF 150 kpa. MIN. AND AS PER SOILS REPORT.

10 **STEEL COLUMN**
89mm(3-1/2") DIA x 4.78mm(.188) NON-ADJUSTABLE STL. COL. WITH 152x152x6.35 (6"x6"x1/4") STEEL TOP PLATE, W. BOTTOM PLATE. BASE PLATE: 1200x550x12.5
(4 1/2"x21"x1/2") WITH 2-13mm DIA. x 300mm LONG 150mm HOOK ANCHORS (2-1/2"x12"x2") FIELD WELD COL. TO BASE PLATE.

11 **CONCRETE NIB/ POCKET**
BEAM POCKET ON 300x150 (12"x6") POURED CONC. NIB WALLS. MIN. BEARING 90mm (3-1/2")

12 19x64 (1"x2") CONTINUOUS WOOD STRAPPING BOTH SIDES OF STEEL BEAM.

13 **BASEMENT INSULATION** [SB-12-2.1.1.6), 9.25.2.3, 9.13.2.6]
INSULATION FROM TOP OF FOOTING TO THE SURFACE NOT MORE THAN 200mm (8") ABOVE THE FINISHED FLOOR & NO CLOSER THAN 50mm (2") OF THE BASEMENT SLAB. INSULATION TO HAVE APPROVED VAPOUR BARRIER. DAMPPROOF WITH BUILDING PAPER TO 300mm (12") BELOW GRADE. BACKFILL WITH 19mm (3/4") GRADE LEVEL NOTE: FULL HEIGHT INSULATION AT COLD CELLAR WALLS. REFER TO OBC SB-12, TABLE 2.1.1.2.A. FOR REQUIRED MINIMUM THERMAL INSULATION. AIR BARRIER TO BE SEALED TO FDTN. WALL WITH CAULKING.

14 **BEARING STUD PARTITION**
38x89 (2"x4") STUDS @ 400mm (16") O.C. 38x89 (2"x4") SILL PLATE ON DAMPPROOFING MATERIAL. 13mm (1/2") DIA. ANCHOR BOLTS 200mm (8") LONG, EMBEDDED MIN. 100mm (4") INTO CONC. @ 2400mm (7'-10") O.C. 100mm (4") THICK CONC. CURB ON 30x105 (1"x4") CONC. FOOTING. ADD HORIZ. BLOCKING AT MID-HEIGHT IF WALL IS UNFINISHED.

15 **STEEL BASEMENT COLUMN.** (SEE O.B.C. 9.15.3.5)
89mm(3-1/2") DIA x 3.0mm(0.118") SINGLE WALL TUBE TYPE 2 ADJUSTABLE STL. COL. W/ MIN. CAPACITY OF 71.2kN (16,000lbs.) AT A MAX. EXTENSION OF 2318mm (7'-7 1/2") WITH A MIN. OF 1905mm (6'-2") OR AS PER SHOP DRAWINGS. (6"x6"x0.5") STL. PLATE TOP & BOTTOM. 87x87x10x10 (3"x3"x3/8") STL. PLATE BOTTOM. 152x152x6.4 (6"x6") STL. PLATE TOP. ADJUSTABLE TO 152mm (6") MIN. OF ENGINEERED FILL CAPABLE OF SUSTAINING A PRESSURE OF 150 kpa. MINIMUM AND AS PER SOILS REPORT.

16 **STEEL BASEMENT COLUMN.** (SEE O.B.C. 9.15.3.5)
89mm(3-1/2") DIA x 4.78mm(.188) THICK STL. COL. WITH 305x305x6.35 (6"x6"x1/4") STL. TOP & BOTTOM PLATE ON 1370x1370x457 (54"x54"x18"). CONC. FOOTING ON UNDISTURBED SOIL OR ENGINEERED FILL CAPABLE OF SUSTAINING A PRESSURE OF 150 kpa. MIN. AND AS PER SOILS REPORT.

17 **STEEL COLUMN**
89mm(3-1/2") DIA x 4.78mm(.188) NON-ADJUSTABLE STL. COL. WITH 152x152x6.35 (6"x6"x1/4") STEEL TOP PLATE, W. BOTTOM PLATE. BASE PLATE: 1200x550x12.5
(4 1/2"x21"x1/2") WITH 2-13mm DIA. x 300mm LONG 150mm HOOK ANCHORS (2-1/2"x12"x2") FIELD WELD COL. TO BASE PLATE.

18 **GARAGE SLAB**
100mm (4") 25MPa (4640psi) CONC. SLAB WITH 5-8% AIR ENTRAINMENT ON OPT. 100 (4") COARSE GRANULAR FILL WITH COMPACTED SUB-GRADE OF CONSTANT NATIVE FILL. SLOPE TO FRONT.

19 **GARAGE CEILINGS/INTERIOR WALLS**
13mm (1/2") GYPSUM BOARD ON WALL AND CEILING BETWEEN HOUSE AND GARAGE. TAPE AND SEAL ALL JOINTS AIRTIGHT PER O.B.C. 9.10.9.16. REFER TO SB-12, TABLE 2.1.1.2.A. FOR REQUIRED THERMAL INSULATION.

20 DOOR AND FRAME GASPROOFED. DOOR EQUIPPED WITH SELF CLOSING DEVICE AND WEATHERSTRIPPING PER OBC 9.10.13.15.

21 **EXTERIOR STEP**
REFACED CONCRETE STEP OR WOOD STEP WHERE NOT EXPOSED TO WEATHER. MAX. RISE 200mm (7-7/8") MIN. TREAD 250mm (9-1/2"). SEE OBC 9.8.8.2., 9.8.3.1. & 9.8.1.0.

22 **DRYER EXHAUST** [OBC-6.2.3.8.(7) & 6.2.4.11.]
UNVENTED DRYER EXHAUST VENTED TO EXTERIOR.

23 **INSULATED ATTIC ACCESS** [OBC-9.19.2.1. & SB-12-2.1.1.7]
ATTIC ACCESS TO BE INSULATED TO THE SAME VALUE AS ATTIC (31.2"x24") & A MIN. ARCH OF 0.32 SQM. (3.4 SQ.FT.) WITH WEATHERSTRIPPING. R50 3.52 (20kl) BLOW INSUL. NOTE: ATTIC ACCESS TO BE GAS UTILIZATION CODE.

24 **DIRECT VENTING GAS FIREPLACE VENT**
DIRECT VENT GAS FIREPLACE. VENT TO BE A MINIMUM 300mm (12") FROM ANY OPENING AND ABOVE FINAL GRADE. REFER TO GAS UTILIZATION CODE.

25 **SUBFLOOR - SEE STRAPPING AND BRIDGING**
16mm (5/8") T & G SUBFLOOR ON WOOD FLOOR JOISTS. FOR CERAMIC TILE APPLICATION (* SEE OBC 9.30.4. 5) 6mm (1/4") PANEL TYPE UNDERLAY UNDER RESILIENT & PARQUET FLOORING. (* SEE OBC 9.30.2.)
FLOOR JOISTS WITH SPANS OVER 2100mm (6'-11") TO BE BRIDGED WITH 38x38 (2"x2") CROSS BRACING OR SOLID BLOCKING @ 2100mm (6'-11") O.C. MAX. AND WHERE SPECIFIED BY JOIST TABLES A-1 OR A-2 STRAPPING SHALL BE 19x64 (1"x3") @ 2100mm (6'-11") O.C. UNLESS A PANEL TYPE CEILING FINISH IS APPLIED.
(* SEE OBC 9.23.9.4. *)

26 **EXPOSED BUILDING FACE** OBC. 9.10.15. & SB-12-3.3.5.(2)
EXTERIOR WALLS TO HAVE A FIRE RESISTANCE RATING OF NOT LESS THAN 45 min. AND BE LOCATED A MINIMUM DISTANCE (1) IS LESS THAN 1.2M (3'-11"). WHERE THE LD IS LESS THAN 600mm (1'-11") THE EXPOSING FACE SHALL BE CLAD IN NON-COMBUSTIBLE MATERIAL. SEE ELEVATIONS FOR ADDITIONAL NOTES.

28 RESERVED

29 **BEARING WOOD POST (BASEMENT) (OBC 9.17.4.)**
3-38x140 (3"x6") BUILT-UP-POST ON METAL BASE SHOE ANCHORED TO CONC. WITH 13mm (1/2") DIA. BOLT, 610x610x305 (24"x24"x12") CONC. FTG.

30 **STEPPED FOOTINGS OBC 9.15.3.9.**
MIN. HORIZ. STEP = 600mm (24").
MAX. VERT. STEP = 400mm (24")

31 **SLAB ON GRADE**
MIN. 100mm (4") CONCRETE SLAB ON GRADE ON 100mm (4") COARSE GRANULAR FILL. REINFORCED WITH 6x6-W2.9xW2.9 MESH PLACED NEAR MID-DEPTH OF SLAB. CONC. STRENGTH 32 MPa (4640 psi) WITH 5-8% AIR ENTRAINMENT ON COMPACTED SUB-GRADE. REFER TO OBC SB-12, TABLE 2.1.1.2.A. FOR REQUIRED MINIMUM THERMAL INSULATION UNDER SLAB.

32 **DIRECT VENTING GAS FURNACE/ H.W.T. VENT**
DIRECT VENT FURNACE TERMINAL MIN. 900mm (36") FROM A GAS REGULATOR. MIN. 300mm (12") ABOVE FIN. GRADE, FROM ALL OPENINGS, EXHAUST AND INTAKE VENTS. MIN INTAKE TO EXHAUST 1.5M. (5'-0") FROM ALL DIRECT VENT EXHAUST TERMINALS. REFER TO GAS UTILIZATION CODE.

33 **DIRECT VENTING GAS FIREPLACE VENT**
DIRECT VENT GAS FIREPLACE. VENT TO BE A MINIMUM 300mm (12") FROM ANY OPENING AND ABOVE FINAL GRADE. REFER TO GAS UTILIZATION CODE.

34 **SUBFLOOR - SEE STRAPPING AND BRIDGING**
16mm (5/8") T & G SUBFLOOR ON WOOD FLOOR JOISTS. FOR CERAMIC TILE APPLICATION (* SEE OBC 9.30.4. 5) 6mm (1/4") PANEL TYPE UNDERLAY UNDER RESILIENT & PARQUET FLOORING. (* SEE OBC 9.30.2.)
FLOOR JOISTS WITH SPANS OVER 2100mm (6'-11") TO BE BRIDGED WITH 38x38 (2"x2") CROSS BRACING OR SOLID BLOCKING @ 2100mm (6'-11") O.C. MAX. AND WHERE SPECIFIED BY JOIST TABLES A-1 OR A-2 STRAPPING SHALL BE 19x64 (1"x3") @ 2100mm (6'-11") O.C. UNLESS A PANEL TYPE CEILING FINISH IS APPLIED.
(* SEE OBC 9.23.9.4. *)

35 **COLD CELLAR SUMP** (OBC 9.40.)
FOR MAX. 2000mm (6'-2") PORCH DEPTH (SHORTEST DIM.), 125mm (4 7/8") 32MPa (4640psi) CONC. SLAB WITH 5-8% AIR ENTRAINMENT. REINF. WITH 15M BARS @ 200mm (7 7/8") O.C. EACH WAY, BOTTOM THRD OF SLAB. MIN. 30mm (1 1/4") COVER. 600x600 (23 5/8"x23 5/8") CONC. SUMP @ 600mm (23 5/8") DEEP.
SUMP TO BE PROVIDED WITH 100mm (4") DIA. PVC DRAIN TO PROVIDE 1L/1 SLAB TO HAVE MIN. 30mm (1") BEARING ON FDTN. WALL. PROVIDE 1L/1 LINTEL OVER COLDAR DOOR AND WITH 100mm (4") END BEARING.

36 **BRICK CHECK**
MIN. 100mm (4") THICK TO A MAX. DEPTH OF 600mm (24") AND SHALL BE TIED TO THE FACING MATERIAL WITH METAL TIES SPACED 200mm (8") O.C. VERTICALLY AND 900mm (36") O.C. HORIZONTALLY. FILL SPACE BETWEEN WALL AND FACING SOLID WITH MORTAR.

37 **CONVENTIONAL ROOF FRAMING (2.0Kpa- SNOW LOAD)**
38x140 (2"x6") RAFTERS @ 400mm (16"O.C.) FOR MAX 11'-7" SPAN, 38x184 (2"x8") RIDGE BOARD, 38x89 (2"x4") COLLAR TIES AT MIDSPANS. CEILING JOISTS 38 BY 38x89 (2"x4") @ 400mm (16") O.C. FOR MAX. 2830mm (9'-3") SPAN & 38x140 (2"x6") @ 400 (16") O.C. FOR MAX. 4400mm (14'-7") SPAN. RAFTERS FOR BUILT-UP ROOF TO BE 38x89 (2"x4") @ 600mm (24") O.C. WITH A 38x89 (2"x4") CENTRE POST TO THE TRUSS BELOW, LATERALLY BRACED @ 1800mm (6'-0") O.C. VERTICALLY.

38 **TWO STOREY VOIDED SPACES**
-FOR A MAXIMUM 5490 mm (18'-0") HEIGHT AND MAXIMUM SUPPORTED ROOF TRUSS LENGTH OF 6.0m, PROVIDE 2-38x140 (2-2"x6") SPRUCE STUDS @ 300mm (12") O.C. (TRIPLE UP AT EVERY THIRD DOUBLE STUD FOR BRICK WALLS) C/W 3x6 (3/8") THICK EXT. PLYWOOD SHEATHING. PROVIDE SOLID WOOD BLOCKING BETWEEN WOOD STUDS @ 1220 mm (4'-0") O.C. VERTICALLY. -FOR WALLS WITH HORIZ. DISTANCES NOT EXCEEDING 2900 mm (9'-6"), PROVIDE 38x140 (2"x6") STUDS @ 400 (16") O.C. BTN CONTINUOUS 2-38x140 (2"x6")TOP PLATES + 1-38x140 (1-2"x6") BOTTOM PLATE & MINIMUM OF 1-38x184 (2-2"x8") CONT. HEADER AT GIRDL CEILING LEVEL. TOE-NAILED & GLUED AT TOP, BOTTOM PLATES AND HEADERS.
TYPICAL 1 HOUR RATED PARTITION.
REFER TO DETAILS FOR TYPE AND SPECIFICATIONS.

39 **FOUNDATION WALL (N.O.D./V.O.D.)**
-FOR LATERAL SUPPORT WHERE DISTANCE FROM TOP TO BASEMENT SLAB EXCEEDS 1200mm (3'-11") 200mm (8") POURED CONC. FOUNDATION WALL PROVIDE VERTICAL 38x140 (2"x6") WOOD STUDS @ 400 (16") o.c. MATCH FLOOR JOIST SPACING WHEN PARALLEL WITH FLOOR JOISTS. [BANGET BOTTOM PLATE TO SLAB & FASTEN TOP OF WALL TO FLOOR JOIST AND ALSO TIED TO 38x84 (2"x4") @ 300 (12") o.c. KNEE WALL] REFER TO DETAIL FOR CLARITY.

40 **EXTERIOR WALLS FOR SUB-GRADE**
THE EXTERIOR BASEMENT STUD WALL TO BE 38x140 (2"x6") STUDS @ 400mm (16") o.c. DE 38x89 (2"x4") STUDS @ 300mm (12"o.c.

WOOD LINTELS AND BUILT-UP WOOD BEAMS

L1 ---- 2/38 x 184 (2/2" x 8") SPR.#2
B1 ---- 2/38 x 184 (3/2" x 8") SPR#2
B2 ---- 4/38 x 184 (3/2" x 8") SPR#2
B7 ---- 5/38 x 184 (5/2" x 8") SPR#2

B2 ---- 2/38 x 235 (2/2" x 10") SPR#2
B3 ---- 3/38 x 235 (3/2" x 10") SPR#2
B4 ---- 4/38 x 235 (4/2" x 10") SPR#2

B5 ---- 2/38 x 286 (2/2" x 12") SPR#2
B6 ---- 3/38 x 286 (3/2" x 12") SPR#2
B8 ---- 4/38 x 286 (4/2" x 12") SPR#2

LOOSE STEEL LINTELS

L7 ------ 89 x 89 x 6.4L (3-1/2" x 3-1/2" x 1/4")
L8 ------ 89 x 89 x 7.9L (3-1/2" x 3-1/2" x 5/16")
L9 ------ 102 x 89 x 7.9L (4" x 3-1/2" x 5/16")
L10 ----- 127 x 89 x 7.9L (5" x 3-1/2" x 5/16")
L11 ----- 127 x 89 x 11.0L (5" x 3-1/2" x 7/16")
L12 ----- 152 x 102 x 11.0L (6" x 4" x 7/16")
L13 ----- 178 x 102 x 11.0L (7" x 4" x 7/16")

LAMINATED VENEER LUMBER (LVL) BEAMS

LVL14 ---- 1-1 3/4"(44) 1/4" (2-45x184)
LVL1 ----- 2-1 3/4"(44) 1/4" (2-45x184)
LVL2 ----- 2-1 3/4"(44) 1/4" (2-45x235)
LVL3 ----- 2-1 3/4"(44) 1/4" (2-45x286)

LVL4A ---- 1-1 3/4"(44) 1/2" (1-45x240)
LVL5 ----- 2-1 3/4"(44) 1/2" (2-45x240)
LVL5 ----- 3-1 3/4"(44) 1/2" (3-45x240)
LVL5A ---- 4-1 3/4"(44) 1/2" (4-45x240)

LVL6A ---- 1-1 3/4"(44) 7/8" (1-45x300)
LVL6 ----- 2-1 3/4"(44) 7/8" (2-45x300)
LVL7 ----- 3-1 3/4"(44) 7/8" (3-45x300)
LVL7A ---- 4-1 3/4"(44) 7/8" (4-45x300)

WINDOWS:
1) MINIMUM BEDROOM WINDOW - OBC. 9.9.10.1.(1)
AT LEAST ONE BEDROOM WINDOW ON A GIVEN FLOOR IS TO HAVE MIN. 0.35m2 UNOBSTRUCTED GLAZED OR OPENABLE AREA WITH MIN. CLEAR WIDTH OF 380 mm (1'-3").
2) WINDOW GUARDS - OBC. 9.8.8.1.(6)
A GUARD IS REQUIRED WHERE THE SILL OF THE WINDOW SILL IS LOCATED LESS THAN 480mm (1'-7") ABOVE FIN. FLOOR AND THE DISTANCE FROM THE FIN. FLOOR TO THE ADJACENT GRADE IS GREATER THAN 1800mm (5'-11")
3) EXTERIOR WINDOWS
SHALL COMPLY WITH OBC DIV-B 9.7.3. & SB12-2.1.8.

DOOR SCHEDULE

1	EXTERIOR DOOR	915 x 2035 x 45 (3'-0" x 6'-8" x 1-3/4") INSULATED MIN. R5.0 (7.8kl)	
1A	EXTERIOR DOOR	865 x 2035 x 45 (2'-10" x 6'-8" x 1-3/4") INSULATED MIN. R5.0 (7.8kl)	
1B	EXTERIOR DOOR	915 x 2030 x 45 (3'-0" x 6'-8" x 1-3/4") INSULATED MIN. R5.0 (7.8kl)	
1C	EXTERIOR DOOR	815 x 2335 x 45 (2'-8" x 7'-8" x 1-3/4") INSULATED MIN. R5.0 (7.8kl)	
1D	EXTERIOR DOOR	815 x 2035 x 45 (2'-8" x 6'-8" x 1-3/4")	
1E	EXTERIOR DOOR	915 x 2335 x 45 (3'-0" x 7'-8" x 1-3/4") 20 MIN. RATED DOOR AND FRAME, WITH APPROVED SELF CLOSING DEVICE INSULATED MIN. R5.0 (7.8kl)	
1F	EXTERIOR DOOR	915 x 2030 x 45 (3'-0" x 6'-8" x 1-3/4") WEATHERSTRIPPED INSTALLED	
2	INTERIOR DOOR	760 x 2030 x 35 (2'-6" x 6'-8" x 1-3/8")	
3	INTERIOR DOOR	610 x 2030 x 35 (2'-0" x 6'-8" x 1-3/8")	
4	INTERIOR DOOR	660 x 2030 x 35 (2'-2" x 6'-8" x 1-3/8")	
5	INTERIOR DOOR	460 x 2030 x 35 (1'-4" x 6'-8" x 1-3/8")	

REFER TO INSULATION CHART FOR SB-12 COMPLIANCE PACKAGE TO BE USED FOR THIS MODEL.
The minimum thermal performance of building envelope and equipment shall conform to the selected package unless otherwise noted.

GENERAL: 1) MECHANICAL VENTILATION IS REQUIRED TO COMPLY WITH OBC-DIV. B, 6.2.2. SEE MECHANICAL.
2) ALL DOWNSPOUTS TO DRAIN AWAY FROM THE BUILDING AS PER OBC 9.26.18.2., 5.6.2.(2) AND MUNICIPAL STANDARDS.
3) ALL WINDOW WELLS TO DRAIN TO FOOTING LEVEL PER OBC 9.14.6.3. CHECK WITH THE LOCAL AUTHORITY.
4) STUD WALL REINFORCEMENT FOR FUTURE GRAB BARS IN MAIN BATHROOM REINFORCEMENT OF STUD WALLS SHALL BE INSTALLED ADJACENT WATER CLOSETS AND SHOWER OR BATHTUB IN MAIN BATHROOM. REFER TO OBC. 9.5.2.3., 3.8.3.8.(7)(d) & 3.8.3.13.(1)(f). SEE DETAIL.
5) ALL EXTERIOR DOORS TO COMPLY WITH THERMAL RESISTANCE AS STATED IN O.B.C.
6) ALL AIR BARRIER SYSTEMS ARE REQUIRED TO COMPLY WITH O.B.C. DIV.-B 9.25.3.
7) ALL LUMBER SHALL BE SPRUCE NO.2 GRADE, UNLESS NOTED OTHERWISE.
2) STUDS SHALL BE STUD GRADE SPRUCE, UNLESS NOTED OTHERWISE.
3) LUMBER EXPOSED TO THE EXTERIOR TO BE SPRUCE No. 2 GRADE PRESSURE TREATED OR CEDAR, UNLESS NOTED OTHERWISE.
4) ALL LAMINATED VENEER LUMBER (LVL) BEAMS, GIRDER TRUSSES, AND METAL HANGER CONNECTIONS SUPPORTING ROOF FRAMING TO BE DESIGNED & CERTIFIED BY TRUSS MANUFACTURER.
5) LVL BEAMS SHALL BE 2.0E -2950Fb MIN., NAIL EACH PLY OF LVL WITH 89mm (3 1/2") LONG COMMON NAILS @ 300mm (12") O.C. EACH PLY. FOR 184, 240 & 300mm (7 1/4"& 1/2", 11 7/8") DEPTHS AND STAGGERED IN 3 ROWS FOR GREATER DEPTHS AND FOR 4 PLY MEMBERS ADD 76mm (3") DIA. GALVANIZED BOLTS BOLTED AT MID-DEPTH OF BEAM @ 915mm (3'-0") O.C.
6) PROVIDE TOP LAYER BEAM HANGERS TYPE "U" MANUFACTURED BY SIMPSON STRONG TIE OR EQUAL FOR ALL LVL BEAM TO BEAM CONNECTIONS UNLESS NOTED OTHERWISE.
7) JOISTS HANGERS: PROVIDE METAL HANGERS FOR ALL JOISTS AND BUILT-UP WOOD MEMBERS. PROVIDE FLUSH BLOCKING FOR WOOD MEMBERS.
8) WOOD FRAME NOT TREATED WITH A WOOD PRESERVATIVE, IN CONTACT WITH CONCRETE, SHALL BE SEPARATED FROM THE CONC. BY AT LEAST 2 mil. POLYETHYLENE FILM. No.50 (45lbs.) ROLL ROOFING OR OTHER DAMPPROOFING MATERIAL, EXCEPT WHERE THE WOOD MEMBER IS AT LEAST 150mm (6") ABOVE THE GROUND.

STEEL: 1) STRUCTURAL STEEL SHALL CONFORM TO CAN/CSA-G40-21 GRADE 350W, HOLLOW STRUCTURAL SECTIONS SHALL CONFORM TO CSA-G40.21 GRADE 350W "STRUCTURAL QUALITY". OBC. B-9.23.4.3.
2) REINFORCING STEEL SHALL CONFORM TO CSA-G30-18M GRADE 400R.

STUCCO: 1) ALL STUCCO WALLS TO HAVE A MINIMUM 10mm APR SPACE BEHIND THE CLADDING WITH POSITIVE DRAINAGE TO THE EXTERIOR. THE EXTERIOR SHEATHING MUST NOT BE GYPSUM BASED. ALL STUCCO TO BE INSTALLED AS PER MANUFACTURERS SPECIFICATIONS.

LEGEND

CLASS 'B' VENT
EXHAUST VENT
DUPLEX OUTLET (12" HIGH)
DUPLEX OUTLET (HEIGHT AS NOTED A.F.F)
WEATHERPROOF DUPLEX OUTLET
HEAVY DUTY OUTLET
POT LIGHT
LIGHT FIXTURE (CEILING MOUNTED)
LIGHT FIXTURE (PULL CHAIN)
LIGHT FIXTURE (WALL MOUNTED)
SWITCH
FLOOR DRAIN
HOSE BIB
DJ DOUBLE JOIST
TJ TRIPLE JOIST
LVL LAMINATED VENEER LUMBER
C.T. GIRDER TRUSS OR ROOF TRUSS MANUF.
FLAT ARCH
CURVED ARCH
MEDICINE CABINET
CONC. BLOCK WALL
DOUBLE VOLUME WALL SEE NOTE 39

MECHANICAL SYMBOLS
HEAT PIPE
PLUMBING (TOILET)
PLUMBING (BATH, SHOWER)
WARM AIR
RETURN AIR DUCT

SOLID WOOD BEARING (SPRUCE No. 2).
SOLID BEARING - NO SPACING.
SUPPORTED MEMBER OR AS DIRECTED BY STRUCTURAL ENGINEER.
SOLID BEARING TO BE MINIMUM 2 PIECES.
SOLID WOOD BEARING TO MATCH FROM ABOVE

SMOKE ALARM (REFER TO OBC 9.10.19)
PROVIDE: 1. PER FLOOR, SEAR THE STARS CONNECTING THE FLOOR LEVEL AND ALS

PACKAGE J

STUD WALL REINFORCEMENT FOR FUTURE GRAB BARS IN MAIN BATHROOM

REINFORCEMENT OF STUD WALLS SHALL BE INSTALLED ADJACENT TO WATER CLOSETS AND SHOWER OR BATHTUB IN MAIN BATHROOM.
FUTURE GRAB BARS TO BE MOUNTED TO RESIST HORIZ. AND VERT. LOADS OF 1.3 KN (300 lb)
REFER TO OBC. DIV. B– 9.5.2.3.. WATER CLOSET 3.8.3.8.(3)(a) & 3.8.3.8.(3)(c).. SHOWER 3.8.3.13.(2)(f).. BATHTUB & 3.8.3.13.(4)(c). AND DETAILS PROVIDED.

BUILT-UP WOOD POST DOUBLE OR TRIPLE STUDS NAILED TOGETHER W/ 3" LONG COMMON NAILS @ 11 3/4" O.C. MAX. VERT. (AS PER O.B.C. 9.17.4.2)



① VERTICAL STUDS

VERTICAL STUDS	
9'–0" HIGH CEILINGS	8'–0" HIGH CEILINGS
2/2"x6" SPR. #2 OR 3/2"x4" SPR. #2	2/2"x6" SPR. #2 OR 3/2"x4" SPR. #2 (4" WALL)

② SOLID BLOCKING
2/2"x8" SPR. #2 NAILED WITH 3–ROWS OF 3" LONG COMMON NAILS @ 6" O.C. AND END NAILED TO STUDS WITH 6–3 1/2" LONG COMMON NAILS



GB1 FUTURE GRAB BAR @ TOILET (BACK WALL) — OBC. DIV.B–3.8.3.8.(3)(c)

GB1A FUTURE L–SHAPE GRAB BAR DETAIL (*ONLY IF SIDE WALL PRESENT) — OBC. DIV.B–3.8.3.8.(3)(a)



GB3 FUTURE L–SHAPE GRAB BAR DETAIL @ SHOWER (BACK WALL) — OBC. DIV.B–3.8.3.13.(2)(f)

GB4 FUTURE GRAB BAR IN BATHTUB (SIDE VIEW) — OBC. DIV.B–3.8.3.13.(4)(c)

GB4A FUTURE GRAB BAR IN BATHTUB (VERTICAL BAR LOCATED @ EACH END WALL) — OBC. DIV.B–3.8.3.13.(2)(f)

** MAX. HEIGHT FOR 2"x6" EXTERIOR WALL IS AS FOLLOW:
2"x6" @ 16" O.C. – 12'–6"
2"x6" @ 12" O.C. – 13'–10"
2–2"x6" @ 16" O.C. – 15'–0"
2–2"x6" @ 12" O.C. – 17'–4"

MAX. HEIGHT FOR 2"x8" EXTERIOR WALL IS AS FOLLOWS:
2"x8" @ 16" O.C. – 16'–0"
2"x8" @ 12" O.C. – 17'–9"
2–2"x8" @ 16" O.C. – 20'–4"
2–2"x8" @ 12" O.C. – 22'–4"

NOTES:
1. FOR ROOF DESIGN SNOW LOAD OF 2.6 KPa
2. SUPPORTED ROOF TRUSS LENGTH OF 6.0m ONLY.
3. PROVIDE HORIZONTAL SOLID BLOCKING 1200 O.C. (4'–0")
4. PROVIDE A MINIMUN OF 9.5mm (3/8") PLYWOOD OR OSB EXTERIOR SHEATHING ON THE EXTERIOR FACE AND 12.5mm (1/2") GYPSUM BOARD ON THE INTERIOR FACE.
5. WALL FRAMING SHALL CONFORM TO OBC 9.23.10.1.(2)

** STUD INFORMATION TAKEN FROM OBC TABLE A–30

MAX. HEIGHT FOR 2"x4" GARAGE WALL IS AS FOLLOW:

SIDING	BRICK VENEER
2"x4" @ 16" O.C. – 9'–10"	2"x4" @ 16" O.C. – 8'–0"
2–2"x4" @ 12" O.C. – 10'–9"	2"x4" @ 12" O.C. – 8'–10"
3–2"x4" @ 16" O.C. – 11'–2"	2–2"x4"@ 16" O.C. – 10'–1"
3–2"x4" @ 12" O.C. – 12'–4"	2–2"x4"@ 12" O.C. – 10'–9"
	3–2"x4"@ 16" O.C. – 11'–2"
	3–2"x4"@ 12" O.C. – 12'–4"

NOTES:
1. FOR ROOF DESIGN SNOW LOAD OF 2.6 KPa
2. SUPPORTED ROOF TRUSS LENGTH OF 6.0m AND FLOOR JOIST LENGTH OF 2.5m OF ONE FLOOR
3. PROVIDE HORIZONTAL SOLID BLOCKING 1200 O.C. (4'–0")
4. PROVIDE A MINIMUM OF 9.5mm (3/8") PLYWOOD OR OSB EXTERIOR SHEATHING ON THE EXTERIOR FACE



✳ REVISED– 27 SEPTEMBER 2012

EW TYPICAL EXT. WALL AIR BARRIER CONTINUITY SECTION W/ BRICK VENEER SCALE: 1/2" = 1'–0"



✳ REVISED– 15 MARCH 2013

SECTION AT W.O.D/W.O.B.

PACKAGE 'J'

THE MINIMAL THERMAL PERFORMANCE OF BUILDING ENVELOPE AND EQUIPMENT SHALL CONFORM TO THE FOLLOWING SB–12 COMPLIANCE PACKAGE AS PER OBC SUPPLEMENTARY STANDARD SB–12, SECTION 2.1.1.1

USE SB–12 COMPLIANCE PACKAGE (J):

COMPONENT	J	Notes:
Ceiling with Attic Space Minimum RSI (R) value	8.81 (R50)	BLOWN –LOOSE
Ceiling without Attic Space Minimum RSI (R) value	5.46 (R31)	BATT or SPRAY
Exposed Floor Minimum RSI (R) value	5.46 (R31)	BATT or SPRAY
Walls Above Grade Minimum RSI (R) value	3.87 (R22)	6" R22 BATT
Basement Walls Minimum RSI (R) value	2.11 (R12)	4" R12 BLANKET
Edge of Below Grade Slab ≤600mm below grade Minimum RSI (R) value	1.76 (R10)	RIGID INSUL
Windows & Sliding glass Doors Maximum U–value	1.8	DOUBLE PANE LOW EMISSIVITY
Skylights Maximum U–value	2.8	DOUBLE PANE LOW EMISSIVITY
Space Heating Equipment Minimum AFUE	94%	NATURAL GAS
Hot Water Heater Minimum EF	0.67	NATURAL GAS
HRV Minimum Efficiency	60%	–



SECOND FLOOR PLAN 'A'
4 BEDROOM



PART. SECOND FLOOR PLAN 'B'
4 BEDROOM



SECTION A–A

NOTE:
DIMENSIONS/STRUCTURE IN BRACKETS REPRESENT EL.'B'

NOTE:
ALL L/4.'S SUPPORTING FLOOR LOADS ARE TO BE SPECIFIED BY THE FLOOR TRUSS MANUFACTURER.

NOTE:
REFER TO STANDARD FLOOR PLANS FOR ADDITONAL INFORMATION.

NOTE:
SPACE ALL FLOOR JOISTS @ 12" O.C. UNDER ALL CERAMIC TILE AREAS.

NOTE:
ROOF TRUSS INFORMATION REFER TO ROOF TRUSS SHOP DRAWINGS FOR ALL ROOF FRAMING INFORMATION UNLESS OTHERWISE NOTED.

35–1

no.	description	date	by
10		-	-
9		-	-
8	REV AS PER ENG COMMENTS	FEB 04–15	RC
7	UPDATE TO OBC 2012 AND ENG COMMENTS	JAN 30–15	RC
6	CHANGE WINDOW MANUF. / UPDATE TO SB12	MAR. 19/12	AA
5	ISSUED FOR PERMIT	DEC. 19/07	KL
4	REVISED AS PER ENGINEER'S COMMENTS	DEC 10/07	KL
3	REVISED AS PER TRUSS MANUF.'S COMMENTS	NOV 13/07	KL
2	ISSUED FOR CLIENT REVIEW	SEPT 26/07	KL
1	INTRO FROM PROJECT 05008	JUN. 21/07	KL

Contractor must verify all dimensions on the job and report any discrepancy to the Designer before proceeding with the work. All drawings and specifications are instruments of service and the property of the architect which must be returned at the completion of the work. Drawings are not to be scaled.

VA3 DESIGN
300A Wilson Avenue
Toronto ON M3H 1S8
t 416.630.2255
f 416.630.4782
va3design.com

All drawings specifications, related documents and designs are the copyright property of VA3 DESIGN. Reproduction of this property in whole or in part is strictly prohibited without VA3 DESIGN's written permission.

The undersigned has reviewed and takes responsibility for this design and has the qualifications and meets the requirements set out in the Ontario Building Code to be a designer.
qualification information
Wellington Jnc–Bogdale — 25591
name — BCIN
registration information — VA3 Design Inc. — 42658

project name: BAYVIEW WELLINGTON
VICTORIA VILLAGE
municipality: ST CATHERINES
project no.: 07004
unit name: PRESTON 1
unit no.: 35–1
title: FLOOR PLAN & SECTION
date: JUNE 2007
scale: 3/16" = 1'–0"
drawn by: JM / KL
checked by: DF
file name: 07004–35–1–OBC2012
sheet no.: 2/4



REAR UPGRADE ELEVATION 'A' -4BED

REAR UPGRADE ELEVATION 'A' -3BED



RIGHT ELEVATION 'A'



REAR ELEVATION 'A' - 4BED

REAR ELEVATION 'A' - 3BED



LEFT ELEVATION 'A'



FRONT ELEVATION 'A'

UNINSULATED OPENINGS (PER OBC. SB-12,2.1.1.(7)		ELEVATION A 3 BED
TOTAL INSULATED WALL AREA	2373.60 S.F.	220.51 S.M.
TOTAL UNINSULATED OPENINGS	223.40 S.F.	20.75 S.M.
PERCENTAGE OF OPENINGS	9.41 %	9.41 %

UNINSULATED OPENINGS (PER OBC. SB-12,2.1.1.(7)		ELEVATION A 4 BED
TOTAL INSULATED WALL AREA	2373.60 S.F.	220.51 S.M.
TOTAL UNINSULATED OPENINGS	236.73 S.F.	21.99 S.M.
PERCENTAGE OF OPENINGS	9.97 %	9.97 %



ROOF PLAN UPGRADE 'A'
N.T.S.



ROOF PLAN 'A'
N.T.S.

no.	description	date	by
10		-	-
9		-	-
8	REV AS PER ENG COMMENTS	FEB 04-15	RC
7	UPDATE TO OBC 2012 AND ENG COMMENTS	JAN. 30-15	RC
6	CHANGE WINDOW MANUF./ UPDATE TO SB12	MAR. 19/13	AK
5	ISSUED FOR PERMIT	DEC. 19/07	KL
4	REVISED AS PER ENGINEER'S COMMENTS	DEC 10/07	KL
3	REVISED AS PER TRUSS MANUF.'S COMMENTS	NOV 13/07	KL
2	ISSUED FOR CLIENT REVIEW	SEPT 26/07	KL
1	INTRO FROM PROJECT 05008	JUN. 21/07	KL

Contractor must verify all dimensions on the job and report any discrepancy to the Designer before proceeding with the work. All drawings and specifications are instruments of service and the property of the architect which must be returned at the completion of the work. Drawings are not to be scaled.

VA3 DESIGN
300A Wilson Avenue
Toronto ON M3H 1S8
t 416.630.2255
f 416.630.4782
va3design.com

All drawings specifications, related documents and designs are the copyright property of VA3 DESIGN. Reproduction of this property in whole or in part is strictly prohibited without VA3 DESIGN's written permission.

The undersigned has reviewed and takes responsibility for this design, and has the qualifications and meets the requirements set out in the Ontario Building Code to be a Designer.
qualification information
Wellington Jino-Baptiste signature 25591
name registration number BCIN
registration information VA3 Design Inc. 42658

BAYVIEW WELLINGTON

project name: VICTORIA VILLAGE
municipality: ST CATHERINES
project no.: 07004
unit name: PRESTON 1
unit no.: 35-1
title: ELEVATIONS
date: JUNE 2007
scale: 3/16" = 1'-0"
drawn by: JM / KL
checked by: OF
file name: 07004-35-1-OBC2012
drawing no.: 3/4

35-1













UNINSULATED OPENINGS (PER OBC, SB-12,2.1.1.(7)		ELEVATION B 3 BED
TOTAL INSULATED WALL AREA	2334.17 S.F.	216.85 S.M.
TOTAL UNINSULATED OPENINGS	243.89 S.F.	22.66 S.M.
PERCENTAGE OF OPENINGS	10.45 %	10.45 %

UNINSULATED OPENINGS (PER OBC, SB-12,2.1.1.(7)		ELEVATION B 4 BED
TOTAL INSULATED WALL AREA	2334.05 S.F.	216.84 S.M.
TOTAL UNINSULATED OPENINGS	257.22 S.F.	23.90 S.M.
PERCENTAGE OF OPENINGS	11.02 %	11.02 %



ROOF PLAN UPGRADE 'B'
N.T.S.



ROOF PLAN 'B'
N.T.S.

no.	description	date	by
10		-	-
9		-	-
8	REV AS PER ENG COMMENTS	FEB 04-15	RC
7	UPDATE TO OBC 2012 AND ENG COMMENTS	JAN 30-15	RC
6	CHANGE WINDOW MANUF./ UPDATE TO SB12	MAR. 19/12	KM
5	ISSUED FOR PERMIT	DEC. 19/07	KL
4	REVISED AS PER ENGINEER'S COMMENTS	DEC 10/07	KL
3	REVISED AS PER TRUSS MANUF.'S COMMENTS	NOV 13/07	KL
2	ISSUED FOR CLIENT REVIEW	SEPT 26/07	KL
1	INTRO FROM PROJECT 05008	JUN. 21/07	KL

Contractor must verify all dimensions on the job and report any discrepancy to the Designer before proceeding with the work. All drawings and specifications are instruments of service and the property of the architect which must be returned at the completion of the work. Drawings are not to be scaled.

VA3 DESIGN
300A Wilson Avenue
Toronto ON M3H 1S8
t 416.630.2255
f 416.630.4782
va3design.com

All drawings specifications, related documents and design are the copyright property of VA3 DESIGN. Reproduction of this property in whole or in part is strictly prohibited without VA3 DESIGN's written permission.

The undersigned has reviewed and takes responsibility for this design and has the qualifications and meets the requirements set out in the Ontario Building Code to be a Designer.
qualification information
Wellington Jno-Baptiste signature 25591
name BCIN
registration information
VA3 Design Inc. 42658

BAYVIEW WELLINGTON

project name
VICTORIA VILLAGE
municipality
ST CATHERINES
project no. 07004
unit name
PRESTON 1
unit no. 35-1
title
ELEVATIONS
date JUNE 2007
scale 3/16" = 1'-0"
drawing no. 4/4
drawn by JM / KL
checked by
file name 07004-35-1-OBC2012
of

35-1