


Schedule 1: Designer Information

Use one form for each individual who reviews and takes responsibility for design activities with respect to the project.

A. Project Information			
Building number, street name		Unit no.	Lot/con.
Municipality VAUGHAN (WOODBIDGE)	Postal code	Plan number/ other description	
B. Individual who reviews and takes responsibility for design activities			
Name MICHAEL O'ROURKE		Firm HVAC DESIGNS LTD.	
Street address 375 FINLEY AVE		Unit no. 202	Lot/con. N/A
Municipality AJAX	Postal code L1S 2E2	Province ONTARIO	E-mail info@hvacdesigns.ca
Telephone number (905) 619-2300	Fax number (905) 619-2375	Cell number ()	
C. Design activities undertaken by individual identified in Section B. [Building Code Table 3.5.2.1 OF Division C]			
<input type="checkbox"/> House <input type="checkbox"/> Small Buildings <input type="checkbox"/> Large Buildings <input type="checkbox"/> Complex Buildings			
<input checked="" type="checkbox"/> HVAC – House <input type="checkbox"/> Building Services <input type="checkbox"/> Detection, Lighting and Power <input type="checkbox"/> Fire Protection			
<input type="checkbox"/> Building Structural <input type="checkbox"/> Plumbing – House <input type="checkbox"/> Plumbing – All Buildings <input type="checkbox"/> On-site Sewage Systems			
Description of designer's work HEAT LOSS / GAIN CALCULATIONS DUCT SIZING RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY RESIDENTIAL SYSTEM DESIGN per CSA-F280-12		Model: 5011 TIMBERLAND - LOTS 72 & 101 Project: PINE VALLEY PH 2	
D. Declaration of Designer			
I, <u>MICHAEL O'ROURKE</u>		declare that (choose one as appropriate):	
(print name)			
<input type="checkbox"/> I review and take responsibility for the design work on behalf of a firm registered under subsection 3.2.4. of Division C, of the Building Code. I am qualified, and the firm is registered, in the appropriate classes/categories. Individual BCIN: _____ Firm BCIN: _____			
<input checked="" type="checkbox"/> I review and take responsibility for the design and am qualified in the appropriate category as an "other designer" under subsection 3.2.5. of Division C, of the Building Code. Individual BCIN: <u>19669</u> Basis for exemption from registration and qualification: <u>O.B.C SENTENCE 3.2.4.1 (4)</u>			
<input type="checkbox"/> The design work is exempt from the registration and qualification requirements of the Building Code. Basis for exemption from registration and qualification: _____			
I certify that:			
1. The information contained in this schedule is true to the best of my knowledge. 2. I have submitted this application with the knowledge and consent of the firm.			
July 12, 2022			
Date		Signature of Designer	

NOTE:

- For the purposes of this form, "individual" means the "person" referred to in Clause 3.2.4.7(1) d). of Division C, Article 3.2.5.1. of Division C, and all other persons who are exempt from qualification under Subsections 3.2.4. and 3.2.5. of Division C.
- Schedule 1 is not required to be completed by a holder of a license, temporary license, or a certificate of authorization, issued by the Ontario Association of Architects. Schedule 1 is also not required to be completed by a holder of a license to practise, a limited license to practise, or a certificate of authorization, issued by the Association of Professional Engineers of Ontario.

Application for a Permit Construct or Demolish – Effective January 1, 2015

SITE NAME: PINE VALLEY PH 2

TIMBERLAND - LOTS 72 & 101

DATE Jul-22

WINTER NATURAL AIR CHANGE RATE 0.340

HEAT LOSS ΔT °F. 76

CSA-F280-12

BUILDER: GOLD PARK HOMES

TYPE: 5011

GFA: 4238

LO# 98030

SUMMER NATURAL AIR CHANGE RATE 0.114

HEAT GAIN ΔT °F. 13

SB-12 PACKAGE A1

ROOM USE	PBR		ENS		WIC		BED-2		BED-3		BED-4		ENS-2		ENS-3		WIC-E		ENS-4					
EXP. WALL	40		15		8		13		15		44		10		16		12		10					
CLG. HT.	9		9		9		9		9		9		9		9		9		9					
FACTORS																								
GRS.WALL AREA	LOSS	GAIN	360		135		72		117		135		396		90		144		108		90			
GLAZING	LOSS	GAIN	LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN			
NORTH	21.3	16.0	0	0	0	0	0	0	0	18	383	288	0	0	0	0	0	0	0	0	0	0		
EAST	21.3	41.6	0	0	0	0	0	0	0	0	0	0	25	532	1039	64	1362	2659	0	0	0	0		
SOUTH	21.3	24.9	21	447	523	21	447	523	21	447	523	0	0	0	0	0	0	0	0	0	6	128	149	
WEST	21.3	41.6	53	1128	2202	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
SKYL.T.	37.2	101.5	8	279	762	0	0	0	0	0	0	0	8	279	762	8	279	762	8	279	762	0	0	0
DOORS	25.2	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
NET EXPOSED WALL	4.5	0.8	286	1276	215	114	509	86	51	228	38	99	442	74	110	491	83	311	1388	234	90	402	68	
NET EXPOSED BSMT WALL ABOVE GR	3.6	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED CLG	1.3	0.6	393	504	231	245	314	144	204	262	120	330	423	194	203	260	119	265	339	155	67	86	39	
NO ATTIC EXPOSED CLG	2.7	1.3	0	0	0	0	0	0	0	0	0	0	0	0	48	132	60	83	228	104	0	0	0	
EXPOSED FLOOR	2.6	0.4	0	0	0	0	0	0	74	189	32	141	360	61	258	658	111	0	0	0	117	298	50	
BASEMENT/CRAWL HEAT LOSS			0			0			0			0			0			0			0			
SLAB ON GRADE HEAT LOSS			0			0			0			0			0			0			0			
SUBTOTAL HT LOSS			3634		1270		1125		1887		2352		4044		786		1248		698		778			
SUB TOTAL HT GAIN			3932		753		713		1378		2173		4437		157		693		279		388			
LEVEL FACTOR / MULTIPLIER	0.20	0.34	0.20		0.34		0.20		0.34		0.20		0.34		0.20		0.34		0.20		0.34			
AIR CHANGE HEAT LOSS			1244		435		385		646		805		1384		269		427		239		266			
AIR CHANGE HEAT GAIN			275		53		50		97		152		311		11		49		20		27			
DUCT LOSS			0		0		151		253		316		0		105		168		0		0			
DUCT GAIN			0		0		76		230		315		0		76		133		0		0			
HEAT GAIN PEOPLE	240	2	480		0		0		1		240		1		240		0		0		0			
HEAT GAIN APPLIANCES/LIGHTS			588		0		0		588		588		588		588		588		588		588			
TOTAL HT LOSS BTU/H			4878		1705		1661		2785		3472		5427		1160		1843		937		1044			
TOTAL HT GAIN x 1.3 BTU/H			6858		1047		1091		3292		4509		7249		1081		1900		1152		1304			

ROOM USE	GRT		DIN		KT/BF		LIB		LND		FOY		MUD		BAS		
EXP. WALL	46		35		67		24		10		22		28		216		
CLG. HT.	20		11		11		11		9		11		11		10		
FACTORS																	
GRS.WALL AREA	LOSS	GAIN	920		385		737		264		90		242		308		
GLAZING	LOSS	GAIN	LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		
NORTH	21.3	16.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EAST	21.3	41.6	0	0	0	0	0	0	30	638	1247	0	0	0	0	0	
SOUTH	21.3	24.9	0	0	50	1064	1245	39	830	971	27	575	672	9	192	224	
WEST	21.3	41.6	121	2575	5028	0	0	0	106	2256	4405	0	0	0	0	0	
SKYL.T.	37.2	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
DOORS	25.2	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
NET EXPOSED WALL	4.5	0.8	799	3566	601	335	1495	252	592	2642	445	207	924	156	81	361	61
NET EXPOSED BSMT WALL ABOVE GR	3.6	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED CLG	1.3	0.6	303	389	178	0	0	0	0	0	0	180	231	106	0	0	
NO ATTIC EXPOSED CLG	2.7	1.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED FLOOR	2.6	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
BASEMENT/CRAWL HEAT LOSS			0			0			0			0			0		
SLAB ON GRADE HEAT LOSS			0			0			0			0			0		
SUBTOTAL HT LOSS			6529		2559		5728		2137		784		2124		1790		
SUB TOTAL HT GAIN			5806		1497		5821		2074		391		1307		302		
LEVEL FACTOR / MULTIPLIER	0.30	0.46	0.30		0.46		0.30		0.46		0.20		0.34		0.30		
AIR CHANGE HEAT LOSS			2988		1171		2621		978		268		972		819		
AIR CHANGE HEAT GAIN			407		105		408		145		27		92		21		
DUCT LOSS			0		0		0		0		0		0		0		
DUCT GAIN			0		0		0		0		0		0		0		
HEAT GAIN PEOPLE	240	0	0		0		0		0		0		0		0		
HEAT GAIN APPLIANCES/LIGHTS			588		588		588		588		588		588		588		
TOTAL HT LOSS BTU/H			9518		3730		8349		3115		1052		3096		2610		
TOTAL HT GAIN x 1.3 BTU/H			8841		2846		8861		3650		1308		2582		419		

TOTAL HEAT GAIN BTU/H: 59936

TONS: 4.99

LOSS DUE TO VENTILATION LOAD BTU/H: 6156

STRUCTURAL HEAT LOSS: 83059

TOTAL COMBINED HEAT LOSS BTU/H: 89215



SITE NAME: PINE VALLEY PH 2
 BUILDER: GOLD PARK HOMES

TIMBERLAND - LOTS 72 & 101
 TYPE: 5011

DATE: Jul-22

GFA: 4238 LO# 98030

FURNACE 1

HEATING CFM 985 COOLING CFM 985
 TOTAL HEAT LOSS 57,094 TOTAL HEAT GAIN 28,627
 AIR FLOW RATE CFM 17.25 AIR FLOW RATE CFM 34.41

furnace pressure 0.6
 furnace filter 0.05
 a/c coil pressure 0.2
 available pressure for s/a & r/a 0.35

FURNACE HEAT LOSS +
 HRV / ERV HEAT LOSS
 = 60172 BTUH

\$LENNOX
ML196UH070XE36B
 FAN SPEED 70
 LOW 0
 MEDLOW 0
 MEDIUM 985
 MEDIUM HIGH 1110
 HIGH 1275

AFUE = 96 %
 INPUT (BTU/H) = 66,000
 OUTPUT (BTU/H) = **63,900**
 DESIGN CFM = **985**
 CFM @ .6" E.S.P.
 TEMPERATURE RISE 60 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	0	11	5
R/A	0	0	0	3	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	21	22	23	24
ROOM NAME	FOY	GRT	GRT	GRT
RM LOSS MBH.	3.10	3.17	3.17	3.17
CFM PER RUN HEAT	53	55	55	55
RM GAIN MBH.	2.58	2.95	2.95	2.95
CFM PER RUN COOLING	89	101	101	101
ADJUSTED PRESSURE	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	53	62	58	52
EQUIVALENT LENGTH	150	120	120	150
TOTAL EFFECTIVE LENGTH	203	182	178	202
ADJUSTED PRESSURE	0.08	0.09	0.09	0.08
ROUND DUCT SIZE	6	6	6	6
HEATING VELOCITY (ft/min)	270	280	280	280
COOLING VELOCITY (ft/min)	454	515	515	515
OUTLET GRILL SIZE	4X10	4X10	4X10	4X10
TRUNK	E	D	D	D

RUN #	25	26	27	28	29	30	31	32	33	34	35	36
ROOM NAME	DIN	KT/BF	KT/BF	KT/BF	LIB	LIB	MUD	BAS	BAS	BAS	BAS	BAS
RM LOSS MBH.	3.73	2.78	2.78	2.78	1.56	1.56	2.61	5.34	5.34	5.34	5.34	5.34
CFM PER RUN HEAT	64	48	48	48	27	27	45	92	92	92	92	92
RM GAIN MBH.	2.85	2.95	2.95	2.95	1.82	1.82	0.42	0.29	0.29	0.29	0.29	0.29
CFM PER RUN COOLING	98	102	102	102	63	63	14	10	10	10	10	10
ADJUSTED PRESSURE	0.16	0.16	0.16	0.16	0.17	0.17	0.17	0.16	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	18	45	34	7	53	57	45	29	40	54	41	48
EQUIVALENT LENGTH	170	160	110	120	185	170	160	120	170	130	200	180
TOTAL EFFECTIVE LENGTH	188	205	144	127	238	227	205	149	210	184	241	228
ADJUSTED PRESSURE	0.09	0.08	0.11	0.13	0.07	0.08	0.08	0.11	0.08	0.09	0.07	0.07
ROUND DUCT SIZE	6	6	6	6	5	5	4	6	6	6	6	6
HEATING VELOCITY (ft/min)	326	245	245	245	198	198	516	469	469	469	469	469
COOLING VELOCITY (ft/min)	500	520	520	520	463	463	161	51	51	51	51	51
OUTLET GRILL SIZE	4X10	4X10	4X10	4X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10	4X10
TRUNK	E	D	E	E	E	E	D	E	D	D	D	E

SUPPLY AIR TRUNK SIZE

	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK A	0	0.00	0	0	x 8
TRUNK B	0	0.00	0	0	x 8
TRUNK C	0	0.00	0	0	x 8
TRUNK D	534	0.07	11.5	16	x 8
TRUNK E	985	0.07	14.4	24	x 8
TRUNK F	0	0.00	0	0	x 8

RETURN AIR TRUNK SIZE

	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK O	0	0.05	0	0	x 8
TRUNK P	0	0.05	0	0	x 8
TRUNK Q	0	0.05	0	0	x 8
TRUNK R	0	0.05	0	0	x 8
TRUNK S	0	0.05	0	0	x 8
TRUNK T	0	0.05	0	0	x 8
TRUNK U	0	0.05	0	0	x 8
TRUNK V	0	0.05	0	0	x 8
TRUNK W	475	0.05	11.9	16	x 8
TRUNK X	985	0.05	15.7	28	x 8
TRUNK Y	0	0.05	0	0	x 8
TRUNK Z	0	0.05	0	0	x 8
DROP	985	0.05	15.7	24	x 10

RETURN AIR #

	7	8	9	BR
AIR VOLUME	0	0	0	220
PLENUM PRESSURE	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	1	1	1	14
EQUIVALENT LENGTH	0	0	0	185
TOTAL EFFECTIVE LH	1	1	1	199
ADJUSTED PRESSURE	14.80	14.80	14.80	0.07
ROUND DUCT SIZE	0	0	0	8.2
INLET GRILL SIZE	0	0	0	8
	X	X	X	X
INLET GRILL SIZE	0	0	0	24

SITE NAME: PINE VALLEY PH 2
BUILDER: GOLD PARK HOMES

TIMBERLAND - LOTS 72 & 101
TYPE: 5011

DATE: Jul-22

GFA: 4238 LO# 98030

FURNACE 2

HEATING CFM 980 COOLING CFM 980
TOTAL HEAT LOSS 25,965 TOTAL HEAT GAIN 30,791
AIR FLOW RATE CFM 37.74 AIR FLOW RATE CFM 31.83

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 29043 BTUH

ML196UH045XE36B \$LENNOX
FAN SPEED 45

AFUE = 96 %
INPUT (BTU/H) = 44,000
OUTPUT (BTU/H) = 42,800

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	18	0	0
R/A	0	0	6	0	0

plenum pressure s/a 0.18 r/a pressure 0.17
max s/a dif press. loss 0.01 r/a grille press. Loss 0.02
min adjusted pressure s/a 0.17 adjusted pressure r/a 0.15

LOW 620
MEDLOW 685
MEDIUM 980
MEDIUM HIGH 1110
HIGH 0

DESIGN CFM = 980
CFM @ .6" E.S.P.

TEMPERATURE RISE 40 °F

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	13	15	17	18	19	20
ROOM NAME	PBR	PBR	PBR	ENS	ENS	WIC	WIC-E	BED-2	BED-2	BED-3	BED-3	BED-4	BED-4	ENS-2	ENS-3	ENS-4	LND
RM LOSS MBH.	1.63	1.63	1.63	0.85	0.85	1.66	0.94	1.39	1.39	1.74	1.74	1.81	1.81	1.16	1.84	1.04	1.05
CFM PER RUN HEAT	61	61	61	32	32	63	35	53	53	66	66	68	68	44	70	39	40
RM GAIN MBH.	2.29	2.29	2.29	0.52	0.52	1.09	1.15	1.65	1.65	2.25	2.25	2.42	2.42	1.08	1.90	1.30	1.31
CFM PER RUN COOLING	73	73	73	17	17	35	37	52	52	72	72	77	77	34	60	41	42
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	75	63	51	61	20	69	22	62	67	61	55	54	75	50	66	61	54
EQUIVALENT LENGTH	200	160	130	170	90	140	80	180	190	160	150	180	190	220	160	200	180
TOTAL EFFECTIVE LENGTH	275	223	181	231	110	209	102	242	257	221	205	234	265	270	226	261	234
ADJUSTED PRESSURE	0.06	0.08	0.1	0.07	0.16	0.08	0.17	0.07	0.07	0.08	0.08	0.07	0.06	0.06	0.08	0.07	0.07
ROUND DUCT SIZE	6	6	5	4	4	5	4	5	5	6	6	6	6	5	5	5	5
HEATING VELOCITY (ft/min)	311	311	448	367	367	463	402	389	389	337	337	347	347	323	514	286	294
COOLING VELOCITY (ft/min)	372	372	536	195	195	257	424	382	382	367	367	393	393	250	441	301	308
OUTLET GRILL SIZE	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10
TRUNK	C	C	C	C	C	C	B	B	B	B	B	A	A	B	B	A	C

ROOM NAME	38 BED-4
RM LOSS MBH.	1.81
CFM PER RUN HEAT	68
RM GAIN MBH.	2.42
CFM PER RUN COOLING	77
ADJUSTED PRESSURE	0.17
ACTUAL DUCT LGH.	72
EQUIVALENT LENGTH	210
TOTAL EFFECTIVE LENGTH	282
ADJUSTED PRESSURE	0.06
ROUND DUCT SIZE	6
HEATING VELOCITY (ft/min)	347
COOLING VELOCITY (ft/min)	393
OUTLET GRILL SIZE	4X10
TRUNK	A

SUPPLY AIR TRUNK SIZE

	TRUNK	STATIC	ROUND	RECT	VELOCITY										
	CFM	PRESS.	DUCT	DUCT	(ft/min)										
TRUNK A	243	0.06	8.9	12	x	8	365	TRUNK G	0	0.00	0	0	x	8	0
TRUNK B	595	0.06	12.4	18	x	8	595	TRUNK H	0	0.00	0	0	x	8	0
TRUNK C	852	0.06	14.2	26	x	8	590	TRUNK I	0	0.00	0	0	x	8	0
TRUNK D	0	0.00	0	0	x	8	0	TRUNK J	0	0.00	0	0	x	8	0
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0

RETURN AIR TRUNK SIZE

	TRUNK	STATIC	ROUND	RECT	VELOCITY			
	CFM	PRESS.	DUCT	DUCT	(ft/min)			
TRUNK O	0	0.05	0	0	x	8	0	0
TRUNK P	0	0.05	0	0	x	8	0	0
TRUNK Q	0	0.05	0	0	x	8	0	0
TRUNK R	0	0.05	0	0	x	8	0	0
TRUNK S	0	0.05	0	0	x	8	0	0
TRUNK T	0	0.05	0	0	x	8	0	0
TRUNK U	0	0.05	0	0	x	8	0	0
TRUNK V	0	0.05	0	0	x	8	0	0
TRUNK W	0	0.05	0	0	x	8	0	0
TRUNK X	980	0.05	15.7	28	x	8	630	630
TRUNK Y	480	0.05	12	16	x	8	540	540
TRUNK Z	330	0.05	10.4	12	x	8	495	495
DROP	980	0.05	15.7	24	x	10	588	588

RETURN AIR #

	1	2	3	4	5	6	BR															
AIR VOLUME	245	75	75	75	255	255	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	74	67	63	49	48	57	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	215	215	190	225	205	195	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	289	282	253	274	253	252	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.05	0.05	0.06	0.05	0.06	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	9.3	6	5.7	6	9	9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	30	14	14	14	30	30	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

TYPE: 5011
 SITE NAME: PINE VALLEY PH 2

LO # 98030
 TIMBERLAND - LOTS 72 & 101

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES 9.32.3.1(1)

a) Direct vent (sealed combustion) only

b) Positive venting induced draft (except fireplaces)

c) Natural draft, B-vent or induced draft gas fireplace

d) Solid Fuel (including fireplaces)

e) No Combustion Appliances

HEATING SYSTEM

Forced Air Non Forced Air

Electric Space Heat

HOUSE TYPE 9.32.1(2)

I Type a) or b) appliance only, no solid fuel

II Type I except with solid fuel (including fireplaces)

III Any Type c) appliance

IV Type I, or II with electric space heat

Other: Type I, II or IV no forced air

SYSTEM DESIGN OPTIONS O.N.H.W.P.

1 Exhaust only/Forced Air System

2 HRV with Ducting/Forced Air System

3 HRV Simplified/connected to forced air system

4 HRV with Ducting/non forced air system

Part 6 Design

TOTAL VENTILATION CAPACITY 9.32.3.3(1)

Basement + Master Bedroom	<u>2</u>	@ 21.2 cfm	<u>42.4</u>	cfm
Other Bedrooms	<u>3</u>	@ 10.6 cfm	<u>31.8</u>	cfm
Kitchen & Bathrooms	<u>6</u>	@ 10.6 cfm	<u>63.6</u>	cfm
Other Rooms	<u>4</u>	@ 10.6 cfm	<u>42.4</u>	cfm
Table 9.32.3.A.		TOTAL	<u>180.2</u>	cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED 9.32.3.4.(1)

1	Bedroom	31.8	cfm
2	Bedroom	47.7	cfm
3	Bedroom	63.6	cfm
4	Bedroom	79.5	cfm
5	Bedroom	95.4	cfm
	TOTAL	79.5	cfm

SUPPLEMENTAL VENTILATION CAPACITY 9.32.3.5.

Total Ventilation Capacity	<u>180.2</u>	cfm
Less Principal Ventil. Capacity	<u>150</u>	cfm
Required Supplemental Capacity	<u>30.2</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY

Model: VANEE V150H Location: BSMT

150.0 cfm HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION

CFM		ΔT °F		FACTOR		% LOSS
150.0 CFM	X	76 F	X	1.08	X	0.25

SUPPLEMENTAL FANS BY INSTALLING CONTRACTOR

Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
ENS-2	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
ENS-3	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
ENS-4	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5

HEAT RECOVERY VENTILATOR 9.32.3.11.

Model: VANEE V150H INSTALL 2 HRV / ERV's

150 cfm high 35 cfm low

75 % Sensible Efficiency @ 32 deg F (0 deg C) HVI Approved

LOCATION OF INSTALLATION

Lot: Concession

Township: Plan:

Address:

Roll # Building Permit #

BUILDER: GOLD PARK HOMES

Name:

Address:

City:

Telephone #: Fax #:

INSTALLING CONTRACTOR

Name:

Address:

City:

Telephone #: Fax #:

DESIGNER CERTIFICATION

I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.

Name: HVAC Designs Ltd.

Signature: *Michael O'Rourke*

HRAI # 001820

Date: July-22

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																																
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																																
LO#: 98030	Model: 5011	Builder: GOLD PARK HOMES	Date: 2022-07-12																																																													
Volume Calculation			Air Change & Delta T Data																																																													
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="4">House Volume</th> </tr> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>2121</td> <td>10</td> <td>21210</td> </tr> <tr> <td>First</td> <td>2121</td> <td>11</td> <td>23331</td> </tr> <tr> <td>Second</td> <td>2700</td> <td>9</td> <td>24300</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>68,841.0 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>1949.4 m³</td> </tr> </tbody> </table>			House Volume				Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)	Bsmt	2121	10	21210	First	2121	11	23331	Second	2700	9	24300	Third	0	9	0	Fourth	0	9	0	Total:			68,841.0 ft ³	Total:			1949.4 m ³	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 70%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 30%;">0.340</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.114</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> </thead> <tbody> <tr> <td>Winter DTDh</td> <td>22</td> <td>-20</td> <td>42</td> <td>76</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </tbody> </table>		WINTER NATURAL AIR CHANGE RATE	0.340	SUMMER NATURAL AIR CHANGE RATE	0.114	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-20	42	76	Summer DTDc	24	31	7	13
House Volume																																																																
Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)																																																													
Bsmt	2121	10	21210																																																													
First	2121	11	23331																																																													
Second	2700	9	24300																																																													
Third	0	9	0																																																													
Fourth	0	9	0																																																													
Total:			68,841.0 ft ³																																																													
Total:			1949.4 m ³																																																													
WINTER NATURAL AIR CHANGE RATE	0.340																																																															
SUMMER NATURAL AIR CHANGE RATE	0.114																																																															
Design Temperature Difference																																																																
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																												
Winter DTDh	22	-20	42	76																																																												
Summer DTDc	24	31	7	13																																																												
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																													
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ <p>0.340 x 541.49 x 42 °C x 1.2 = 9329 W = 31832 Btu/h</p>			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ <p>= 0.114 x 541.49 x 7 °C x 1.2 = 528 W = 1802 Btu/h</p>																																																													
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																													
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E) \times 2 \text{ HRV / ERV's}$ <p>300 CFM x 76 °F x 1.08 x 0.25 = 6156 Btu/h</p>			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ <p>300 CFM x 13 °F x 1.08 x 0.25 = 1,037 Btu/h</p>																																																													
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																																
$HL_{airr} = Level \ Factor \times HL_{airbv} \times \{ (HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel}) \}$																																																																
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairve Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{level})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5" style="text-align: center;">31,832</td> <td>10,762</td> <td>1.479</td> </tr> <tr> <td>2</td> <td>0.3</td> <td>20,867</td> <td>0.458</td> </tr> <tr> <td>3</td> <td>0.2</td> <td>18,605</td> <td>0.342</td> </tr> <tr> <td>4</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> </tbody> </table>					Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)	1	0.5	31,832	10,762	1.479	2	0.3	20,867	0.458	3	0.2	18,605	0.342	4	0	0	0.000	5	0	0	0.000																																		
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																												
1	0.5	31,832	10,762	1.479																																																												
2	0.3		20,867	0.458																																																												
3	0.2		18,605	0.342																																																												
4	0		0	0.000																																																												
5	0		0	0.000																																																												
<p>*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0</p>																																																																
				Michael O'Rourke BCIN# 19669 																																																												

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: 5011	TIMBERLAND - LOTS 72 & 101	BUILDER: GOLD PARK HOMES
SFQT: 4238	LO# 98030	SITE: PINE VALLEY PH 2

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-4	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.50

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft ³):	68841.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft ²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	7.0 ft
LENGTH: 65.0 ft	WIDTH: 43.0 ft	EXPOSED PERIMETER:	216.0 ft


2012 OBC - COMPLIANCE PACKAGE

Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669
 MICHAEL O'ROURKE

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Vaughan (Woodbridge)	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	19.8	 <p>Insulation Configuration</p>
Floor Width (m):	13.1	
Exposed Perimeter (m):	0.0	
Wall Height (m):	3.0	
Depth Below Grade (m):	2.13	
Window Area (m ²):	1.7	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	2210	

TYPE: 5011
 LO# 98030

TIMBERLAND - LOTS 72 & 101


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description			
Province:	Ontario		
Region:	Vaughan (Woodbridge)		
Weather Station Location:	Open flat terrain, grass		
Anemometer height (m):	10		
Local Shielding			
Building Site:	Suburban, forest		
Walls:	Heavy		
Flue:	Heavy		
Highest Ceiling Height (m):	7.01		
Building Configuration			
Type:	Detached		
Number of Stories:	Two		
Foundation:	Full		
House Volume (m ³):	1949.4		
Air Leakage/Ventilation			
Air Tightness Type:	Present (1961-) (3.57 ACH)		
Custom BDT Data:	ELA @ 10 Pa.	2598.6 cm ²	
	3.57	ACH @ 50 Pa	
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust	
	70.8	70.8	
Flue Size			
Flue #:	#1	#2	#3 #4
Diameter (mm):	0	0	0 0
Natural Infiltration Rates			
Heating Air Leakage Rate (ACH/H):	0.340		
Cooling Air Leakage Rate (ACH/H):	0.114		

TYPE: 5011
 LO# 98030

TIMBERLAND - LOTS 72 & 101



FURNACE 1
 LENNOX ML196UH070XE36B
 63900 BTU/H OUTPUT
 2.5 TONS A/C @ 985 cfm

FURNACE 2
 LENNOX ML196UH045XE36B
 42,800 BTU/H OUTPUT
 2.5 TONS A/C @ 980 cfm

BASEMENT PLAN, EL. 'A'
 LOT 72/101

CSA-F280-12
LOTS 72/101 PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
 Michael O'Rourke, BCIN# 19669
 HVAC DESIGNS LTD.

F.D. COLD CELLAR

HVAC LEGEND							REVISIONS		
— □ —	SUPPLY AIR GRILLE	— ■ —	6" SUPPLY AIR BOOT ABOVE	— ▨ —	14"x8" RETURN AIR GRILLE	— ▩ —	RETURN AIR STACK ABOVE	3.	
— ■ —	SUPPLY AIR GRILLE 6" BOOT	⊙	SUPPLY AIR STACK FROM 2nd FLOOR	— ▨ —	30"x8" RETURN AIR GRILLE	— ▩ —	RETURN AIR STACK 2nd FLOOR	2.	
— ▨ —	SUPPLY AIR BOOT ABOVE	●	6" SUPPLY AIR STACK 2nd FLOOR	— ▨ —	FRA- FLOOR RETURN AIR GRILLE	— ▩ —	REDUCER	1.	
								No.	Description
									Date


ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. © AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GOLD PARK HOMES
 Project Name
PINE VALLEY PH 2
VAUGHAN, ONTARIO
LOTS 72 & 101
TIMBERLAND
5011 **4238 sqft**

HVAC DESIGNS LTD.
 375 Finley Ave. Suite 202 - Ajax, Ontario
 L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
 Email: info@hvacdsgns.ca
 Web: www.hvacdsgns.ca
 Specializing in Residential Mechanical Design Services
 Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

	S/A	R/A	FANS
2ND	18	6	5
1ST	11	3	2
BAS	5	1	0

Sheet Title
BASEMENT HEATING LAYOUT
 Date JULY/2022
 Scale 3/16" = 1'-0"
 BCIN# 19669
LO# 98030



GROUND FLOOR PLAN, EL. 'A' - LOT 72/101

CSA-F280-12
 LOTS 72/101 PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
 Michael O'Rourke, BCIN# 19669
 HVAC DESIGNS LTD.


HVAC LEGEND							REVISIONS	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	3.
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	2.
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	1.
								No. Description Date

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. © AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GOLD PARK HOMES
 Project Name
PINE VALLEY PH 2
VAUGHAN, ONTARIO
LOTS 72 & 101
TIMBERLAND
5011 **4238 sqft**

HVAC DESIGNS LTD.
 375 Finley Ave. Suite 202 - Ajax, Ontario
 L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
 Email: info@hvacdsgns.ca
 Web: www.hvacdsgns.ca
 Specializing in Residential Mechanical Design Services
 Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

Sheet Title
FIRST FLOOR HEATING LAYOUT
 Date **JULY/2022**
 Scale **3/16" = 1'-0"**
 BCIN# 19669
LO# 98030



SECOND FLOOR PLAN, EL. 'A'

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
 Michael O'Rourke, BCIN# 19669
 HVAC DESIGNS LTD.

CSA-F280-12
LOTS 72/101 PACKAGE A1

HVAC LEGEND							3.	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	2.
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	1.
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	No.

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GOLD PARK HOMES
 Project Name
PINE VALLEY PH 2
VAUGHAN, ONTARIO
LOTS 72 & 101
TIMBERLAND
5011 **4238 sqft**

HVAC DESIGNS LTD.

375 Finley Ave. Suite 202 - Ajax, Ontario
 L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
 Email: info@hvacdsgns.ca
 Web: www.hvacdsgns.ca
 Specializing in Residential Mechanical Design Services

Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

REVISIONS	
No.	Description Date

Sheet Title
SECOND FLOOR HEATING LAYOUT

Date **JULY/2022**

Scale **3/16" = 1'-0"**

BCIN# 19669

LO# 98030