

Schedule 1: Designer Information

Use one form for each individual who reviews and takes responsibility for design activities with respect to the project.

A. Project Information			
Building number, street name		Unit no.	Lot/con.
Municipality VAUGHAN (WOODBIDGE)	Postal code	Plan number/ other description	
B. Individual who reviews and takes responsibility for design activities			
Name MICHAEL O'ROURKE		Firm HVAC DESIGNS LTD.	
Street address 375 FINLEY AVE		Unit no. 202	Lot/con. N/A
Municipality AJAX	Postal code L1S 2E2	Province ONTARIO	E-mail info@hvacdesigns.ca
Telephone number (905) 619-2300	Fax number (905) 619-2375	Cell number ()	
C. Design activities undertaken by individual identified in Section B. [Building Code Table 3.5.2.1 OF Division C]			
☐ House ☐ Small Buildings ☐ Large Buildings ☐ Complex Buildings ☒ HVAC – House ☐ Building Services ☐ Detection, Lighting and Power ☐ Fire Protection ☐ Building Structural ☐ Plumbing – House ☐ Plumbing – All Buildings ☐ On-site Sewage Systems			
Description of designer's work HEAT LOSS / GAIN CALCULATIONS DUCT SIZING RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY RESIDENTIAL SYSTEM DESIGN per CSA-F280-12		Model: 6001 - QUEENSLAND - ELEV C OPT 2ND - WOB Project: PINE VALLEY PH 2	
D. Declaration of Designer			
I, <u>MICHAEL O'ROURKE</u> declare that (choose one as appropriate): (print name)			
☐ I review and take responsibility for the design work on behalf of a firm registered under subsection 3.2.4. of Division C, of the Building Code. I am qualified, and the firm is registered, in the appropriate classes/categories. Individual BCIN: _____ Firm BCIN: _____			
☒ I review and take responsibility for the design and am qualified in the appropriate category as an "other designer" under subsection 3.2.5. of Division C, of the Building Code. Individual BCIN: <u>19669</u> Basis for exemption from registration and qualification: <u>O.B.C SENTENCE 3.2.4.1 (4)</u>			
☐ The design work is exempt from the registration and qualification requirements of the Building Code. Basis for exemption from registration and qualification: _____			
I certify that:			
1. The information contained in this schedule is true to the best of my knowledge. 2. I have submitted this application with the knowledge and consent of the firm.			
April 14, 2022 Date		 Signature of Designer	

NOTE:

- For the purposes of this form, "individual" means the "person" referred to in Clause 3.2.4.7(1) d) of Division C, Article 3.2.5.1. of Division C, and all other persons who are exempt from qualification under Subsections 3.2.4. and 3.2.5. of Division C.
- Schedule 1 is not required to be completed by a holder of a license, temporary license, or a certificate of authorization, issued by the Ontario Association of Architects. Schedule 1 is also not required to be completed by a holder of a license to practise, a limited license to practise, or a certificate of authorization, issued by the Association of Professional Engineers of Ontario.

Application for a Permit Construct or Demolish – Effective January 1, 2015

SITE NAME: PINE VALLEY PH 2				OPT 2ND - WOB				DATE Apr-22				WINTER NATURAL AIR CHANGE RATE 0.486				HEAT LOSS ΔT °F. 76				CSA-F280-12			
BUILDER: GOLD PARK HOMES				TYPE: 6001 - QUEENSLAND - ELEV C				GFA: 5742				SUMMER NATURAL AIR CHANGE RATE 0.162				HEAT GAIN ΔT °F. 13				SB-12 PACKAGE A1			
ROOM USE				GREAT				KIT				DIN				LIBR				FOY			
EXP. WALL				58				56				25				33				43			
CLG. HT.				11				11				11				11				13			
FACTORS																							
GRS.WALL AREA				615				594				265				350				456			
GLAZING				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN			
NORTH				21.3	16.0	26	553	415	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EAST				21.3	41.6	0	0	0	0	0	0	0	0	0	0	65	1383	2701	15	319	623	0	0
SOUTH				21.3	24.9	0	0	0	0	0	0	41	872	1021	18	383	448	0	0	0	0	0	0
WEST				21.3	41.6	78	1660	3241	119	2532	4945	0	0	0	0	0	0	0	0	0	0	0	0
SKYLT.				37.2	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS				25.2	4.3	0	0	0	15	379	64	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL				4.5	0.8	511	2280	384	460	2051	345	224	1000	168	267	1191	201	401	1789	301	257	1148	193
NET EXPOSED BSMT WALL ABOVE GR				3.6	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG				1.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG				2.7	1.3	10	27	13	0	0	0	0	0	0	10	27	13	0	0	0	0	0	0
EXPOSED FLOOR				2.6	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS						0			0			0			0			0			0		
SLAB ON GRADE HEAT LOSS						0			0			0			0			0			0		
SUBTOTAL HT LOSS						4520			4962			1872			2984			3118			1653		
SUB TOTAL HT GAIN							4053		5354			1189			3362			1095			278		56
LEVEL FACTOR / MULTIPLIER				0.30	0.82			0.30	0.82			0.30	0.82		0.30	0.82		0.30	0.82		0.30	0.82	
AIR CHANGE HEAT LOSS						3718			4081			1540			2455			2564			1359		272
AIR CHANGE HEAT GAIN							340		449			100			282			92			23		5
DUCT LOSS						0			0			0			0			0			0		0
DUCT GAIN							0		0			0			0			0			0		0
HEAT GAIN PEOPLE				240		0		0	0		0	0		0	0		0	0		0	0		0
HEAT GAIN APPLIANCES/LIGHTS							860		860				860		860			0		0		0	
TOTAL HT LOSS BTU/H						8238			9043			3412			5439			5682			3012		603
TOTAL HT GAIN x 1.3 BTU/H							6828		8661			2793			5855			1542			392		79

ROOM USE																							
EXP. WALL																							
CLG. HT.																							
FACTORS																							
GRS.WALL AREA				LOSS GAIN																			
GLAZING																							
NORTH				21.3	16.0																		
EAST				21.3	41.6																		
SOUTH				21.3	24.9																		
WEST				21.3	41.6																		
SKYLT.				37.2	101.5																		
DOORS				25.2	4.3																		
NET EXPOSED WALL				4.5	0.8																		
NET EXPOSED BSMT WALL ABOVE GR				3.6	0.6																		
EXPOSED CLG				1.3	0.6																		
NO ATTIC EXPOSED CLG				2.7	1.3																		
EXPOSED FLOOR				2.6	0.4																		
BASEMENT/CRAWL HEAT LOSS																							
SLAB ON GRADE HEAT LOSS																							
SUBTOTAL HT LOSS																							
SUB TOTAL HT GAIN																							
LEVEL FACTOR / MULTIPLIER																							
AIR CHANGE HEAT LOSS																							
AIR CHANGE HEAT GAIN																							
DUCT LOSS																							
DUCT GAIN																							
HEAT GAIN PEOPLE				240																			
HEAT GAIN APPLIANCES/LIGHTS																							
TOTAL HT LOSS BTU/H																							
TOTAL HT GAIN x 1.3 BTU/H																							

TOTAL HEAT GAIN BTU/H: 79368 TONS: 6.61 LOSS DUE TO VENTILATION LOAD BTU/H: 6156 STRUCTURAL HEAT LOSS: 109520 TOTAL COMBINED HEAT LOSS BTU/H: 115676

SITE NAME: PINE VALLEY PH 2										OPT 2ND - WOB										DATE Apr-22				WINTER NATURAL AIR CHANGE RATE 0.486										HEAT LOSS ΔT °F. 76				CSA-F280-12													
BUILDER: GOLD PARK HOMES										TYPE: 6001 - QUEENSLAND - ELEV C										GFA: 5742				LO# 96174				SUMMER NATURAL AIR CHANGE RATE 0.162										HEAT GAIN ΔT °F. 13				SB-12 PACKAGE A1									
ROOM USE				MBR				ENS				BED-2				BED-3				BED-4				BED-5				ENS-2				ENS-3				ENS-4				ENS-5											
EXP. WALL				20				32				18				20				45				16				6				18				6				0											
CLG. HT.				10				9				9				10				10				9				9				9				9				9											
FACTORS																																																			
GRS.WALL AREA				LOSS GAIN				200				288				162				200				450				144				54				162				54				0							
GLAZING				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN							
NORTH				21.3	16.0	0	0	0	0	0	0	0	38	809	607	18	383	288	0	0	0	0	0	0	8	170	128	0	0	0	0	0	0	0	0	0	0	0	0	0											
EAST				21.3	41.6	0	0	0	0	0	0	0	0	0	65	1383	2701	65	1383	2701	0	0	0	0	0	0	10	213	416	0	0	0	0	0	0	0	0	0	0	0											
SOUTH				21.3	24.9	0	0	0	22	468	548	0	0	0	0	0	0	18	383	448	19	404	473	0	0	0	0	0	0	8	170	199	0	0	0	0	0	0	0	0											
WEST				21.3	41.6	42	894	1745	8	170	332	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0										
SKYLT.				37.2	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0											
DOORS				25.2	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0											
NET EXPOSED WALL				4.5	0.8	158	705	119	258	1151	194	124	553	93	117	522	88	367	1638	276	125	558	94	46	205	35	152	678	114	46	205	35	0	0	0	0	0	0	0	0											
NET EXPOSED BSMT WALL ABOVE GR				3.6	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0											
EXPOSED CLG				1.3	0.6	380	488	223	240	308	141	438	562	257	323	415	190	348	447	204	232	298	136	66	85	39	72	92	42	84	108	49	72	92	42	0	0	0	0												
NO ATTIC EXPOSED CLG				2.7	1.3	0	0	0	0	0	0	0	0	0	55	151	69	55	151	69	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0												
EXPOSED FLOOR				2.6	0.4	0	0	0	0	0	0	200	510	86	228	581	98	0	0	0	0	0	0	66	168	28	72	184	31	0	0	0	0	0	0	0	0	0	0	0											
BASEMENT/CRAWL HEAT LOSS				0				0				0				0				0				0				0				0				0				0				0							
SLAB ON GRADE HEAT LOSS				0				0				0				0				0				0				0				0				0				0				0				0			
SUBTOTAL HT LOSS				2087				2098				2434				3436				4002				1260				629				1167				483				92											
SUB TOTAL HT GAIN				2087				1215				1044				3433				3699				703				229				603				283				42											
LEVEL FACTOR / MULTIPLIER				0.20	0.44				0.20	0.44		0.20	0.44		0.20	0.44		0.20	0.44		0.20	0.44		0.20	0.44		0.20	0.44		0.20	0.44		0.20	0.44		0.20	0.44		0.20												
AIR CHANGE HEAT LOSS				926				931				1081				1525				1777				559				279				518				215				41											
AIR CHANGE HEAT GAIN								175				102				87				288				310				59				19				51				24				4							
DUCT LOSS				0				0				351				496				0				0				91				169				0				0				0				0			
DUCT GAIN				0				0				223				482				0				0				111				151				0				0				0				0			
HEAT GAIN PEOPLE				240		2		480	0		1	240		1	240		1	240		1	240		0		0		0		0		0		0		0		0		0												
HEAT GAIN APPLIANCES/LIGHTS								860				0				860				860				860				860				860				860				860				860				860			
TOTAL HT LOSS BTU/H				3013				3029				3866				5457				5778				1819				998				1854				698				133											
TOTAL HT GAIN x 1.3 BTU/H				4683				1712				3190				6894				6641				2421				1585				2164				1517				1177											

ROOM USE			LAUN			HALL			DRESS																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
----------	--	--	------	--	--	------	--	--	-------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

TOTAL HEAT GAIN BTU/H: 79368 TONS: 6.61 LOSS DUE TO VENTILATION LOAD BTU/H: 6156 STRUCTURAL HEAT LOSS: 109520 TOTAL COMBINED HEAT LOSS BTU/H: 115676

SITE NAME: PINE VALLEY PH 2
BUILDER: GOLD PARK HOMES

OPT 2ND - WOB
TYPE: 6001 - QUEENSLAND - ELEV C DATE: Apr-22

GFA: 5742 LO# 96174

FURNACE 1

HEATING CFM 1170 COOLING CFM 1170
TOTAL HEAT LOSS 73,741 TOTAL HEAT GAIN 36,000
AIR FLOW RATE CFM 15.87 AIR FLOW RATE CFM 32.5

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

**FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 76819 BTUH**
\$LENNOX
ML196UH090XE36C
FAN SPEED

LOW 0

MEDLOW 0

MEDIUM 0

MEDIUM HIGH 1170

HIGH 1300

AFUE = 96 %
INPUT (BTU/H) = 88,000
OUTPUT (BTU/H) = **85,600**

DESIGN CFM = **1170**
CFM @ .6" E.S.P.

TEMPERATURE RISE 68 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	0	15	9
R/A	0	0	0	3	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	5	6	7	8	9	10	11	12	13	14	15	18	19	21	22	23	24
ROOM NAME	GREAT	GREAT	GREAT	KIT	KIT	KIT	KIT	DIN	DIN	LIBR	LIBR	LIBR	FOY	MUD	PWD	BAS	BAS	BAS	BAS
RM LOSS MBH.	2.75	2.75	2.75	2.26	2.26	2.26	2.26	1.71	1.71	1.81	1.81	1.81	5.68	3.01	0.60	4.26	4.26	4.26	4.26
CFM PER RUN HEAT	44	44	44	36	36	36	36	27	27	29	29	29	90	48	10	68	68	68	68
RM GAIN MBH.	2.28	2.28	2.28	2.17	2.17	2.17	2.17	1.40	1.40	1.95	1.95	1.95	1.54	0.39	0.08	1.09	1.09	1.09	1.09
CFM PER RUN COOLING	74	74	74	70	70	70	70	45	45	63	63	63	50	13	3	36	36	36	36
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	74	89	72	67	59	45	46	46	10	22	27	31	40	48	55	82	56	65	71
EQUIVALENT LENGTH	140	130	170	160	170	170	110	120	150	150	110	120	140	150	130	140	120	150	150
TOTAL EFFECTIVE LENGTH	214	219	242	227	229	215	156	166	160	172	137	151	180	198	185	222	176	215	221
ADJUSTED PRESSURE	0.08	0.08	0.07	0.08	0.08	0.08	0.11	0.1	0.11	0.1	0.13	0.11	0.09	0.09	0.09	0.08	0.1	0.08	0.08
ROUND DUCT SIZE	6	6	6	6	6	6	6	5	5	5	5	5	6	4	4	5	5	5	5
HEATING VELOCITY (ft/min)	224	224	224	184	184	184	184	198	198	213	213	213	459	551	115	499	499	499	499
COOLING VELOCITY (ft/min)	377	377	377	357	357	357	357	330	330	463	463	463	255	149	34	264	264	264	264
OUTLET GRILL SIZE	4X10	4X10	4X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10
TRUNK	A	A	A	A	A	A	B	C	C	D	D	D	D	C	C	B	B	A	A

RUN #	25	26	27	28	29
ROOM NAME	BAS	BAS	BAS	BAS	BAS
RM LOSS MBH.	4.26	4.26	4.26	4.26	4.26
CFM PER RUN HEAT	68	68	68	68	68
RM GAIN MBH.	1.09	1.09	1.09	1.09	1.09
CFM PER RUN COOLING	36	36	36	36	36
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	39	44	23	41	58
EQUIVALENT LENGTH	140	160	100	130	170
TOTAL EFFECTIVE LENGTH	179	204	123	171	228
ADJUSTED PRESSURE	0.1	0.08	0.14	0.1	0.08
ROUND DUCT SIZE	5	5	5	5	5
HEATING VELOCITY (ft/min)	499	499	499	499	499
COOLING VELOCITY (ft/min)	264	264	264	264	264
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	3X10
TRUNK	C	D	D	D	A

SUPPLY AIR TRUNK SIZE

	TRUNK	STATIC	ROUND	RECT			VELOCITY		TRUNK	STATIC	ROUND	RECT			VELOCITY
	CFM	PRESS.	DUCT	DUCT			(ft/min)		CFM	PRESS.	DUCT	DUCT			(ft/min)
TRUNK A	408	0.07	10.4	12	x	8	612	TRUNK G	0	0.00	0	0	x	8	0
TRUNK B	172	0.08	7.3	8	x	8	387	TRUNK H	0	0.00	0	0	x	8	0
TRUNK C	796	0.07	13.3	16	x	12	597	TRUNK I	0	0.00	0	0	x	8	0
TRUNK D	381	0.08	9.8	12	x	8	572	TRUNK J	0	0.00	0	0	x	8	0
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0

RETURN AIR TRUNK SIZE

	TRUNK	STATIC	ROUND	RECT		VELOCITY	
	CFM	PRESS.	DUCT	DUCT		(ft/min)	
TRUNK O	0	0.06	0	0	x	8	0
TRUNK P	0	0.06	0	0	x	8	0
TRUNK Q	0	0.06	0	0	x	8	0
TRUNK R	0	0.06	0	0	x	8	0
TRUNK S	0	0.06	0	0	x	8	0
TRUNK T	0	0.06	0	0	x	8	0
TRUNK U	0	0.06	0	0	x	8	0
TRUNK V	0	0.06	0	0	x	8	0
TRUNK W	330	0.06	9.9	12	x	8	495
TRUNK X	840	0.06	14.1	16	x	12	630
TRUNK Y	580	0.06	12.3	12	x	10	696
TRUNK Z	275	0.06	9.3	10	x	8	495
DROP	1170	0.06	16	24	x	12	585

RETURN AIR #	1	2	3												BR
AIR VOLUME	275	305	330	0	0	0	0	0	0	0	0	0	0	0	260
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	76	47	41	1	1	1	1	1	1	1	1	1	1	1	19
EQUIVALENT LENGTH	180	165	140	0	0	0	0	0	0	0	0	0	0	0	145
TOTAL EFFECTIVE LH	256	212	181	1	1	1	1	1	1	1	1	1	1	1	164
ADJUSTED PRESSURE	0.06	0.07	0.08	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.09
ROUND DUCT SIZE	9.3	9.3	9.3	0	0	0	0	0	0	0	0	0	0	0	8.2
INLET GRILL SIZE	8	8	8	0	0	0	0	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	30	30	30	0	0	0	0	0	0	0	0	0	0	0	24

SITE NAME: PINE VALLEY PH 2
BUILDER: GOLD PARK HOMES

OPT 2ND - WOB
TYPE: 6001 - QUEENSLAND - ELEV C DATE: Apr-22

GFA: 5742 LO# 96174

FURNACE 2

HEATING CFM 1270 COOLING CFM 1270
TOTAL HEAT LOSS 35,779 TOTAL HEAT GAIN 42,849
AIR FLOW RATE CFM 35.5 AIR FLOW RATE CFM 29.64

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

**FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 38857 BTUH**
**\$*LENNOX
ML196UH070XE48B
FAN SPEED 70**

AFUE = 96 %
INPUT (BTU/H) = 66,000
OUTPUT (BTU/H) = **63,900**

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	24	0	0
R/A	0	0	6	0	0

plenium pressure s/a 0.18 r/a pressure 0.17
max s/a dif press. loss 0.02 r/a grille press. Loss 0.02
min adjusted pressure s/a 0.16 adjusted pressure r/a 0.15

LOW 0
MEDLOW 1070
MEDIUM 1270
MEDIUM HIGH 1515
HIGH 1595

DESIGN CFM = **1270**
CFM @ .6" E.S.P.

TEMPERATURE RISE 47 °F

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	MBR	MBR	ENS	ENS	BED-2	BED-2	ENS-2	BED-3	BED-3	BED-3	ENS-3	BED-4	BED-4	BED-4	ENS-5	ENS-4	BED-5	BED-5	LAUN	HALL	HALL	DRESS	DRESS
RM LOSS MBH.	1.00	1.00	1.00	2.27	0.76	1.93	1.93	1.00	1.82	1.82	1.82	1.85	1.93	1.93	1.93	0.13	0.70	0.91	0.91	0.16	2.51	2.51	1.98	1.98
CFM PER RUN HEAT	36	36	36	81	27	69	69	35	65	65	65	66	68	68	68	5	25	32	32	6	89	89	70	70
RM GAIN MBH.	1.56	1.56	1.56	1.28	0.43	1.59	1.59	1.59	2.30	2.30	2.30	2.16	2.21	2.21	2.21	1.18	1.52	1.21	1.21	1.19	3.28	3.28	1.56	1.56
CFM PER RUN COOLING	46	46	46	38	13	47	47	47	68	68	68	64	66	66	66	35	45	36	36	35	97	97	46	46
ADJUSTED PRESSURE	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.17	0.17
ACTUAL DUCT LGH.	67	72	83	75	69	85	95	102	79	85	91	86	37	30	42	32	24	28	67	82	34	48	91	90
EQUIVALENT LENGTH	150	160	220	180	180	160	170	180	170	180	170	160	170	150	140	200	210	180	180	190	110	140	160	170
TOTAL EFFECTIVE LENGTH	217	232	303	255	249	245	265	282	249	265	261	246	207	180	182	232	234	208	247	272	144	188	251	260
ADJUSTED PRESSURE	0.08	0.07	0.06	0.06	0.07	0.07	0.06	0.06	0.07	0.06	0.07	0.07	0.08	0.1	0.09	0.07	0.07	0.08	0.07	0.06	0.11	0.09	0.07	0.07
ROUND DUCT SIZE	6	6	6	6	4	6	6	5	6	6	6	6	5	5	5	4	5	5	5	6	6	6	6	6
HEATING VELOCITY (ft/min)	184	184	184	413	310	352	352	257	331	331	331	337	499	499	499	57	184	235	235	31	454	454	357	357
COOLING VELOCITY (ft/min)	235	235	235	194	149	240	240	345	347	347	347	326	485	485	485	402	330	264	264	178	495	495	235	235
OUTLET GRILL SIZE	4X10	4X10	4X10	4X10	3X10	4X10	4X10	3X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10	4X10
TRUNK	B	B	A	B	B	A	A	A	C	C	C	C	D	D	D	C	C	C	B	A	D	D	A	A

RUN #	ROOM NAME	RM LOSS MBH.	CFM PER RUN HEAT	RM GAIN MBH.	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH.	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK
1	MBR	1.00	36	1.56	46	0.17	67	150	217	0.08	6	184	235	4X10	B
2	MBR	1.00	36	1.56	46	0.17	72	160	232	0.07	6	184	235	4X10	B
3	MBR	1.00	36	1.56	46	0.17	83	220	303	0.06	6	184	235	4X10	A
4	ENS	2.27	81	1.28	38	0.16	75	180	255	0.06	6	413	194	4X10	B
5	ENS	0.76	27	0.43	13	0.17	69	180	249	0.07	4	310	149	3X10	B
6	BED-2	1.93	69	1.59	47	0.17	85	160	245	0.07	6	352	240	4X10	A
7	BED-2	1.93	69	1.59	47	0.17	95	170	265	0.06	6	352	240	4X10	A
8	ENS-2	1.00	35	1.59	47	0.17	102	180	282	0.06	5	257	345	3X10	A
9	BED-3	1.82	65	2.30	68	0.17	79	170	249	0.07	6	331	347	4X10	C
10	BED-3	1.82	65	2.30	68	0.17	85	170	265	0.06	6	331	347	4X10	C
11	BED-3	1.82	65	2.30	68	0.17	91	170	261	0.07	6	337	347	4X10	C
12	ENS-3	1.85	66	2.21	64	0.17	86	160	246	0.07	6	499	326	4X10	C
13	BED-4	1.93	68	2.21	66	0.17	37	150	207	0.08	5	499	485	3X10	D
14	BED-4	1.93	68	2.21	66	0.17	30	140	180	0.1	5	499	485	3X10	D
15	BED-4	1.93	68	2.21	66	0.17	42	200	182	0.09	5	57	402	3X10	D
16	ENS-5	0.13	5	1.18	35	0.17	32	210	232	0.07	4	184	330	3X10	C
17	ENS-4	0.70	25	1.52	45	0.17	24	210	234	0.07	5	184	330	3X10	C
18	BED-5	0.91	32	1.21	36	0.17	28	180	208	0.08	5	235	264	3X10	C
19	BED-5	0.91	32	1.21	36	0.17	67	180	247	0.07	5	235	264	3X10	B
20	LAUN	0.16	6	1.19	35	0.17	82	190	272	0.06	6	31	178	4X10	A
21	HALL	2.51	89	3.28	97	0.16	34	110	144	0.11	6	454	495	4X10	D
22	HALL	2.51	89	3.28	97	0.16	48	140	188	0.09	6	454	495	4X10	D
23	DRESS	1.98	70	1.56	46	0.17	91	160	251	0.07	6	357	235	4X10	A
24	DRESS	1.98	70	1.56	46	0.17	90	170	260	0.07	6	357	235	4X10	A

SUPPLY AIR TRUNK SIZE															RETURN AIR TRUNK SIZE														
TRUNK	STATIC	ROUND	RECT	VELOCITY					TRUNK	STATIC	ROUND	RECT	VELOCITY					TRUNK	STATIC	ROUND	RECT	VELOCITY							
CFM	PRESS.	DUCT	DUCT	(ft/min)					CFM	PRESS.	DUCT	DUCT	(ft/min)					CFM	PRESS.	DUCT	DUCT	(ft/min)							
TRUNK A	355	0.06	10.2	10	x	10	511	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.05	0	0	x	8	0						
TRUNK B	567	0.06	12.2	14	x	10	583	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.05	0	0	x	8	0						
TRUNK C	890	0.06	14.4	18	x	12	593	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.05	0	0	x	8	0						
TRUNK D	382	0.08	9.8	12	x	8	573	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.05	0	0	x	8	0						
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.05	0	0	x	8	0						
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.05	0	0	x	8	0						

RETURN AIR #	1	2	3	4	5	6	BR
AIR VOLUME	230	115	260	185	115	365	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	75	71	71	60	83	65	1
EQUIVALENT LENGTH	230	215	195	185	225	190	0
TOTAL EFFECTIVE LH	305	286	266	245	308	255	1
ADJUSTED PRESSURE	0.05	0.05	0.06	0.06	0.05	0.06	14.80
ROUND DUCT SIZE	9.1	7	9.1	8	7	10.3	0
INLET GRILL SIZE	8	8	8	8	8	8	0
INLET GRILL SIZE	X	X	X	X	X	X	X
INLET GRILL SIZE	30	14	30	24	14	30	0

TYPE: 6001 - QUEENSLAND - ELEV C
SITE NAME: PINE VALLEY PH 2

LO # 96174
OPT 2ND - WOB

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm <u>42.4</u> cfm	
Other Bedrooms	<u>4</u> @ 10.6 cfm <u>42.4</u> cfm	
Kitchen & Bathrooms	<u>7</u> @ 10.6 cfm <u>74.2</u> cfm	
Other Rooms	<u>5</u> @ 10.6 cfm <u>53.0</u> cfm	
Table 9.32.3.A.	TOTAL <u>212.0</u> cfm	

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8 cfm	
2 Bedroom	47.7 cfm	
3 Bedroom	63.6 cfm	
4 Bedroom	79.5 cfm	
5 Bedroom	95.4 cfm	
TOTAL	95.4 cfm	

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>212</u> cfm	
Less Principal Ventil. Capacity	<u>150</u> cfm	
Required Supplemental Capacity	<u>62.0</u> cfm	

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE V150H	Location: BSMT
<u>150.0</u> cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
150.0 CFM	X 76 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		BY INSTALLING CONTRACTOR		
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-2	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-3	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-4	BY INSTALLING CONTRACTOR	50	☒	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE V150H	INSTALL 2 HRV / ERV's	
<u>150</u> cfm high	<u>35</u> cfm low	
<u>75</u> % Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved	

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GOLD PARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-22

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669 MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 96174	Model: 6001 - QUEENSLAND - ELEV C	Builder: GOLD PARK HOMES	Date: 4/14/2022																																																									
Volume Calculation		Air Change & Delta T Data																																																										
House Volume <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr><td>Bsmt</td><td>2581</td><td>10</td><td>24777.6</td></tr> <tr><td>First</td><td>2581</td><td>11</td><td>27358.6</td></tr> <tr><td>Second</td><td>3175</td><td>9</td><td>28575</td></tr> <tr><td>Third</td><td>0</td><td>9</td><td>0</td></tr> <tr><td>Fourth</td><td>0</td><td>9</td><td>0</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>80,711.2 ft³</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>2285.5 m³</td></tr> </tbody> </table>		Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	2581	10	24777.6	First	2581	11	27358.6	Second	3175	9	28575	Third	0	9	0	Fourth	0	9	0	Total:			80,711.2 ft³	Total:			2285.5 m³	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 70%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 30%;">0.486</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.162</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-20</td> <td>42</td> <td>76</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </table>			WINTER NATURAL AIR CHANGE RATE	0.486	SUMMER NATURAL AIR CHANGE RATE	0.162	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-20	42	76	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	2581	10	24777.6																																																									
First	2581	11	27358.6																																																									
Second	3175	9	28575																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			80,711.2 ft³																																																									
Total:			2285.5 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.486																																																											
SUMMER NATURAL AIR CHANGE RATE	0.162																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-20	42	76																																																								
Summer DTDc	24	31	7	13																																																								
5.2.3.1 Heat Loss due to Air Leakage		6.2.6 Sensible Gain due to Air Leakage																																																										
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.486 x 634.86 x 42 °C x 1.2 = 15621 W = 53299 Btu/h		$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.162 x 634.86 x 7 °C x 1.2 = 876 W = 2989 Btu/h																																																										
5.2.3.2 Heat Loss due to Mechanical Ventilation		6.2.7 Sensible heat Gain due to Ventilation																																																										
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E) \times 2 \text{ HRV / ERV's}$ 300 CFM x 76 °F x 1.08 x 0.25 = 6156 Btu/h		$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 300 CFM x 13 °F x 1.08 x 0.25 = 1,037 Btu/h																																																										
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level \ Factor \times HL_{airbv} \times \{ (HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel}) \}$ <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairve Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{clevel})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)</th> </tr> </thead> <tbody> <tr><td>1</td><td>0.5</td><td rowspan="5" style="text-align: center; vertical-align: middle;">53,299</td><td>10,576</td><td>2.520</td></tr> <tr><td>2</td><td>0.3</td><td>19,441</td><td>0.822</td></tr> <tr><td>3</td><td>0.2</td><td>24,012</td><td>0.444</td></tr> <tr><td>4</td><td>0</td><td>0</td><td>0.000</td></tr> <tr><td>5</td><td>0</td><td>0</td><td>0.000</td></tr> </tbody> </table> *HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0					Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)	1	0.5	53,299	10,576	2.520	2	0.3	19,441	0.822	3	0.2	24,012	0.444	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	53,299	10,576	2.520																																																								
2	0.3		19,441	0.822																																																								
3	0.2		24,012	0.444																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
				Michael O'Rourke BCIN# 19669 																																																								

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: 6001 - QUEENSLAND - ELEV C	OPT 2ND - WOB	BUILDER: GOLD PARK HOMES
SFQT: 5742	LO# 96174	SITE: PINE VALLEY PH 2

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-4	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.50

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	80711.2	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	6
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.65	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	8.1 ft
LENGTH: 66.0 ft	WIDTH: 55.0 ft	EXPOSED PERIMETER:	175.0 ft
WOB INSULATION CONFIGURATION	SCB_9	WOB EXPOSED PERIMETER	67.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package
A1****Nominal Min. Eff.**

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description		
Province:	Ontario	
Region:	Vaughan (Woodbridge)	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	4.9	
Floor Width (m):	16.8	
Exposed Perimeter (m):	53.3	
Wall Height (m):	2.9	
Depth Below Grade (m):	2.19	
Window Area (m ²):	0.3	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		836

TYPE: 6001 - QUEENSLAND - ELEV C
LO# 96174

OPT 2ND - WOB

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Vaughan (Woodbridge)	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	1.8	
Width (m):	16.8	
Exposed Perimeter (m):	20.4	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		318

TYPE: 6001 - QUEENSLAND - ELEV C
LO# 96174

OPT 2ND - WOB

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Vaughan (Woodbridge)			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	11.95			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	2285.5			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	3046.6 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	70.8	70.8		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.486			
Cooling Air Leakage Rate (ACH/H):	0.162			

TYPE: 6001 - QUEENSLAND - ELEV C OPT 2ND - WOB
LO# 96174

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.® AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.


INSTALLATION TO COMPLY WITH THE LATEST ONTARIO BUILDING CODE. ALL SUPPLY BRANCH OUTLETS SHALL BE EQUIPPED WITH MANUAL BALANCING DAMPER. DUCTWORK WHICH PASSES THROUGH THE GARAGE OR UNHEATED SPACES SHALL BE ADEQUATELY INSULATED AND GAS-PROOFED

ALL S/A DIFFUSERS "4x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A

FURNACE 1 (F-1)
LENNOX ML196UH090XE36C
85600 BTU/H OUTPUT
3.0 TONS A/C @ 1170 cfm

FURNACE 2 (F-2)
LENNOX ML196UH070XE48B
63900 BTU/H OUTPUT
3.5 TONS A/C @ 1270 cfm

	S/A	R/A	FANS
2ND	22	6	7
1ST	15	3	2
BAS	9	1	0



BASEMENT PLAN, EL.'C'

HVAC LEGEND	
	4X10 SUPPLY GRILLE
	14X8 RETURN GRILLE
	4X10 SUPPLY GRILLE FTD BOOT
	30X8 RETURN GRILLE
	SUPPLY DUCTWORK
	RETURN DUCTWORK
	EXHAUST FAN
	LW LOW WALL
	HW HIGH WALL

UNLESS OTHERWISE NOTED, THE DESIGNER SHALL BE RESPONSIBLE FOR THE DESIGN WORK AND ANY NECESSARY PERMITS. THE DESIGNER SHALL BE RESPONSIBLE FOR THE DESIGN WORK AND ANY NECESSARY PERMITS. THE DESIGNER SHALL BE RESPONSIBLE FOR THE DESIGN WORK AND ANY NECESSARY PERMITS.

1	ISSUED FOR PERMIT	APRIL 2022	EG
No.	Revision	Date	By

SB-12 PACKAGE

A1

HVACDESIGNS LTD.

375 Finley Ave - Unit 202 - Ajax, Ontario L1S 2E2
Tel: 905.619.2300 - 905.420.5300 Fax: 905.619.2375
Email: info@hvacadesigns.ca
Web: www.hvacadesigns.ca
Specializing in Residential Mechanical Design Services

Client: GOLDPARK HOMES

Project Name: PINE VALLEY PH2 VAUGHAN, ONTARIO

6001 - QUEENSLAND - ELEV C

OPT 2ND - WOB

5742 SQFT

Sheet Title: BASEMENT HVAC LAYOUT

Drawn By: EG Checked By: MO

Scale: 3/16"=1'-0"

Date: APRIL 2022

LO # 96174


1

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

INSTALLATION TO COMPLY WITH THE LATEST ONTARIO BUILDING CODE. ALL SUPPLY BRANCH OUTLETS SHALL BE EQUIPPED WITH MANUAL BALANCING DAMPER. DUCTWORK WHICH PASSES THROUGH THE GARAGE OR UNHEATED SPACES SHALL BE ADEQUATELY INSULATED AND GAS-PROOFED

ALL S/A DIFFUSERS "4x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A

	S/A	R/A	FANS
2ND	22	6	7
1ST	15	3	2
BAS	9	1	0



HVAC LEGEND	
	4X10 SUPPLY GRILLE
	14X9 RETURN GRILLE
	4X10 SUPPLY GRILLE 6'Ø BOOT
	30X8 RETURN GRILLE
	SUPPLY DUCTWORK
	RETURN DUCTWORK
	EXHAUST FAN
LW	LOW WALL
HW	HIGH WALL

I WARRANT, ONCE REVIEWED, THAT I HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED TO TAKE RESPONSIBILITY FOR THE DESIGN WORK.
Hvac Designs Ltd. 1989
Hvac Designs Ltd.

1. ISSUED FOR PERMIT	APRIL 2022	EG
No. Revision	Date	By

SB-12 PACKAGE A1

HVACDESIGNS LTD.
375 Finley Ave - Unit 202 - Ajax, Ontario L1S 2E2
Tel: 905.619.2300 - 905.420.5300 Fax: 905.619.2375
Email: info@hvacadesigns.ca
Web: www.hvacadesigns.ca
Specializing in Residential Mechanical Design Services

Client	GOLDPARK HOMES		
Project Name	PINE VALLEY PH2 VAUGHAN, ONTARIO 6001 - QUEENSLAND - ELEV C OPT 2ND - WOB 5742 SQFT		
Sheet Title	FIRST FLOOR HVAC LAYOUT		
Drawn By	EG	Checked By	MO
Scale	3/16"=1'-0"		
Date	APRIL 2022		
LO #	96174		
	2		

ALL S/A DIFFUSERS "4x10"
UNLESS NOTED OTHERWISE
ON LAYOUT. ALL S/A RUNS 5"Ø
UNLESS NOTED OTHERWISE
ON LAYOUT. UNDERCUT
DOORS 1" min. FOR R/A



	S/A	R/A	FANS
2ND	22	6	7
1ST	15	3	2
BAS	9	1	0

HVAC LEGEND	
	4X10 SUPPLY GRILLE
	14X8 RETURN GRILLE
	4X10 SUPPLY GRILLE 6\"/>
	30X8 RETURN GRILLE
	SUPPLY DUCTWORK
	RETURN DUCTWORK
	EXHAUST FAN
LW	LOW WALL
HW	HIGH WALL

I MICHAEL O'BROURKE HAVE REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM A QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Brourke, BCTN# 19609
HVAC DESIGNER LTD.



1	ISSUED FOR PERMIT	APRIL 2022
No.	Revision	Date

SB-12 PACKAGE

A1



375 Finley Ave - Unit 202 - Ajax, Ontario L1S 2E2
Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdesigns.ca
Web: www.hvacdesigns.ca
Specializing in Residential Mechanical Design Services

Client **GOLDPARK HOMES**

Project Name PINE VALLEY PH2
VAUGHAN, ONTARIO

6001 - QUEENSLAND - ELEV C
OPT 2ND - WOB

Copyright & Copy; © 2022 HVAC Designs Ltd.

Sheet Title SECOND FLOOR HVAC LAYOUT

Drawn By	EG
Scale	2 (1/8" = 1' 0")

3/16" = 1'-0"

Date APRIL 2021

LO 96174

3