

Schedule 1: Designer Information

Use one form for each individual who reviews and takes responsibility for design activities with respect to the project.

A. Project Information			
Building number, street name		Unit no.	Lot/con.
Municipality VAUGHAN (WOODBIDGE)	Postal code	Plan number/ other description	
B. Individual who reviews and takes responsibility for design activities			
Name MICHAEL O'ROURKE		Firm HVAC DESIGNS LTD.	
Street address 375 FINLEY AVE		Unit no. 202	Lot/con. N/A
Municipality AJAX	Postal code L1S 2E2	Province ONTARIO	E-mail info@hvacdesigns.ca
Telephone number (905) 619-2300	Fax number (905) 619-2375	Cell number ()	
C. Design activities undertaken by individual identified in Section B. [Building Code Table 3.5.2.1 OF Division C]			
☐ House ☐ Small Buildings ☐ Large Buildings ☐ Complex Buildings ☒ HVAC – House ☐ Building Services ☐ Detection, Lighting and Power ☐ Fire Protection ☐ Building Structural ☐ Plumbing – House ☐ Plumbing – All Buildings ☐ On-site Sewage Systems			
Description of designer's work HEAT LOSS / GAIN CALCULATIONS DUCT SIZING RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY RESIDENTIAL SYSTEM DESIGN per CSA-F280-12		Model: 6002 - KINGSVIEW OPT 2ND Project: PINE VALLEY PH 2	
D. Declaration of Designer			
I, <u>MICHAEL O'ROURKE</u> declare that (choose one as appropriate): (print name)			
☐ I review and take responsibility for the design work on behalf of a firm registered under subsection 3.2.4. of Division C, of the Building Code. I am qualified, and the firm is registered, in the appropriate classes/categories. Individual BCIN: _____ Firm BCIN: _____			
☒ I review and take responsibility for the design and am qualified in the appropriate category as an "other designer" under subsection 3.2.5. of Division C, of the Building Code. Individual BCIN: <u>19669</u> Basis for exemption from registration and qualification: <u>O.B.C SENTENCE 3.2.4.1 (4)</u>			
☐ The design work is exempt from the registration and qualification requirements of the Building Code. Basis for exemption from registration and qualification: _____			
I certify that:			
1. The information contained in this schedule is true to the best of my knowledge. 2. I have submitted this application with the knowledge and consent of the firm.			
April 14, 2022 Date		 Signature of Designer	

NOTE:

- For the purposes of this form, "individual" means the "person" referred to in Clause 3.2.4.7(1) d) of Division C, Article 3.2.5.1. of Division C, and all other persons who are exempt from qualification under Subsections 3.2.4. and 3.2.5. of Division C.
- Schedule 1 is not required to be completed by a holder of a license, temporary license, or a certificate of authorization, issued by the Ontario Association of Architects. Schedule 1 is also not required to be completed by a holder of a license to practise, a limited license to practise, or a certificate of authorization, issued by the Association of Professional Engineers of Ontario.

Application for a Permit Construct or Demolish – Effective January 1, 2015

SITE NAME: PINE VALLEY PH 2			OPT 2ND			DATE Apr-22			WINTER NATURAL AIR CHANGE RATE 0.342			HEAT LOSS AT °F. 76			CSA-F280-12					
BUILDER: GOLD PARK HOMES			TYPE: 6002 - KINGSVIEW			GFA: 5901			LO# 96140			SUMMER NATURAL AIR CHANGE RATE 0.115			HEAT GAIN AT °F. 13			SB-12 PACKAGE A1		
ROOM USE																				
EXP. WALL																				
CLG. HT.																				
FACTORS																				
GRS.WALL AREA	LOSS	GAIN																		
GLAZING																				
NORTH	21.3	16.0																		
EAST	21.3	41.6																		
SOUTH	21.3	24.9																		
WEST	21.3	41.6																		
SKYLT.	37.2	101.5																		
DOORS	25.2	4.3																		
NET EXPOSED WALL	4.5	0.8																		
NET EXPOSED BSMT WALL ABOVE GR	3.6	0.6																		
EXPOSED CLG	1.3	0.6																		
NO ATTIC EXPOSED CLG	2.7	1.3																		
EXPOSED FLOOR	2.6	0.4																		
BASEMENT/CRAWL HEAT LOSS																				
SLAB ON GRADE HEAT LOSS																				
SUBTOTAL HT LOSS																				
SUB TOTAL HT GAIN																				
LEVEL FACTOR / MULTIPLIER																				
AIR CHANGE HEAT LOSS																				
AIR CHANGE HEAT GAIN																				
DUCT LOSS																				
DUCT GAIN																				
HEAT GAIN PEOPLE	240																			
HEAT GAIN APPLIANCES/LIGHTS																				
TOTAL HT LOSS BTU/H																				
TOTAL HT GAIN x 1.3 BTU/H																				

ROOM USE			OFFICE		FM/DN		KIT		GRT		CATER		PWD		FOY		MUD						WOD		BAS				
EXP. WALL			32		30		47		44		19		11		68		21						73		244				
CLG. HT.			11		11		11		11		11		11		11		11						10		10				
FACTORS																													
GRS.WALL AREA	LOSS	GAIN	355		333		522		488		211		122		755		233						737		2170				
GLAZING			LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN					LOSS	GAIN	LOSS	GAIN			
NORTH	21.3	16.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	12	255	192			0		0	0	0			
EAST	21.3	41.6	67	1426	2784	0	0	0	0	0	0	0	0	0	0	102	2171	4238	0	0	0	0		0	0	0			
SOUTH	21.3	24.9	0	0	0	69	1468	1718	0	0	0	0	0	0	0	0	0	0	0			0		0	8	170	199		
WEST	21.3	41.6	0	0	0	0	0	0	120	2554	4986	54	1149	2244	14	298	582	0	0	0			25		532	1039	0	0	0
SKYLT.	37.2	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			0		0	0	0	0	0	
DOORS	25.2	4.3	0	0	0	0	0	0	20	505	85	0	0	0	10	252	43	0	0	0			0		0	20	505	85	
NET EXPOSED WALL	4.5	0.8	288	1286	217	264	1178	198	382	1703	287	434	1939	327	187	834	140	122	545	92			640		2855	481	221	987	166
NET EXPOSED BSMT WALL ABOVE GR	3.6	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			413		1486	250	294	1058	178	
EXPOSED CLG	1.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			0		0	0	0	0	0	
NO ATTIC EXPOSED CLG	2.7	1.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			0		0	0	0	0	0	
EXPOSED FLOOR	2.6	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			0		0	0	0	0	0	
BASEMENT/CRAWL HEAT LOSS																													
SLAB ON GRADE HEAT LOSS																													
SUBTOTAL HT LOSS			2712		2646		4762		3088		1384		545		5503		1242						2018		10271				
SUB TOTAL HT GAIN					3001		1916		5358		2570		765		92		4843		358				1289		462				
LEVEL FACTOR / MULTIPLIER			0.30	0.55			0.30	0.55	0.30		0.55	0.30		0.55	0.30		0.55	0.30		0.55			0.50		1.63				
AIR CHANGE HEAT LOSS			1491		1455		2619		1698		761		300		3026		683								20057				
AIR CHANGE HEAT GAIN			229		146		409		196		58		7		369		27								134				
DUCT LOSS			0		0		0		0		0		0		0		0								0				
DUCT GAIN			0		0		0		0		0		0		0		0								0				
HEAT GAIN PEOPLE	240	0		0		0		0		0		0		0		0		0				0		0		0			
HEAT GAIN APPLIANCES/LIGHTS			1371		1371		1371		1371		1371		1371		0		0								0				
TOTAL HT LOSS BTU/H			4203		4102		7381		4786		2146		845		8529		1925						2018		30327				
TOTAL HT GAIN x 1.3 BTU/H			5981		4464		9280		5379		1070		128		6776		501						1676		775				

SITE NAME: PINE VALLEY PH 2				OPT 2ND				DATE Apr-22				WINTER NATURAL AIR CHANGE RATE 0.342				HEAT LOSS AT °F. 76				CSA-F280-12			
BUILDER: GOLD PARK HOMES				TYPE: 6002 - KINGSVIEW				GFA: 5901				SUMMER NATURAL AIR CHANGE RATE 0.115				HEAT GAIN ΔT °F. 13				SB-12 PACKAGE A1			
ROOM USE				PRI				ENS				WIC				WIC-2				BED-2			
EXP. WALL				21				35				39				0				14			
CLG. HT.				9				9				9				9				9			
FACTORS																							
GRS.WALL AREA				191				319				355				0				127			
GLAZING				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN			
NORTH				21.3	16.0	0	0	0	0	0	0	0	0	0	0	20	426	319	0	0	0	0	0
EAST				21.3	41.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SOUTH				21.3	24.9	0	0	0	0	0	0	9	192	224	0	0	0	0	0	0	0	0	0
WEST				21.3	41.6	44	936	1828	28	596	1163	32	681	1330	0	0	0	0	0	0	0	0	0
SKYLT.				37.2	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS				25.2	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL				4.5	0.8	147	656	111	291	1296	218	314	1401	236	0	0	0	107	479	81	0	0	0
NET EXPOSED BSMT WALL ABOVE GR				3.6	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG				1.3	0.6	440	565	259	304	390	179	375	481	220	165	212	97	285	366	167	0	0	0
NO ATTIC EXPOSED CLG				2.7	1.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR				2.6	0.4	0	0	0	0	0	0	0	0	0	55	140	24	218	556	94	0	0	0
BASEMENT/CRAWL HEAT LOSS						0			0			0			0			0			0		
SLAB ON GRADE HEAT LOSS						0			0			0			0			0			0		
SUBTOTAL HT LOSS						2157			2282			2755			352			1827			604		
SUB TOTAL HT GAIN							2197			1560			2010		121				661				
LEVEL FACTOR / MULTIPLIER				0.20	0.38			0.20	0.38			0.20	0.38		0.20	0.38		0.20	0.38				
AIR CHANGE HEAT LOSS						824			872			1052			134			698			231		
AIR CHANGE HEAT GAIN							168			119			153		9				50				
DUCT LOSS						0			0			0			49			252			83		
DUCT GAIN							0		0				0		13				232				
HEAT GAIN PEOPLE				240		2	480		0		0	0		0	1			240			0		
HEAT GAIN APPLIANCES/LIGHTS							1371		0				0		0				1371				
TOTAL HT LOSS BTU/H						2982			3154			3807			535			2777			918		
TOTAL HT GAIN x 1.3 BTU/H							5481			2183			2812		186				3322				

ROOM USE				BED-4				ENS-4				LAUN				BED-5				ENS-5			
EXP. WALL				31				5				7				14				7			
CLG. HT.				9				9				9				9				9			
FACTORS																							
GRS.WALL AREA				282				46				64				127				64			
GLAZING				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN				LOSS GAIN			
NORTH				21.3	16.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EAST				21.3	41.6	67	1426	2784	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SOUTH				21.3	24.9	0	0	0	9	192	224	9	192	224	20	426	498	9	192	224	0	0	0
WEST				21.3	41.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SKYLT.				37.2	101.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS				25.2	4.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL				4.5	0.8	215	960	162	37	163	27	55	244	41	107	479	81	55	244	41	0	0	0
NET EXPOSED BSMT WALL ABOVE GR				3.6	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG				1.3	0.6	332	426	195	56	72	33	220	282	129	414	531	243	78	100	46	0	0	0
NO ATTIC EXPOSED CLG				2.7	1.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR				2.6	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS						0			0			0			0			0			0		
SLAB ON GRADE HEAT LOSS						0			0			0			0			0			0		
SUBTOTAL HT LOSS						2812			426			718			1436				536				
SUB TOTAL HT GAIN							3141			284			394		822				311				
LEVEL FACTOR / MULTIPLIER				0.20	0.38			0.20	0.38			0.20	0.38		0.20	0.38		0.20	0.38				
AIR CHANGE HEAT LOSS						1074			163			274			549				205				
AIR CHANGE HEAT GAIN							240			22			30		63				24				
DUCT LOSS						0			0			0			0				0				
DUCT GAIN							0		0				0		0				0				
HEAT GAIN PEOPLE				240		1	240		0		0	0		0	1	240		0		0			
HEAT GAIN APPLIANCES/LIGHTS							1371		0				1371			1371			0				
TOTAL HT LOSS BTU/H						3886			589			992			1985				740				
TOTAL HT GAIN x 1.3 BTU/H							6489			398			2335		3245				435				

TOTAL HEAT GAIN BTU/H: 72519 TONS: 6.04 LOSS DUE TO VENTILATION LOAD BTU/H: 6156 STRUCTURAL HEAT LOSS: 96374 TOTAL COMBINED HEAT LOSS BTU/H: 102530

SITE NAME: PINE VALLEY PH 2
BUILDER: GOLD PARK HOMES

OPT 2ND
TYPE: 6002 - KINGSVIEW

DATE: Apr-22

GFA: 5901 LO# 96140

FURNACE 1

HEATING CFM 1190 COOLING CFM 1190
TOTAL HEAT LOSS 66,262 TOTAL HEAT GAIN 36,029
AIR FLOW RATE CFM 17.96 AIR FLOW RATE CFM 33.03

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

**FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 69340 BTUH**
\$*LENNOX
ML196UH090XE48C
90
FAN SPEED LOW 0
MEDLOW 1080
MEDIUM 1190
MEDIUM HIGH 1340
HIGH 1575

AFUE = 96 %
INPUT (BTU/H) = 88,000
OUTPUT (BTU/H) = **85,600**

DESIGN CFM = **1190**
CFM @ .6" E.S.P.

TEMPERATURE RISE 67 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	0	17	7
R/A	0	0	0	4	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	FOY	FOY	FOY	OFFCE	OFFCE	FM/DN	FM/DN	GRT	GRT	GRT	KIT	KIT	KIT	KIT	CATER	MUD	PWD	BAS	BAS	BAS	BAS	BAS	BAS	BAS
RM LOSS MBH.	2.84	2.84	2.84	2.10	2.10	2.05	2.05	1.60	1.60	1.60	1.85	1.85	1.85	1.85	2.15	1.93	0.84	4.62	4.62	4.62	4.62	4.62	4.62	4.62
CFM PER RUN HEAT	51	51	51	38	38	37	37	29	29	29	33	33	33	33	39	35	15	83	83	83	83	83	83	83
RM GAIN MBH.	2.26	2.26	2.26	2.99	2.99	2.23	2.23	1.79	1.79	1.79	2.32	2.32	2.32	2.32	1.07	0.50	0.13	0.35	0.35	0.35	0.35	0.35	0.35	0.35
CFM PER RUN COOLING	75	75	75	99	99	74	74	59	59	59	77	77	77	77	35	17	4	12	12	12	12	12	12	12
ADJUSTED PRESSURE	0.17	0.17	0.17	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	58	60	52	51	58	37	27	45	45	36	31	32	32	42	49	36	32	36	24	41	28	28	52	41
EQUIVALENT LENGTH	150	180	150	160	190	110	170	120	110	110	190	140	130	110	120	120	120	120	150	110	130	130	160	110
TOTAL EFFECTIVE LENGTH	208	240	202	211	248	147	197	165	155	146	221	172	162	152	169	156	152	156	174	151	158	158	212	151
ADJUSTED PRESSURE	0.08	0.07	0.09	0.08	0.07	0.12	0.09	0.1	0.11	0.12	0.08	0.1	0.11	0.11	0.1	0.11	0.11	0.1	0.09	0.11	0.1	0.1	0.08	0.11
ROUND DUCT SIZE	6	6	5	6	6	5	5	5	5	5	6	6	6	6	4	4	4	6	5	6	6	6	6	6
HEATING VELOCITY (ft/min)	260	260	374	194	194	272	272	213	213	213	168	168	168	168	447	402	172	423	609	423	423	423	423	423
COOLING VELOCITY (ft/min)	382	382	551	505	505	543	543	433	433	433	393	393	393	393	402	195	46	61	88	61	61	61	61	61
OUTLET GRILL SIZE	4X10	4X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	4X10	3X10	4X10	4X10	4X10	4X10	4X10
TRUNK	A	A	A	A	A	B	B	C	C	C	E	E	E	E	E	E	B	E	E	C	C	B	A	B

RUN #	
ROOM NAME	
RM LOSS MBH.	
CFM PER RUN HEAT	
RM GAIN MBH.	
CFM PER RUN COOLING	
ADJUSTED PRESSURE	
ACTUAL DUCT LGH.	
EQUIVALENT LENGTH	
TOTAL EFFECTIVE LENGTH	
ADJUSTED PRESSURE	
ROUND DUCT SIZE	
HEATING VELOCITY (ft/min)	
COOLING VELOCITY (ft/min)	
OUTLET GRILL SIZE	
TRUNK	

SUPPLY AIR TRUNK SIZE														RETURN AIR TRUNK SIZE													
	TRUNK	STATIC	ROUND	RECT			VELOCITY		TRUNK	STATIC	ROUND	RECT		VELOCITY		TRUNK	STATIC	ROUND	RECT			VELOCITY					
	CFM	PRESS.	DUCT	DUCT			(ft/min)		CFM	PRESS.	DUCT	DUCT		(ft/min)		CFM	PRESS.	DUCT	DUCT			(ft/min)					
TRUNK A	312	0.07	9.4	14	x	8	401	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.06	0	0	x	8	0				
TRUNK B	567	0.07	11.7	18	x	8	567	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.06	0	0	x	8	0				
TRUNK C	253	0.10	7.9	8	x	8	569	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.06	0	0	x	8	0				
TRUNK D	820	0.07	13.5	22	x	8	671	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.06	0	0	x	8	0				
TRUNK E	372	0.08	9.7	12	x	8	558	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.06	0	0	x	8	0				
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.06	0	0	x	8	0				

RETURN AIR #	1	2	3	4												BR
AIR VOLUME	120	310	370	175	0	0	0	0	0	0	0	0	0	0	0	215
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	58	53	44	34	1	1	1	1	1	1	1	1	1	1	1	15
EQUIVALENT LENGTH	195	200	150	160	0	0	0	0	0	0	0	0	0	0	0	140
TOTAL EFFECTIVE LH	253	253	194	194	1	1	1	1	1	1	1	1	1	1	1	155
ADJUSTED PRESSURE	0.06	0.06	0.08	0.08	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.10
ROUND DUCT SIZE	6.8	9.7	9.7	7.3	0	0	0	0	0	0	0	0	0	0	0	7.5
INLET GRILL SIZE	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	30	30	14	0	0	0	0	0	0	0	0	0	0	0	14

SITE NAME: PINE VALLEY PH 2
BUILDER: GOLD PARK HOMES

OPT 2ND
TYPE: 6002 - KINGSVIEW

DATE: Apr-22

GFA: 5901 LO# 96140

FURNACE 2

HEATING CFM 1110 COOLING CFM 1110
TOTAL HEAT LOSS 30,112 TOTAL HEAT GAIN 35,971
AIR FLOW RATE CFM 36.86 AIR FLOW RATE CFM 30.86

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 33190 BTUH

\$LENNOX
ML196UH045XE36B
FAN SPEED 45
LOW 620
MEDLOW 685
MEDIUM 980
MEDIUM HIGH 1110
HIGH 0

AFUE = 96 %
INPUT (BTU/H) = 44,000
OUTPUT (BTU/H) = 42,800

DESIGN CFM = 1110
CFM @ .6" E.S.P.

TEMPERATURE RISE 36 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	22	0	0
R/A	0	0	6	0	0

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46
ROOM NAME	PRI	PRI	ENS	ENS	WIC	WIC-2	BED-2	BED-2	ENS-2	WIC	WIC-3	ENS-3	BED-3	BED-3	BED-3	BED-4	BED-4	BED-4	ENS-4	LAUN	BED-5	ENS-5
RM LOSS MBH.	1.49	1.49	1.18	1.97	1.90	0.54	1.39	1.39	0.92	1.90	0.50	0.92	2.11	2.11	2.11	1.30	1.30	1.30	0.59	0.99	1.98	0.74
CFM PER RUN HEAT	55	55	44	73	70	20	51	51	34	70	18	34	78	78	78	48	48	48	22	37	73	27
RM GAIN MBH.	2.74	2.74	0.82	1.36	1.41	0.19	1.66	1.66	0.37	1.41	0.13	0.37	2.74	2.74	2.74	2.16	2.16	2.16	0.40	2.33	3.24	0.44
CFM PER RUN COOLING	85	85	25	42	43	6	51	51	11	43	4	11	85	85	85	67	67	67	12	72	100	13
ADJUSTED PRESSURE	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.16	0.17
ACTUAL DUCT LGH.	53	67	61	57	55	26	40	42	43	50	40	47	57	53	50	59	79	72	60	49	47	55
EQUIVALENT LENGTH	230	170	170	160	200	180	190	200	110	200	140	120	160	170	180	150	190	170	160	160	170	200
TOTAL EFFECTIVE LENGTH	283	237	231	217	255	206	230	242	153	250	180	167	217	223	230	209	269	242	220	209	217	255
ADJUSTED PRESSURE	0.06	0.07	0.07	0.08	0.07	0.08	0.07	0.07	0.11	0.07	0.1	0.1	0.07	0.07	0.07	0.08	0.06	0.07	0.08	0.08	0.07	0.07
ROUND DUCT SIZE	6	6	5	6	6	4	5	5	4	6	4	4	6	6	6	5	6	6	4	5	6	4
HEATING VELOCITY (ft/min)	280	280	323	372	357	229	374	374	390	357	207	390	398	398	398	352	245	245	252	272	372	310
COOLING VELOCITY (ft/min)	433	433	184	214	219	69	374	374	126	219	46	126	433	433	433	492	342	342	138	529	510	149
OUTLET GRILL SIZE	4X10	4X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	4X10	4X10	4X10	3X10	4X10	4X10	3X10	3X10	4X10	3X10
TRUNK	B	B	B	B	B	B	B	B	C	B	C	C	C	C	C	A	A	A	A	A	A	B

SUPPLY AIR TRUNK SIZE

	TRUNK	STATIC	ROUND	RECT			VELOCITY		TRUNK	STATIC	ROUND	RECT		VELOCITY	
	CFM	PRESS.	DUCT	DUCT			(ft/min)		CFM	PRESS.	DUCT	DUCT		(ft/min)	
TRUNK A	276	0.06	9.3	14	x	8	355	TRUNK G	0	0.00	0	0	x	8	0
TRUNK B	516	0.06	11.8	16	x	8	581	TRUNK H	0	0.00	0	0	x	8	0
TRUNK C	836	0.06	14.1	24	x	8	627	TRUNK I	0	0.00	0	0	x	8	0
TRUNK D	0	0.00	0	0	x	8	0	TRUNK J	0	0.00	0	0	x	8	0
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0

RETURN AIR TRUNK SIZE

	TRUNK	STATIC	ROUND	RECT		VELOCITY	
	CFM	PRESS.	DUCT	DUCT		(ft/min)	
TRUNK O	0	0.05	0	0	x	8	0
TRUNK P	0	0.05	0	0	x	8	0
TRUNK Q	0	0.05	0	0	x	8	0
TRUNK R	0	0.05	0	0	x	8	0
TRUNK S	0	0.05	0	0	x	8	0
TRUNK T	0	0.05	0	0	x	8	0
TRUNK U	0	0.05	0	0	x	8	0
TRUNK V	0	0.05	0	0	x	8	0
TRUNK W	270	0.05	9.7	12	x	8	405
TRUNK X	1110	0.05	16.4	32	x	8	624
TRUNK Y	550	0.05	12.6	20	x	8	495
TRUNK Z	420	0.05	11.4	16	x	8	473
DROP	1110	0.05	16.4	24	x	10	666

RETURN AIR #

	1	2	3	4	5	6										
AIR VOLUME	270	155	135	110	130	310	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	90	31	48	78	91	75	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	110	135	175	200	150	195	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	200	166	223	278	241	270	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.07	0.09	0.07	0.05	0.06	0.05	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	8.9	6.8	6.8	6.9	7	10.2	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	30	14	14	14	14	30	0	0	0	0	0	0	0	0	0	0

TYPE: 6002 - KINGSVIEW
SITE NAME: PINE VALLEY PH 2

LO # 96140
OPT 2ND

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐ Other:	Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm	<u>42.4</u> cfm
Other Bedrooms	<u>4</u> @ 10.6 cfm	<u>42.4</u> cfm
Kitchen & Bathrooms	<u>7</u> @ 10.6 cfm	<u>74.2</u> cfm
Other Rooms	<u>6</u> @ 10.6 cfm	<u>63.6</u> cfm
Table 9.32.3.A.	TOTAL	<u>222.6</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		<u>95.4</u> cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>222.6</u>	cfm
Less Principal Ventil. Capacity	<u>150</u>	cfm
Required Supplemental Capacity	<u>72.6</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE V150H
Location:	BSMT
<u>150.0</u> cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
150.0 CFM	X 76 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		BY INSTALLING CONTRACTOR		
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-2	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-3	BY INSTALLING CONTRACTOR	50	☒	3.5
PWD	BY INSTALLING CONTRACTOR	50	☒	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE V150H	INSTALL 2 HRV / ERV's
<u>150</u>	cfm high	<u>35</u> cfm low
<u>75</u>	% Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER:	
GOLD PARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-22

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669 *Michael O'Rourke* MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																																	
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																																	
LO#: 96140		Model: 6002 - KINGSVIEW		Builder: GOLD PARK HOMES			Date: 2022-04-14																																																										
Volume Calculation					Air Change & Delta T Data																																																												
House Volume <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr><td>Bsmt</td><td>2602</td><td>10</td><td>26280.2</td></tr> <tr><td>First</td><td>2602</td><td>11</td><td>28882.2</td></tr> <tr><td>Second</td><td>3415</td><td>9</td><td>31076.5</td></tr> <tr><td>Third</td><td>0</td><td>9</td><td>0</td></tr> <tr><td>Fourth</td><td>0</td><td>9</td><td>0</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>86,238.9 ft³</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>2442.0 m³</td></tr> </tbody> </table>					Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	2602	10	26280.2	First	2602	11	28882.2	Second	3415	9	31076.5	Third	0	9	0	Fourth	0	9	0	Total:			86,238.9 ft³	Total:			2442.0 m³	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%;">0.342</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.115</td> </tr> </table> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-20</td> <td>42</td> <td>76</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </table>					WINTER NATURAL AIR CHANGE RATE	0.342	SUMMER NATURAL AIR CHANGE RATE	0.115	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-20	42	76	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																														
Bsmt	2602	10	26280.2																																																														
First	2602	11	28882.2																																																														
Second	3415	9	31076.5																																																														
Third	0	9	0																																																														
Fourth	0	9	0																																																														
Total:			86,238.9 ft³																																																														
Total:			2442.0 m³																																																														
WINTER NATURAL AIR CHANGE RATE	0.342																																																																
SUMMER NATURAL AIR CHANGE RATE	0.115																																																																
Design Temperature Difference																																																																	
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																													
Winter DTDh	22	-20	42	76																																																													
Summer DTDc	24	31	7	13																																																													
5.2.3.1 Heat Loss due to Air Leakage					6.2.6 Sensible Gain due to Air Leakage																																																												
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.342 x 678.34 x 42 °C x 1.2 = 11757 W = 40114 Btu/h					$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.115 x 678.34 x 7 °C x 1.2 = 666 W = 2271 Btu/h																																																												
5.2.3.2 Heat Loss due to Mechanical Ventilation					6.2.7 Sensible heat Gain due to Ventilation																																																												
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E) \times 2 \text{ HRV / ERV's}$ 300 CFM x 76 °F x 1.08 x 0.25 = 6156 Btu/h					$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 300 CFM x 13 °F x 1.08 x 0.25 = 1,037 Btu/h																																																												
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																																	
$HL_{airr} = Level \ Factor \times HL_{airbv} \times \{ (HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel}) \}$																																																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairve Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{clevel})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)</th> </tr> </thead> <tbody> <tr><td>1</td><td>0.5</td><td rowspan="5" style="text-align: center; vertical-align: middle;">40,114</td><td>12,289</td><td>1.632</td></tr> <tr><td>2</td><td>0.3</td><td>21,882</td><td>0.550</td></tr> <tr><td>3</td><td>0.2</td><td>21,001</td><td>0.382</td></tr> <tr><td>4</td><td>0</td><td>0</td><td>0.000</td></tr> <tr><td>5</td><td>0</td><td>0</td><td>0.000</td></tr> </tbody> </table>										Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)	1	0.5	40,114	12,289	1.632	2	0.3	21,882	0.550	3	0.2	21,001	0.382	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																													
1	0.5	40,114	12,289	1.632																																																													
2	0.3		21,882	0.550																																																													
3	0.2		21,001	0.382																																																													
4	0		0	0.000																																																													
5	0		0	0.000																																																													
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																																	
					Michael O'Rourke BCIN# 19669 																																																												

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: 6002 - KINGSVIEW	OPT 2ND	BUILDER: GOLD PARK HOMES
SFQT: 5901	LO# 96140	SITE: PINE VALLEY PH 2

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-4	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.50

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft ³):	86238.9	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	6
INTERIOR LIGHTING LOAD (Btu/h/ft ²):	1.75	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	7.1 ft
LENGTH: 69.0 ft	WIDTH: 53.0 ft	EXPOSED PERIMETER:	244.0 ft


2012 OBC - COMPLIANCE PACKAGE		Compliance Package A1	
Component		Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value		60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value		31	27.65
Exposed Floor Minimum RSI (R)-Value		31	29.80
Walls Above Grade Minimum RSI (R)-Value		22	17.03
Basement Walls Minimum RSI (R)-Value		20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value		-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value		10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value		10	11.13
Windows and Sliding Glass Doors Maximum U-Value		0.28	-
Skylights Maximum U-Value		0.49	-
Space Heating Equipment Minimum AFUE		0.96	-
HRV Minimum Efficiency		75%	-
Domestic Hot Water Heater Minimum EF		0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Vaughan (Woodbridge)	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	21.0	
Floor Width (m):	16.2	
Exposed Perimeter (m):	0.0	
Wall Height (m):	3.1	
Depth Below Grade (m):	2.16	
Window Area (m ²):	3.1	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		2501

TYPE: 6002 - KINGSVIEW
LO# 96140

OPT 2ND


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description				
Province:	Ontario			
Region:	Vaughan (Woodbridge)			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.07			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	2442.0			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	3255.3 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	70.8	70.8		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.342			
Cooling Air Leakage Rate (ACH/H):	0.115			

TYPE: 6002 - KINGSVIEW
LO# 96140


OPT 2ND




BASEMENT PLAN ELEV. 'A', 'B' & 'C' - L.O.D. COND.




BASEMENT PLAN ELEV. 'A', 'B' & 'C' - W.O.D. COND.




BASEMENT PLAN ELEV. 'A', 'B' & 'C' (OPT. COVERED LOGGIA)



BASEMENT PLAN, EL. 'B'



BASEMENT PLAN, EL. 'C'



FURNACE 1
LENNOX ML196UH090XE48C
85,600 BTU/H OUTPUT
3.0 TONS A/C @ 1190 cfm

FURNACE 2
LENNOX ML196UH045XE36B
42,800 BTU/H OUTPUT
3.0 TONS A/C @ 1110 cfm

	S/A	R/A	FANS
2ND	22	6	6
1ST	17	4	2
BAS	7	1	0

HVAC LEGEND	
	OUTLET BY AIRMAX
	4"x10" SUPPLY GRILLE - 6' BOOT
	4"x10" SUPPLY GRILLE - 6' BOOT
	FLEX DUCT
	1400 RETURN AIR STACK
	1400 RETURN AIR GRILLE
	3000 RETURN AIR GRILLE
	FLOOR RETURN AIR GRILLE
	RETURN STACK ABOVE
	RETURN AIR STACK
	REDUCER
	SUPPLY DUCTWORK
	RETURN DUCTWORK
	LINT TRAP by REVERSOMATIC
	EXHAUST FAN
	DRYER BOOSTER FAN PROVIDE ACCESS PANEL, see Page
	DIRECT VENT
	LOW WALL
	HIGH WALL
	CEILING
	MOTORIZED ZONE DAMPER
	EXHAUST PIPE
	CONCENTRIC VENT KIT
	CONCENTRIC HRV or ERV VENT KIT
	SINGLE WALL BOX by REVERSOMATIC
	DOUBLE WALL BOX by REVERSOMATIC
	TRIPLE WALL BOX by REVERSOMATIC
	CONCENTRIC HRV VENT by REVERSOMATIC

I HEREBY CERTIFY THAT I HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED TO SIGN EXHIBITS 1.1.2 OF THE REGULATION.
Hvac Designer (P.E.) 1969
Hvac Designer (P.E.)

1	ISSUED FOR PERMIT	APRIL 2022	AK
No.	Revision	Date	By

SB-12 PACKAGE

A1

HVACDESIGNS LTD.
375 Finley Ave - Unit 202 - Ajax, Ontario L1S 2E2
Tel: 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdsgns.ca
Specializing in Residential Mechanical Design Services

Client: GOLDPARK HOMES

Project Name: PINE VALLEY PH2

VAUGHAN, ONTARIO

6002 - KINGSVIEW

OPT 2ND

5901 SQFT

Sheet Title: BASEMENT HVAC LAYOUT


Drawn By: AK

Scale: 3/16"=1'-0"

Date: APRIL 2022

LO # 96140




1



I MICHAEL O'ROURKE HAVE REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND A QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

SB-12 PACKAGE A1



HVAC LEGEND	
	OUTLET BY AIRMAX
	4x10' SUPPLY GRILLE - 5' FOOT
	4x10' SUPPLY GRILLE - 6' FOOT
	FLEX DUCT
	HV SUPPLY AIR STACK
	1400 RETURN AIR GRILLE
	3000 RETURN AIR GRILLE
	FLOOR RETURN AIR GRILLE
	RETURN STACK ABOVE
	RETURN AIR STACK
	REDUCER
	SUPPLY DUCTWORK
	RETURN DUCTWORK
	LIMP TRAP by REVEREOMATIC
	EXHAUST FAN
	DRYER BOOSTER FAN PROVIDE ACCESS PANEL as Req'd
DV	DIRECT VENT
LW	LOW WALL
HW	HIGH WALL
CLG	CEILING
	MOTORIZED ZONE DAMPER
	EXHAUST PIPE
	CONCENTRIC VENT KIT
	CONCENTRIC HRV by ERV VENT KIT
	SINGLE WALL BOX by REVEREOMATIC
	DOUBLE WALL BOX by REVEREOMATIC
	TRIPLE WALL BOX by REVEREOMATIC
	CONCENTRIC HRV VENT by REVEREOMATIC

I MICHAEL O'NEURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Neurke, BCTM# 19669
HVAC DESIGNS LTD.



2			
1	ISSUED FOR PERMIT	APRIL 2022	A
No.	Revision	Date	B

SB-12 PACKAGE

A1

SB-12 PACKAGE

A1

HVACDESIGNS LTD.
375 Finley Ave - Unit 202 - Ajax, Ontario L1S 2E2
Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdesigns.ca
Web: www.hvacdesigns.ca
Specializing In Residential Mechanical Design Services

Client **GOLDPARK HOMES**

Project Name **PINE VALLEY PH2**
VAUGHAN, ONTARIO

6002 - KINGSVIEW

OPT 2ND
5901 SQFT

Copyright © 2022, HMM, Inc.	
Sheet Title SECOND FLOOR HVAC LAYOUT	
Drawn By AK	Checked By MO
Scale 3/16"=1'-0"	Sheet No.
Date APRIL 2022	
LO # 96140	3

3