



SITE NAME: PINE VALLEY DRIVE  
 BUILDING: GOLD PARK HOMES  
 DATE: May-21  
 LO# 90629  
 WINTER NATURAL AIR CHANGE RATE 0.336  
 SUMMER NATURAL AIR CHANGE RATE 0.109  
 HEAT LOSS AT °F. 76  
 HEAT GAIN AT °F. 13  
 CSA-F280-12  
 SB-12 PACKAGE A1

ROOM USE	ENS	ENS-4	LAUN	BATH	B-BTH	HEAT LOSS AT °F.	HEAT GAIN AT °F.
ROOM USE	6	0	11	6	8		
EXP. WALL	13	25	9	9	9		
CLG. HT.	9	9	9	9	9		
FACTORS							
GRS.WALL AREA	117	225	99	54	60		
GLAZING	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN	LOSS GAIN		
NORTH	0	0	0	0	0		
EAST	16	0	0	0	0		
SOUTH	21.3	277	0	0	0		
WEST	21.3	448	7	0	0		
SKYLT.	37.2	1984	0	19	404		
DOORS	25.2	0	0	0	0		
NET EXPOSED WALL	4.5	0	0	35	156		
NET EXPOSED BSMT WALL ABOVE GR	3.6	0	0	0	0		
NO ATTIC EXPOSED CLG	1.3	0	0	78	100		
EXPOSED FLOOR	2.7	0	0	0	0		
EXPOSED FLOOR	2.6	0	0	78	199		
BASEMENT/CRAWL HEAT LOSS	0	0	0	0	0		
SLAB ON GRADE HEAT LOSS	0	0	0	0	0		
SUBTOTAL HT LOSS	991	200	1361	860	260		
SUB TOTAL HT GAIN	832	92	456	895	7		
LEVEL FACTOR / MULTIPLIER	0.20	0.20	0.20	0.20	0.50		
AIR CHANGE HEAT LOSS	247	545	338	214	415		
AIR CHANGE HEAT GAIN	0	139	28	54	0		
DUCT LOSS	0	0	170	107	0		
DUCT GAIN	0	0	48	95	0		
HEAT GAIN PEOPLE	1	240	0	0	0		
HEAT GAIN APPLANCES/LIGHTS	662	662	0	0	0		
TOTAL HT LOSS BTU/H	1238	2739	1869	1181	674		
TOTAL HT GAIN x 1.3 BTU/H	2320	4347	692	1358	10		

ROOM USE	FOY	KID/G	FOY	STRUCTURAL HEAT LOSS	TOTAL COMBINED HEAT LOSS	TONS
ROOM USE	27	81	2834	38860	40491	2.57
EXP. WALL	13	11	13			
CLG. HT.	13	11	13			
FACTORS						
GRS.WALL AREA	351	891	351			
GLAZING	LOSS GAIN	LOSS GAIN	LOSS GAIN			
NORTH	0	0	0			
EAST	99	2107	0			
SOUTH	48	1021	0			
WEST	0	0	21			
SKYLT.	0	0	44			
DOORS	0	0	286			
NET EXPOSED WALL	744	3320	1275			
NET EXPOSED BSMT WALL ABOVE GR	0	0	0			
NO ATTIC EXPOSED CLG	0	0	0			
EXPOSED FLOOR	0	0	0			
EXPOSED FLOOR	0	0	0			
BASEMENT/CRAWL HEAT LOSS	0	0	0			
SLAB ON GRADE HEAT LOSS	0	0	0			
SUBTOTAL HT LOSS	6448	5868	1275			
SUB TOTAL HT GAIN	0.30	0.44	0.30			
LEVEL FACTOR / MULTIPLIER	2853	355	77			
AIR CHANGE HEAT LOSS	0	0	0			
AIR CHANGE HEAT GAIN	0	0	0			
DUCT LOSS	0	0	0			
DUCT GAIN	0	0	0			
HEAT GAIN PEOPLE	240	662	0			
HEAT GAIN APPLANCES/LIGHTS	662	662	0			
TOTAL HT LOSS BTU/H	9301	8851	1757			
TOTAL HT GAIN x 1.3 BTU/H	1834					

TOTAL HEAT GAIN BTU/H: 30874 TONS: 2.57 LOSS DUE TO VENTILATION LOAD BTU/H: 1631 STRUCTURAL HEAT LOSS: 38860 TOTAL COMBINED HEAT LOSS BTU/H: 40491  
 I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C. 3.2.5 OF THE BUILDING CODE.  
 MICHAEL O'ROURKE  
 INDIVIDUAL BCIN: 19669

SITE NAME: PINE VALLEY DRIVE  
 BUILDER: GOLD PARK HOMES

END 2 - OPT 4-BED  
 TYPE: 3103 DATE: May-21

GFA: 2203 LO# 90629

HEATING CFM 980 COOLING CFM 980  
 TOTAL HEAT LOSS 38,860 TOTAL HEAT GAIN 30,599  
 AIR FLOW RATE CFM 25.22 AIR FLOW RATE CFM 32.03

AFUE = 96 %  
 INPUT (BTU/H) = 44,000  
 OUTPUT (BTU/H) = 42,800

DESIGN CFM = 980  
 CFM @ .5" E.S.P.

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	11	6	5
R/A	0	0	4	1	1

furnace pressure 0.6  
 furnace filter 0.05  
 a/c coil pressure 0.2  
 available pressure for s/a & r/a 0.35  
 plenum pressure s/a 0.18  
 max s/a dif press. loss 0.01  
 min adjusted pressure s/a 0.17  
 r/a grille press. loss 0.02  
 adjusted pressure r/a 0.15

All S/A diffusers 4"x10" unless noted otherwise on layout.  
 All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	19	20	21	22	23	24
ROOM NAME	BED-4	MBR	BED-2	BED-2	BED-3	BED-3	LAUN	ENS-4	MBR	ENS	BATH	K/D/G	K/D/G	K/D/G	K/D/G	FOY	FOY	BAS	BAS	BAS	BAS
RM LOSS MBH	1.24	1.42	1.75	1.75	1.37	1.37	1.87	0.25	1.42	0.74	1.18	2.33	2.33	2.33	2.33	2.04	2.04	2.61	2.61	2.61	2.61
CFM PER RUN HEAT	31	36	44	44	35	35	47	6	36	19	30	59	59	59	59	52	52	66	66	66	66
RM GAIN MBH	2.32	2.16	2.01	2.01	2.17	2.17	0.69	0.13	2.16	0.87	1.36	2.24	2.24	2.24	2.24	0.88	0.88	0.46	0.46	0.46	0.46
CFM PER RUN COOLING	74	69	64	64	70	70	22	4	69	28	43	72	72	72	72	28	28	15	15	15	15
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH	48	54	61	55	59	53	42	36	46	38	50	18	26	37	42	35	28	26	49	35	41
EQUIVALENT LENGTH	150	130	140	120	150	150	160	160	130	150	160	110	140	160	130	140	150	120	140	150	120
TOTAL EFFECTIVE LENGTH	198	184	201	175	209	203	202	196	176	188	210	128	166	197	172	175	178	146	189	185	161
ADJUSTED PRESSURE	0.09	0.09	0.09	0.09	0.08	0.08	0.09	0.09	0.09	0.08	0.08	0.13	0.13	0.13	0.13	0.1	0.1	0.12	0.09	0.09	0.11
ROUND DUCT SIZE	6	5	5	5	6	6	5	4	5	4	5	5	5	5	5	5	5	5	5	5	5
HEATING VELOCITY (ft/min)	158	264	323	323	178	178	345	69	264	218	220	433	433	433	433	382	382	485	485	485	485
COOLING VELOCITY (ft/min)	377	507	470	470	357	357	162	46	507	321	316	529	529	529	529	206	206	110	110	110	110
OUTLET GRILL SIZE	4X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10
TRUNK	B	A	A	B	C	C	A	B	B	B	B	D	B	A	A	C	C	D	A	A	C

RUN #	25
ROOM NAME	B-BTH
RM LOSS MBH	0.67
CFM PER RUN HEAT	17
RM GAIN MBH	0.01
CFM PER RUN COOLING	0
ADJUSTED PRESSURE	0.17
ACTUAL DUCT LGH	16
EQUIVALENT LENGTH	100
TOTAL EFFECTIVE LENGTH	116
ADJUSTED PRESSURE	0.15
ROUND DUCT SIZE	4
HEATING VELOCITY (ft/min)	195
COOLING VELOCITY (ft/min)	0
OUTLET GRILL SIZE	3X10
TRUNK	D

SUPPLY AIR TRUNK SIZE	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK A	377	0.09	9.4	10	679	0	0.00	0	0	0	0	0.00	0	0	0
TRUNK B	602	0.08	11.6	16	677	0	0.00	0	0	0	0	0.00	0	0	0
TRUNK C	240	0.08	8.2	8	540	0	0.00	0	0	0	0	0.00	0	0	0
TRUNK D	984	0.08	13.9	22	805	0	0.00	0	0	0	0	0.00	0	0	0
TRUNK E	0	0.00	0	0	0	0	0.00	0	0	0	0	0.00	0	0	0
TRUNK F	0	0.00	0	0	0	0	0.00	0	0	0	0	0.00	0	0	0

RETURN AIR #	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
1	0	2	3	4	0	0	0	0	0	0	0	0	0	0	0
2@8"	75	190	85	75	0	0	0	0	0	0	0	0	0	0	0
AIR VOLUME	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
PLENUM PRESSURE	44	42	55	57	42	1	1	1	1	1	1	1	1	1	1
ACTUAL DUCT LGH	245	165	195	250	185	0	0	0	0	0	0	0	0	0	0
EQUIVALENT LENGTH	289	207	250	307	227	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
TOTAL EFFECTIVE LH	6	7.8	6	6	10.5	0	0	0	0	0	0	0	0	0	0
ADJUSTED PRESSURE	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0
ROUND DUCT SIZE	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	24	14	14	30	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE															

TYPE: 3103  
 SITE NAME: PINE VALLEY DRIVE

LO # 90629  
 END 2 - OPT 4-BED

**RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY**

**COMBUSTION APPLIANCES 9.32.3.1(1)**

a)  Direct vent (sealed combustion) only

b)  Positive venting induced draft (except fireplaces)

c)  Natural draft, B-vent or induced draft gas fireplace

d)  Solid Fuel (including fireplaces)

e)  No Combustion Appliances

**HEATING SYSTEM**

Forced Air  Non Forced Air

Electric Space Heat

**HOUSE TYPE 9.32.1(2)**

I Type a) or b) appliance only, no solid fuel

II Type I except with solid fuel (including fireplaces)

III Any Type c) appliance

IV Type I, or II with electric space heat

Other: Type I, II or IV no forced air

**SYSTEM DESIGN OPTIONS O.N.H.W.P.**

1 Exhaust only/Forced Air System

2 HRV with Ducting/Forced Air System

3 HRV Simplified/connected to forced air system

4 HRV with Ducting/non forced air system

Part 6 Design

**TOTAL VENTILATION CAPACITY 9.32.3.3(1)**

Basement + Master Bedroom	2	@ 21.2 cfm	42.4	cfm
Other Bedrooms	3	@ 10.6 cfm	31.8	cfm
Kitchen & Bathrooms	6	@ 10.6 cfm	63.6	cfm
Other Rooms	2	@ 10.6 cfm	21.2	cfm
Table 9.32.3.A.	TOTAL		159.0	cfm

**PRINCIPAL VENTILATION CAPACITY REQUIRED 9.32.3.4.(1)**

1	Bedroom	31.8	cfm
2	Bedroom	47.7	cfm
3	Bedroom	63.6	cfm
4	Bedroom	79.5	cfm
5	Bedroom	95.4	cfm
<b>TOTAL</b>		<b>79.5</b>	<b>cfm</b>

**SUPPLEMENTAL VENTILATION CAPACITY 9.32.3.5.**

Total Ventilation Capacity	159	cfm
Less Principal Ventil. Capacity	79.5	cfm
Required Supplemental Capacity	79.5	cfm

**PRINCIPAL EXHAUST FAN CAPACITY**

Model: VANEE V150H Location: BSMT

79.5 cfm  HVI Approved

**PRINCIPAL EXHAUST HEAT LOSS CALCULATION**

CFM		ΔT °F		FACTOR		% LOSS
79.5 CFM	X	76 F	X	1.08	X	0.25

**SUPPLEMENTAL FANS BY INSTALLING CONTRACTOR**

Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
ENS-4	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
BATH	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5

**HEAT RECOVERY VENTILATOR 9.32.3.11.**

Model: VANEE V150H

150 cfm high 35 cfm low

75 % Sensible Efficiency  HVI Approved  
 @ 32 deg F ( 0 deg C)

**LOCATION OF INSTALLATION**

Lot: Concession

Township: Plan:

Address

Roll # Building Permit #

**BUILDER: GOLD PARK HOMES**

Name:

Address:

City:

Telephone #: Fax #:

**INSTALLING CONTRACTOR**

Name:

Address:

City:

Telephone #: Fax #:

**DESIGNER CERTIFICATION**

I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.

Name: HVAC Designs Ltd.

Signature: *Michael O'Rourke*

HRAI # 001820

Date: May-21

CSA F280-12 Residential Heat Loss and Heat Gain Calculations Formula Sheet (For Air Leakage / Ventilation Calculation)																											
LO#: 90629	Model: 3103																										
Builder: GOLD PARK HOMES																											
Date: 5/3/2021																											
Air Change & Delta T Data																											
	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 50%; text-align: right;">0.336</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td style="text-align: right;">0.109</td> </tr> </table>	WINTER NATURAL AIR CHANGE RATE	0.336	SUMMER NATURAL AIR CHANGE RATE	0.109																						
WINTER NATURAL AIR CHANGE RATE	0.336																										
SUMMER NATURAL AIR CHANGE RATE	0.109																										
Design Temperature Difference																											
	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 20%;">Tin °C</td> <td style="width: 20%;">Tout °C</td> <td style="width: 20%;">ΔT °C</td> <td style="width: 20%;">ΔT °F</td> </tr> <tr> <td>Winter DTDh</td> <td>-20</td> <td>42</td> <td>76</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>13</td> </tr> </table>	Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	-20	42	76	Summer DTDc	24	31	13														
Tin °C	Tout °C	ΔT °C	ΔT °F																								
Winter DTDh	-20	42	76																								
Summer DTDc	24	31	13																								
6.2.6 Sensible Gain due to Air Leakage																											
$HG_{saib} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$																											
$= 0.109 \times 235.45 \times 7 \times 1.2 = 220 \text{ W}$																											
6.2.7 Sensible heat Gain due to Ventilation																											
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$																											
$= 80 \text{ CFM} \times 13 \text{ °F} \times 1.08 \times 0.25 = 275 \text{ Btu/h}$																											
5.2.3.1 Heat Loss due to Mechanical Ventilation																											
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$																											
$= 0.336 \times 235.45 \times 42 \times 1.2 = 4012 \text{ W}$																											
5.2.3.2 Heat Loss due to Mechanical Ventilation																											
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$																											
$= 80 \text{ CFM} \times 76 \text{ °F} \times 1.08 \times 0.25 = 1631 \text{ Btu/h}$																											
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																											
$HL_{airr} = Level \ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{aglevel} + HL_{bglevel})\}$																											
	<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HLlevel)</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5" style="text-align: center;">13,688</td> <td>4,286</td> <td>1.597</td> </tr> <tr> <td>2</td> <td>0.3</td> <td>9,283</td> <td>0.442</td> </tr> <tr> <td>3</td> <td>0.2</td> <td>11,009</td> <td>0.249</td> </tr> <tr> <td>4</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> </tbody> </table>	Level	Level Factor (LF)	HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HLlevel)	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)	1	0.5	13,688	4,286	1.597	2	0.3	9,283	0.442	3	0.2	11,009	0.249	4	0	0	0.000	5	0	0	0.000
Level	Level Factor (LF)	HLairbv Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HLlevel)	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																							
1	0.5	13,688	4,286	1.597																							
2	0.3		9,283	0.442																							
3	0.2		11,009	0.249																							
4	0		0	0.000																							
5	0		0	0.000																							
<p>*HLairbv = Air leakage heat loss + ventilation heat loss                  *For a balanced or supply only ventilation system HLairve = 0</p>																											

### HEAT LOSS AND GAIN SUMMARY SHEET

<b>MODEL:</b> 3103	END 2 - OPT 4-BED	<b>BUILDER:</b> GOLD PARK HOMES
<b>SFQT:</b> 2203	<b>LO#</b> 90629	<b>SITE:</b> PINE VALLEY DRIVE

#### DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-4	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

#### BUILDING DATA


ATTACHMENT:	ATTACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft <sup>3</sup> ):	29934.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft <sup>2</sup> ):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	7.5 ft
LENGTH: 43.0 ft	WIDTH: 32.0 ft	EXPOSED PERIMETER:	106.0 ft

2012 OBC - COMPLIANCE PACKAGE  Component	Compliance Package A1	
	Nominal	Min. Eff.
	Ceiling with Attic Space Minimum RSI (R)-Value	60
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669  
MICHAEL O'ROURKE

# Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Vaughan (Woodbridge)	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	13.1	 <p>Insulation Configuration</p>
Floor Width (m):	9.8	
Exposed Perimeter (m):	32.3	
Wall Height (m):	2.7	
Depth Below Grade (m):	2.29	
Window Area (m <sup>2</sup> ):	1.5	
Door Area (m <sup>2</sup> ):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
<b>Heating Load (Watts):</b>	<b>840</b>	

# Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description				
Province:	Ontario			
Region:	Vaughan (Woodbridge)			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	6.55			
Building Configuration				
Type:	Semi			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m <sup>3</sup> ):	847.6			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1129.9 cm <sup>2</sup>		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
<b>Heating Air Leakage Rate (ACH/H):</b>	<b>0.336</b>			
<b>Cooling Air Leakage Rate (ACH/H):</b>	<b>0.109</b>			

TYPE: 3103  
 LO# 90629

END 2 - OPT 4-BED



UNEXCAVATED



BASEMENT PLAN, ELEV. 'A' & 'B'



CSA-F280-12  
PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.  
*Michael O'Rourke*  
Michael O'Rourke, BCIN# 19669  
HVAC DESIGNS LTD.

HVAC LEGEND							REVISIONS		
— □ —	SUPPLY AIR GRILLE	— ■ —	6" SUPPLY AIR BOOT ABOVE	— ▨ —	14"x8" RETURN AIR GRILLE	— ▩ —	RETURN AIR STACK ABOVE	3.	
— ■ —	SUPPLY AIR GRILLE 6" BOOT	○	SUPPLY AIR STACK FROM 2nd FLOOR	— ▨ —	30"x8" RETURN AIR GRILLE	— ▩ —	RETURN AIR STACK 2nd FLOOR	2.	
— ▨ —	SUPPLY AIR BOOT ABOVE	●	6" SUPPLY AIR STACK 2nd FLOOR	— ▨ —	FRA- FLOOR RETURN AIR GRILLE	— ▩ —	REDUCER	1.	
							No.	Description	Date

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. © AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client <b>GOLD PARK HOMES</b>	Project Name <b>PINE VALLEY DRIVE VAUGHAN, ONTARIO</b>	 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdsgns.ca Web: www.hvacdsgns.ca Specializing in Residential Mechanical Design Services	HEAT LOSS 40491 BTU/H	# OF RUNS	S/A	R/A	FANS	Sheet Title <b>BASEMENT HEATING LAYOUT</b>	
			UNIT DATA	3RD FLOOR					
			MAKE LENNOX	2ND FLOOR	11	4	4	Date APR/2021	
			MODEL ML196UH045XE36B	1ST FLOOR	6	1	2	Scale 3/16" = 1'-0"	
			INPUT 44 MBTU/H	BASEMENT	5	1	1	BCIN# 19669	
			OUTPUT 42.8 MBTU/H	ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A					LO# 90629
			COOLING 2.5 TONS						
			FAN SPEED 980 cfm @ 0.6" w.c.						
OPT 4-BED 3103 - END 2	2203 sqft	Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.							



GROUND FLOOR PLAN, ELEV. 'A'

CSA-F280-12  
PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.3 OF THE BUILDING CODE.  
*Michael O'Rourke*  
Michael O'Rourke, BCIN# 19669  
HVAC DESIGNS LTD.

HVAC LEGEND						REVISIONS	
— □ —	SUPPLY AIR GRILLE	— ■ —	6" SUPPLY AIR BOOT ABOVE	— ▨ —	14"x8" RETURN AIR GRILLE	— ▩ —	RETURN AIR STACK ABOVE
— ■ —	SUPPLY AIR GRILLE 6" BOOT	○	SUPPLY AIR STACK FROM 2nd FLOOR	— ▨ —	30"x8" RETURN AIR GRILLE	— ▩ —	RETURN AIR STACK 2nd FLOOR
— ▨ —	SUPPLY AIR BOOT ABOVE	●	6" SUPPLY AIR STACK 2nd FLOOR	— ▨ —	FRA- FLOOR RETURN AIR GRILLE	— ▩ —	REDUCER

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. © AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client  
**GOLD PARK HOMES**

Project Name  
**PINE VALLEY DRIVE  
VAUGHAN, ONTARIO**

**OPT 4-BED  
3103 - END 2      2203 sqft**

**HVAC DESIGNS LTD.**

375 Finley Ave. Suite 202 - Ajax, Ontario  
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375  
Email: info@hvacdsgns.ca  
Web: www.hvacdsgns.ca  
Specializing in Residential Mechanical Design Services

Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

3.

2.

1.

No.

Sheet Title  
**FIRST FLOOR  
HEATING  
LAYOUT**


Date    **APR/2021**

Scale    **3/16" = 1'-0"**


BCIN# 19669

LO#    **90629**

ROOF BELOW FOR OPT. COVERED LOGGIA



PART. SECOND FLOOR PLAN, ELEV. 'B'



4-BEDROOM IS STANDARD

CSA-F280-12  
PACKAGE A1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.  
*Michael O'Rourke*  
Michael O'Rourke, BCIN# 19669  
HVAC DESIGNS LTD.

OPT. 4-BEDROOM FLOOR PLAN, ELEV. 'A'  
(ELEV. 'B' SIMILAR)

HVAC LEGEND							3.	
[Symbol]	SUPPLY AIR GRILLE	[Symbol]	6" SUPPLY AIR BOOT ABOVE	[Symbol]	14"x8" RETURN AIR GRILLE	[Symbol]	RETURN AIR STACK ABOVE	2.
[Symbol]	SUPPLY AIR GRILLE 6" BOOT	[Symbol]	SUPPLY AIR STACK FROM 2nd FLOOR	[Symbol]	30"x8" RETURN AIR GRILLE	[Symbol]	RETURN AIR STACK 2nd FLOOR	1.
[Symbol]	SUPPLY AIR BOOT ABOVE	[Symbol]	6" SUPPLY AIR STACK 2nd FLOOR	[Symbol]	FRA- FLOOR RETURN AIR GRILLE	[Symbol]	REDUCER	No.

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USED OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client  
**GOLD PARK HOMES**

Project Name  
**PINE VALLEY DRIVE  
VAUGHAN, ONTARIO**

**OPT 4-BED  
3103 - END 2      2203 sqft**

**HVAC DESIGNS LTD.**  
375 Finley Ave. Suite 202 - Ajax, Ontario  
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375  
Email: info@hvacdsgns.ca  
Web: www.hvacdsgns.ca  
Specializing in Residential Mechanical Design Services

Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

REVISIONS	
No.	Date

Sheet Title  
**SECOND FLOOR HEATING LAYOUT**

Date **APR/2021**

Scale **3/16" = 1'-0"**

BCIN# **19669**

LO# **90629**