

ENGINEERING NOTE PAGE (ENP-1)
PLEASE READ PRIOR TO INSTALLATION

NE0818-068

GREENPARK-MINNISLAE HOMES-

GRANDBROOKE 1 EL 2 - Lot 13

Roof

RESPONSIBILITIES

THIS DESIGN IS FOR AN INDIVIDUAL BUILDING COMPONENT AND HAS BEEN BASED ON INFORMATION PROVIDED BY THE DESIGN OFFICE OF KOTT LUMBER. THE UNDERSIGNED ENGINEER DISCLAIMS ANY RESPONSIBILITY FOR DAMAGES AS A RESULT OF FAULTY OR INCORRECT INFORMATION, SPECIFICATION AND/OR DESIGNS FURNISHED TO THE ENGINEER. THE UNDERSIGNED ENGINEER IS ONLY RESPONSIBLE FOR THE STRUCTURAL INTEGRITY OF THIS BUILDING COMPONENT FOR THE CONDITIONS AND LOADS SHOWN ON THIS DRAWING. THE STRUCTURAL INTEGRITY OF THE BUILDING AND THE VERIFICATION OF THE DIMENSIONS AND THE DESIGN LOADS USED ARE THE RESPONSIBILITY OF THE BUILDING DESIGNER.

TRUSSES ARE DESIGNED IN CONFORMANCE WITH THE RELEVANT SECTIONS OF THE NATIONAL BUILDING CODE OF CANADA OR THE CANADIAN CODE FOR FARM BUILDINGS, WHICHEVER APPLIES TO THE BUILDING TYPE INDICATED ON THE DRAWING

IT IS THE RESPONSIBILITY OF KOTT LUMBER TO ENSURE THAT TRUSSES ARE MANUFACTURED IN CONFORMANCE WITH THESE DESIGNS AND WITH THE SPECIFICATIONS OUTLINED BELOW. THE UNDERSIGNED ENGINEER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

USE AND OCCUPANCY

- The building is of the type indicated on the drawing

LOADING

- The truss loading intensity and distribution as well as load transfer mechanism is that indicated on the drawing
- No buildings, trees, parapets or other projections higher than the roof for which the trusses are used are located within a distance less than ten (10) times the difference in height, or five metres (16 ft) whichever is greater, unless the drawing indicates that the snow drifting has been taken into account

HANDLING, INSTALLATION AND BRACING

- The trusses must be handled and installed by a qualified professional as per the supplied document titled *Information for Truss Installers* and the BCSI-B1 and BCSI-B3 Summary Sheets
- The compression chords are laterally braced by continuous rigid diaphragm sheathing or as specified on the drawing
- Temporary and permanent bracing must be installed as indicated on the truss drawing and according to the BCSI-B1 and BCSI-B3 Summary Sheets. Bracing for the lateral stability of the truss is to be provided by the building designer
- **It is recommended that a Professional Engineer's advice be obtained for the bracing of trusses spanning more than 12.37m (40'-7")**


SUPPORTS

- The trusses are to be supported at the bearing points indicated and anchored to the supports where considered necessary by the designer of the overall structure
- Bearing sizes shown are the minimum required to prevent crushing of the truss members and do not necessarily take into account stability of the overall building structure
- Elevation of bearings must be carefully checked and shimmed to alignment for solid bearings
- Adequate wood truss bearing is the responsibility of the building designer.

DIMENSIONS

- Geometry of the truss and dimensions indicated on the drawing are identical to those of the installed truss.

READ ALL NOTES ON THIS PAGE AND ON
ENGINEERING NOTE PAGE ENP-1. THIS
NOTE PAGE IS AN INTEGRAL PART OF
THIS DRAWING AS IT CONTAINS
SPECIFICATIONS AND CRITERIA USED IN
THE DESIGN OF THIS COMPONENT.



THIS CERTIFICATION IS FOR THE ENGINEERING REVIEW OF
STRUCTURAL COMPONENTS SHOWN ON THIS DRAWING
AND IS LIMITED TO THE COMPONENTS SUPPLIED BY KOTT
LUMBER FOR THE LOADS AND CONDITIONS SHOWN ON
THE CALCULATION PAGE OF EACH COMPONENT. THE
PLACEMENT OF THESE COMPONENTS ON THIS LAYOUT IS
SHOWN FOR REFERENCE ONLY. ROOF TRUSSES MUST BE
INSTALLED ACCORDING TO MANUFACTURER'S GUIDELINES
AT 24" C/C UNLESS NOTED OTHERWISE. CONVENTIONAL
FRAMING SHOWN ON THE LAYOUT MUST BE DESIGNED
AND APPROVED BY THE PROJECT ENGINEER. TEMPORARY
AND PERMANENT BRACINGS OF THE ROOF AND BUILDING
ARE THE RESPONSIBILITY OF THE PROJECT ENGINEER
AND TO CONFORM TO BCSI GUIDELINES.



**CONVENTIONAL
FRAMING BY OTHERS**

ALL CONVENTIONAL FRAMING TO CONFORM WITH
PART 8 OF THE O.B.C.
ROOF RAFTERS THAT CROSS OVER TRUSSES
TO BE 24 S.P.F. @ 24" O.C. WITH A 24" VERTICAL
POST TO THE TRUSS UNDERNEATH EACH CROSS
POINT. VERTICAL POST LONGER THAN 16' TO HAVE
LATERAL BRACING SO THAT THE DISTANCE BETWEEN
END POINT AND BETWEEN POINTS OF BRACING
DOES NOT EXCEED 6'

SIZE AND LOCATION OF CONVENTIONAL FRAMING
IS APPROPRIATE. ALL AREAS MAY NOT BE SHOWN.
REFER TO ARCHITECTURAL PLANS FOR DETAILS.

HANGER LEGEND:


- ▼ LUS24
- LJS26DS
- HGUS26
- ✕ HGUS26-2

DESIGN CRITERIA
SPECIFIED LOADS
TOP CR. LA = 21.3 PSF
DL = 3 PSF
DOT CR. LL = 0 PSF
WB = 0.5 PSF
TOTAL LOAD = 24.8 PSF
SPACING = 24" O.C.

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR
SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010
THIS DESIGN COMPLIES WITH
PART 9 OF NBC 2012, BCS 2012, AISC 2014
CSA S16-09
TFC 2011

Model: **GRANDBROOKE 1 EL 2**
Customer: **GREENPARK**
Project: **MINNISALE HOMES**
Location: **BRAMPTON**
Date: **6/22/2018** Drawn by: **BB**

Architectural Drawing Info
Date: JULY 26, 2015
Project Number: 18-24
Model: GRANDBROOKE 1



LUMBER
N. L. G. A. RULES

CHORDS	SIZE	LUMBER	DESCR.
1 - 4	2x4	DRY	No.2
4 - 7	2x4	DRY	No.2
7 - 10	2x4	DRY	No.2
19 - 2	2x4	DRY	No.2
11 - 9	2x4	DRY	No.2
19 - 14	2x4	DRY	No.2
14 - 11	2x4	DRY	No.2
ALL WEBS	2x3	DRY	No.2
EXCEPT			

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
2	TMVW-I	MT20	5.0	6.0	1.75	3.00
3	TMVW-I	MT20	3.0	4.0	1.50	1.75
4	TTWW+m	MT20	6.0	6.0	2.50	2.00
5	TMVW-w	MT20	2.0	4.0		
6	TMVW-I	MT20	3.0	4.0		
7	TTWW+m	MT20	6.0	6.0	2.50	2.00
8	TMVW-I	MT20	3.0	4.0	1.50	1.75
9	TMVW-I	MT20	5.0	6.0	1.75	3.00
11	BMV1+p	MT20	3.0	4.0	2.00	
12	BMVW-I	MT20	3.0	8.0	1.50	2.00
13	BMVW-I	MT20	3.0	4.0		
14	BS-I	MT20	3.0	6.0		
15	BMVW-I	MT20	4.0	4.0	1.75	1.75
16	BMVW-I	MT20	4.0	6.0	1.50	2.00
17	BMVW-I	MT20	3.0	4.0		
18	BMVW-I	MT20	3.0	8.0	1.50	2.00
19	BMV1+p	MT20	3.0	4.0	2.00	0.50

HANGERS NOTES
1) SPECIAL HANGER(S) OR CONNECTION(S) REQUIRED TO SUPPORT CONCENTRATED LOAD(S) 348.1 lbs FACTORED DOWN AT 19-0-0, AND 348.1 lbs FACTORED DOWN AT 6-0-0 ON TOP CHORD. DESIGN FOR UNSPECIFIED CONNECTION(S) IS DELEGATED TO THE BUILDING DESIGNER.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	VERT	HORZ	DOWN	HORZ	UPLIFT	IN-SX	IN-SX
19	2278	0	2278	0	0	5-8	5-8
11	2278	0	2278	0	0	5-8	5-8

UNFACTORED REACTIONS

JT	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
19	1598	1123 / 0	0 / 0	0 / 0	0 / 0	475 / 0	0 / 0
11	1598	1123 / 0	0 / 0	0 / 0	0 / 0	475 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 19, 11

BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 3.22 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING
TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX LC1 (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX LC1 (LC)	MAX UNBRACED LENGTH FR-TO
1-2	0 / 27	-77.4	-77.4 0.11 (1)	10-00	18-3	-621 / 0	0.12 (1)
2-3	-2598 / 0	-77.4	-77.4 0.20 (1)	4.10	3-17	0 / 307	0.08 (1)
3-4	-2884 / 0	-77.4	-77.4 0.20 (1)	3.91	17-4	-70 / 99	0.04 (4)
4-5	-3270 / 0	-145.9	-145.9 0.58 (1)	3.24	4-16	0 / 1138	0.28 (1)
5-6	-3270 / 0	-145.9	-145.9 0.58 (1)	3.22	16-5	-676 / 0	0.24 (1)
6-7	-3273 / 0	-145.9	-145.9 0.58 (1)	3.22	16-6	-4 / 0	0.00 (1)
7-8	-2883 / 0	-77.4	-77.4 0.20 (1)	3.91	15-6	-678 / 0	0.24 (1)
8-9	-2599 / 0	-77.4	-77.4 0.20 (1)	4.10	15-7	0 / 1143	0.28 (1)
9-10	0 / 27	-77.4	-77.4 0.11 (1)	10.00	13-7	-73 / 99	0.04 (4)
19-2	-2226 / 0	0.0	0.0 0.25 (1)	5.65	13-8	0 / 307	0.08 (1)
11-9	-2226 / 0	0.0	0.0 0.25 (1)	5.65	12-8	-620 / 0	0.12 (1)
					2-18	0 / 2360	0.58 (1)
19-18	0 / 0	-33.0	-33.0 0.08 (4)	10.00	12-9	0 / 2360	0.58 (1)
18-17	0 / 2252	-33.0	-33.0 0.46 (1)	10.00			
17-16	0 / 2476	-33.0	-33.0 0.50 (1)	10.00			
16-15	0 / 3273	-33.0	-33.0 0.64 (1)	10.00			
15-14	0 / 2476	-33.0	-33.0 0.50 (1)	10.00			
14-13	0 / 2476	-33.0	-33.0 0.50 (1)	10.00			
13-12	0 / 2253	-33.0	-33.0 0.46 (1)	10.00			
12-11	0 / 0	-33.0	-33.0 0.08 (4)	10.00			

FACTORED CONCENTRATED LOADS (LBS)

JT	LOC.	LC1	MAX-	MAX+	FACE	DIR.	TYPE
4	6-0-0	-348	-348	---	FRONT	VERT	TOTAL
7	19-0-0	-348	-348	---	FRONT	VERT	TOTAL

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 23.3 PSF
DL = 3.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.0 PSF
TOTAL LOAD = 33.3 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 2.00/12 MINIMUM

GIRDER TYPE: CPrimeHip
SIDE SETBACK = 6-0-0
END SETBACK = 6-0-0
END WALL WIDTH = 5-8
CORNER FRAMING TYPE: CONVENTIONAL
END JACK TYPE: CONVENTIONAL
APPLIED TO FRONT SIDE
- ADDTL. LOADS BASED ON 55 % OF GSL.

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

(55 % OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.83")
CALCULATED VERT. DEFL.(LL) = L/999 (0.12")
ALLOWABLE DEFL.(TL) = L/360 (0.83")
CALCULATED VERT. DEFL.(TL) = L/999 (0.22")

CSI: TC=0.59/1.00 (6-7:1), BC=0.64/1.00 (15-16:1), WB=0.58/1.00 (9-12:1), SSI=0.32/1.00 (6-7:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS= 1.00

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE	GRIP(DRY)	SHEAR (PSI)	SECTION (PLI)	MAX MIN	MAX MIN	MAX MIN
MT20	618	354	1667	822	2284	1658

CONTINUED ON PAGE 2



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.




JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
NE0818-068	G01	1	1	GREENPARK-MINNISLAE HOMES-GRANDBROOKE 1 EL 2	PAGE 4 OF 28

Version 8.210 S Mar 12 2018 MiTek Industries, Inc. Tue Aug 14 13:10:15 2018 Page 2
ID:w 6JogZnfv1q7BUYX2Ki0Uz3oDL-gllMu2AG64RyDNMTH6rZBz5LFd2iqQumQ?dXnynxK6

PLATE PLACEMENT TOL. = 0.250 inches
PLATE ROTATION TOL. = 5.0 Deg.
JSI GRIP= 0.90 (12) (INPUT = 0.90)
JSI METAL= 0.68 (9) (INPUT = 1.00)

READ ALL NOTES ON THIS PAGE AND ON
ENGINEERING NOTE PAGE ENP-1. THIS
NOTE PAGE IS AN INTEGRAL PART OF
THIS DRAWING AS IT CONTAINS
SPECIFICATIONS AND CRITERIA USED IN
THE DESIGN OF THIS COMPONENT.





TOP - COMPONENTS ARE LOADED FROM THE TOP AND MUST BE PLACED ON TOP EDGE OF ALL PLIES FOR THE LOAD TO BE TRANSFERRED TO EACH PLY.

C H O R D S				W E B S			
MAX. FACTORED		FACTORED		MAX. FACTORED			
MEMB.	FORCE	VERT. LOAD	LC1 MAX	MAX.	MEMB.	FORCE	MAX
	(LBS)	(PLF)	CSI (LC)	UNBRAC		(LBS)	CSI (LC)
FR-TO		FR-TO		LENGTH	FR-TO		
18-2	-7957 / 0	0.0	0.0 89 (1)	5.33	2-17	0 / 10334	0.91 (1)
1-2	0 / 0	-77.4	-77.4 0.05 (1)	10.00	17-3	-5179 / 0	0.85 (1)
2-3	-6988 / 0	-145.9	-145.9 0.38 (1)	3.44	3-16	0 / 6005	0.74 (1)
3-4	-10931 / 0	-145.9	-145.9 0.87 (1)	2.49	16-4	-2631 / 0	0.43 (1)
4-5	-12744 / 0	-145.9	-145.9 0.87 (1)	2.15	4-14	0 / 2762	0.34 (1)
5-6	-12744 / 0	-77.4	-77.4 0.82 (1)	2.21	14-5	-445 / 0	0.07 (1)
6-7	-12744 / 0	-77.4	-77.4 0.82 (1)	2.21	4-7	0 / 2193	0.27 (1)
7-8	-11185 / 0	-77.4	-77.4 0.65 (1)	2.53	13-7	-1867 / 0	0.31 (1)
8-9	-7139 / 0	-77.4	-77.4 0.34 (1)	3.47	13-8	0 / 5760	0.71 (1)
9-10	0 / 0	-77.4	-77.4 0.05 (1)	10.00	12-8	-4483 / 0	0.73 (1)
11-9	-7307 / 0	0.0	0.0 82 (1)	5.54	12-9	0 / 10043	0.89 (1)
18-17	0 / 0	-531.8	-531.8 0.16 (1)	10.00			
17-16	0 / 6988	-531.8	-531.8 0.35 (1)	10.00			
16-15	0 / 10931	-531.8	-531.8 0.42 (1)	10.00			
15-14	0 / 10931	-531.8	-531.8 0.42 (1)	10.00			
14-13	0 / 11185	-516.3	-516.3 0.46 (1)	10.00			
13-12	0 / 7139	-516.3	-516.3 0.38 (1)	10.00			
12-11	0 / 0	-516.3	-516.3 0.19 (1)	10.00			

FACTORED CONCENTRATED LOADS (LBS)							
JT	LOC.	LC1	MAX-	MAX+	FACE	DIR.	TYPE
14	11-8-12	-1049	-1049	—	FRONT	VERT	TOTAL

ALLOWABLE DEFL.(LL)= $L/360$ (0.83")
CALCULATED VERT. DEFL.(LL) = $L/999$ (0.24")
ALLOWABLE DEFL.(TL)= $L/360$ (0.83")
CALCULATED VERT. DEFL.(TL) = $L/723$ (0.41")


KOTT

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
2	TMVW-I	MT20	6.0	8.0	1.75	3.25
3	TMVW-I	MT20	5.0	6.0	1.50	1.75
4	TMVW-I	MT20	4.0	4.0	1.50	1.50
5	TMVW-w	MT20	2.0	4.0		
6	TS-I	MT20	3.0	8.0		
7	TMVW-I	MT20	4.0	4.0	2.00	1.50
8	TMVW-I	MT20	5.0	6.0	1.75	1.75
9	TMVW-I	MT20	6.0	8.0	2.00	3.00
11	BMV1+p	MT20	3.0	5.0	2.75	1.50
12	BMVW+I	MT20	6.0	8.0	3.75	1.50
13	BMVW+I	MT20	5.0	6.0	2.25	1.50
14	BMVW+I	MT20	8.0	8.0	4.25	4.00
15	BS-I	MT20	6.0	8.0		
16	BMVW+I	MT20	5.0	6.0	2.00	1.50
17	BMVW+I	MT20	6.0	8.0	3.50	1.75
18	BMV1+I	MT20	6.0	8.0	5.50	

HANGERS NOTES

- 1) SPECIAL HANGER(S) OR CONNECTION(S) REQUIRED TO SUPPORT CONCENTRATED LOAD(S) 1048.7 lbs FACTORED DOWN AT 11-8-12 ON BOTTOM CHORD. DESIGN FOR UNSPECIFIED CONNECTION(S) IS DELEGATED TO THE BUILDING DESIGNER.

CSI: TC=0.89/1.00 (2-18:1) , BC=0.46/1.00 (13-14:1) , WB=0.91/1.00 (2-17:1) , SSI=0.45/1.00 (11-12:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS= 1.00

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT .

NAIL VALUES

PLATE	GRIP(DRY)	SHEAR	SECTION
	(PSI)	(PLI)	(PLI)
	MAX MIN	MAX MIN	MAX MIN
MT20	618 354	1667 822	2284 1656


PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.90 (2) (INPUT = 0.90)
JSI METAL= 0.84 (15) (INPUT = 1.00)

READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





TOTAL WEIGHT = 31 lb [M]

LUMBER				DESCR.	
N. L. G. A. RULES	CHORDS	SIZE	LUMBER		
6 - 1	2x4	DRY	No.2	SPF	
1 - 3	2x4	DRY	No.2	SPF	
4 - 3	2x4	DRY	No.2	SPF	
6 - 4	2x6	DRY	No.2	SPF	
ALL WEBS 2x3 DRY No.2				SPF	
DRY: SEASONED LUMBER.					

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
1	TMVW+p	MT20	4.0	4.0	1.25	2.00
2	TMVW+t	MT20	3.0	4.0	1.50	0.75
3	TMV+p	MT20	2.0	4.0		
4	BMVW1-t	MT20	4.0	4.0		
5	BMVW-t	MT20	4.0	4.0	1.75	1.75
6	BMV1+p	MT20	2.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS		FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG		REQRD BRG	
JT		VERT	HORZ	DOWN	HORZ	UPLIFT	IN-SX	IN-SX	
6		1049	0	1049	0	0	5-8	5-8	
4		1049	0	1049	0	0	MECHANICAL		

A SUITABLE MECHANICAL CONNECTION IS REQUIRED AT JOINT 4 TO RESIST THE MAX FACTORED REACTIONS.

UNFACTORED REACTIONS

1ST LCASE		MAX./MIN. COMPONENT REACTIONS					
JT	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
6	736	515 / 0	0 / 0	0 / 0	0 / 0	221 / 0	0 / 0
4	736	515 / 0	0 / 0	0 / 0	0 / 0	221 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 6

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX CSI (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX CSI (LC)
FR-TO		FROM TO		FR-TO		FROM TO	
6-1	-709 / 0	0.0	0.0 0.08 (1)	7.81	1-5	0 / 732	0.18 (1)
1-2	-800 / 0	-77.4	-77.4 0.12 (1)	6.25	5-2	0 / 746	0.18 (1)
2-3	-12 / 0	-77.4	-77.4 0.11 (1)	6.25	2-4	-935 / 0	0.25 (1)
4-3	-92 / 0	0.0	0.0 0.03 (1)	7.81			
6-5	0 / 0	-272.4	-272.4 0.16 (1)	10.00			
5-4	0 / 702	-272.4	-272.4 0.25 (1)	10.00			

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 23.3 PSF
	DL = 3.0 PSF
BOT CH.	LL = 0.0 PSF
	DL = 7.0 PSF
TOTAL LOAD	= 33.3 PSF

SPACING = 24.0 IN. C/C

GIRDER TYPE: CSldGirder

START DISTANCE = 0-0

START SPAN CARRIED = 13-2-8

END DISTANCE = 6-0-0

END SPAN CARRIED = 13-2-8

END WALL WIDTH = 5-8

APPLIED TO FRONT SIDE OF BOTTOM CHORD.

- ADD'L LOADS BASED ON 55 % OF GSL.

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:

- PART 9 OF OBC 2012, BCBC 2012, ABC 2014

- CSA 086-09

- TPIC 2011

(55 % OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL)= L/360 (0.20")
CALCULATED VERT. DEFL.(LL)= L/999 (0.01")
ALLOWABLE DEFL.(TL)= L/360 (0.20")
CALCULATED VERT. DEFL.(TL)= L/999 (0.02")

CSI: TC=0.12/1.00 (1-2:1), BC=0.25/1.00 (4-5:1), WB=0.25/1.00 (2-4:1), SSI=0.32/1.00 (5-6:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS=1.00

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES		PLATE GRIP(DRY) SHEAR		SECTION	
(PSI)	(PLI)	(PSI)	(PLI)	(PLI)	(PLI)
MAX	MIN	MAX	MIN	MAX	MIN
MT20	618	354	1667	822	2284

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

CONTINUED ON PAGE 2



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.




JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
NE0818-068	G03	1	1	GREENPARK-MINNISLAE HOMES-GRANDBROOKE 1 EL 2	PAGE 8 OF 28

Version 8.210 S Mar 12 2018 MiTek Industries, Inc. Tue Aug 14 13:10:16 2018 Page 2
ID:w_6JogZnfv1q7BUYX2Ki0Uz3oDL-8UsI5OButNZpqXxfrpMojAeeN1V6ZzPveeNmTDynxK5

JSI GRIP= 0.89 (5) (INPUT = 0.90)
JSI METAL= 0.31 (2) (INPUT = 1.00)

READ ALL NOTES ON THIS PAGE AND ON
ENGINEERING NOTE PAGE ENP-1. THIS
NOTE PAGE IS AN INTEGRAL PART OF
THIS DRAWING AS IT CONTAINS
SPECIFICATIONS AND CRITERIA USED IN
THE DESIGN OF THIS COMPONENT.





TOTAL WEIGHT = 2 X 129 = 258 lb [M]

LUMBER				
N. L. G. A. RULES				
CHORDS	SIZE		LUMBER	DESCR.
1 - 4	2x4	DRY	No.2	SPF
4 - 7	2x4	DRY	No.2	SPF
15 - 1	2x6	DRY	No.2	SPF
8 - 7	2x6	DRY	No.2	SPF
15 - 11	2x6	DRY	No.2	SPF
11 - 8	2x6	DRY	No.2	SPF

ALL WEBS EXCEPT				
	SIZE		LUMBER	DESCR.
1 - 14	2x4	DRY	No.2	SPF
9 - 7	2x4	DRY	No.2	SPF

DRY: SEASONED LUMBER.

DESIGN CONSISTS OF 2 TRUSSES BUILT SEPARATELY THEN FASTENED TOGETHER AS FOLLOWS:

CHORDS #ROWS	SURFACE SPACING (IN)	LOAD (PLF)
TOP CHORDS : (0.122"x3") SPIRAL NAILS		
1-4	12	TOP
4-7	12	TOP
15-1	12	TOP
8-7	12	TOP
BOTTOM CHORDS : (0.122"x3") SPIRAL NAILS		
15-11	9	SIDE(249.4)
11-8	9	SIDE(249.4)
WEBS : (0.122"x3") SPIRAL NAILS		
2x3	6	
2x4	6	

NAILS TO BE DRIVEN FROM ONE SIDE ONLY.

TOP - COMPONENTS ARE LOADED FROM THE TOP AND MUST BE PLACED ON TOP EDGE OF ALL PLIES FOR THE LOAD TO BE TRANSFERRED TO EACH PLY.

SIDE - PLF SHOWN IS THE EQUIVALENT UDL APPLIED TO ONE SIDE THAT THE CORRESPONDING NAILING PATTERN SHALL BE CAPABLE OF TRANSFERING. REMAINING PLF MUST BE APPLIED ON THE OPPOSITE SIDE OR ON THE TOP.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG	REQRD IN-SX
	VERT	HORZ	DOWN	HORZ		
15	7420	0	7420	0	5-8	5-8
8	7420	0	7420	0	5-8	5-8

UNFACTORED REACTIONS

JT	1ST LCASE		MAX/MIN. COMPONENT REACTIONS		WIND	DEAD	SOIL
	COMBINED	SNOW	LIVE	PERM.LIVE			
15	5208	3643 / 0	0 / 0	0 / 0	0 / 0	1564 / 0	0 / 0
8	5208	3643 / 0	0 / 0	0 / 0	0 / 0	1564 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 15, 8

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 2.94 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 - 1x4 LATERAL BRACE(S) AT 1/2 LENGTH OF 5-12, 3-12. DBS = 12-0-0. CBF = 191 LBS.

DBS = DIAGONAL BRACE SPACING (MAX). CBF = CUMULATIVE BRACING FORCE (PER BRACE). FASTEN LATERAL BRACE(S) TO EACH PLY USING (0.122"x3") SPIRAL NAILS : 1 NAIL FOR 2x3 BRACE(S), 2 FOR 1x4, 2x4, 2x5, 3 FOR 2x6, 4 FOR 2x8, 5 FOR 2x10, AND 6 FOR 2x12.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

CHORDS					WEBS				
MAX. FACTORED		FACTORED			MAX. FACTORED				
MEMB.	FORCE	VERT. LOAD	LC1 MAX	MAX.	MEMB.	FORCE	MAX.		
	(LBS)	(PLF)	CSI (LC)	UNBRACED		(LBS)	CSI (LC)		
FR-TO		FROM	TO	LENGTH	FR-TO				
1-2	-9244 / 0	-77.4	-77.4	0.50 (1)	2.94	12-4	0 / 6458	0.80 (1)	
2-3	-8384 / 0	-77.4	-77.4	0.36 (1)	3.19	12-5	-2541 / 0	0.44 (1)	
3-4	-6695 / 0	-77.4	-77.4	0.29 (1)	3.61	10-5	0 / 2592	0.32 (1)	
4-5	-6695 / 0	-77.4	-77.4	0.29 (1)	3.61	10-6	-972 / 0	0.23 (1)	
5-6	-8384 / 0	-77.4	-77.4	0.36 (1)	3.19	9-6	0 / 720	0.09 (1)	
6-7	-9244 / 0	-77.4	-77.4	0.50 (1)	2.94	3-12	-2541 / 0	0.44 (1)	
15-1	-6462 / 0	0.0	0.0	0.23 (1)	5.84	13-3	0 / 2592	0.32 (1)	
8-7	-6462 / 0	0.0	0.0	0.23 (1)	5.84	2-13	-972 / 0	0.23 (1)	
						14-2	0 / 720	0.09 (1)	
15-14	0 / 0	-516.3	-516.3	0.33 (1)	10.00	1-14	0 / 8159	0.72 (1)	
14-13	0 / 7991	-516.3	-516.3	0.76 (1)	10.00	9-7	0 / 8159	0.72 (1)	
13-12	0 / 7243	-516.3	-516.3	0.79 (1)	10.00				
12-11	0 / 7243	-516.3	-516.3	0.79 (1)	10.00				
11-10	0 / 7243	-516.3	-516.3	0.79 (1)	10.00				
10-9	0 / 7991	-516.3	-516.3	0.76 (1)	10.00				
9-8	0 / 0	-516.3	-516.3	0.33 (1)	10.00				

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 23.3	PSF
	DL = 3.0	PSF
BOT CH.	LL = 0.0	PSF
	DL = 7.0	PSF
TOTAL LOAD	= 33.3	PSF

SPACING = 24.0 IN. C/C

GIRDER TYPE: CstdGirder

START DISTANCE = 0-0

START SPAN CARRIED = 23-0-6

END DISTANCE = 25-0-0

END SPAN CARRIED = 23-0-6

END WALL WIDTH = 0-0

APPLIED TO FRONT SIDE OF BOTTOM CHORD.

- ADDTL. LOADS BASED ON 55 % OF GSL.

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010

THIS DESIGN COMPLIES WITH:

- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

(55 % OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL. (LL) = L/360 (0.83")
CALCULATED VERT. DEFL. (LL) = L/999 (0.15")
ALLOWABLE DEFL. (TL) = L/360 (0.83")
CALCULATED VERT. DEFL. (TL) = L/999 (0.27")

CS1: TC=0.50/1.00 (6-7:1), BC=0.79/1.00 (10-12:1), WB=0.80/1.00 (4-12:1), SSI=0.42/1.00 (8-9:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.00
COMP=1.00 SHEAR=1.00 TENS=1.00

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 618 354 1667 822 2284 1658

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.

CONTINUED ON PAGE 2



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.



JOB NAME	TRUSS NAME	QUANTITY	PLY	JOB DESC.	DRWG NO.
NE0818-068	G04	1	2	GREENPARK-MINNISLAE HOMES-GRANDBROOKE 1 EL 2	PAGE 10 OF 28

Version 8.210 S Mar 12 2018 MiTek Industries, Inc. Tue Aug 14 13:10:17 2018 Page 2

ID:w_6JogZnfv1q7BUYX2Ki0Uz3oDL-cgQ7JkcWehhgShWsOXt1GOAjFRiulH13tl6K0gynxK4

PLATES (table is in inches)


JT	TYPE	PLATES	W	LEN	Y	X
1	TMVW-t	MT20	5.0	8.0	1.75	4.00
2	TMWW-t	MT20	3.0	4.0	1.50	1.75
3	TMWW-t	MT20	4.0	4.0	1.50	1.00
4	TTW+p	MT20	5.0	8.0	Edge	
5	TMWW-t	MT20	4.0	4.0	1.50	1.00
6	TMWW-t	MT20	3.0	4.0	1.50	1.75
7	TMVW-t	MT20	5.0	8.0	1.75	4.00
8	BMV1-t	MT20	6.0	8.0	Edge	0.50
9	BMWW-t	MT20	6.0	8.0	3.00	3.25
10	BMWW-t	MT20	3.0	6.0	2.50	1.50
11	BS-t	MT20	4.0	6.0		
12	BMWWWW-t	MT20	6.0	8.0		
13	BMWW-t	MT20	3.0	6.0	2.50	1.50
14	BMWW-t	MT20	6.0	8.0	3.00	3.25
15	BMV1-t	MT20	6.0	8.0	5.50	

Edge - INDICATES REFERENCE CORNER OF PLATE
TOUCHES EDGE OF CHORD.

JSI GRIP= 0.89 (14) (INPUT = 0.90)
JSI METAL= 0.87 (1) (INPUT = 1.00)

READ ALL NOTES ON THIS PAGE AND ON
ENGINEERING NOTE PAGE ENP-1. THIS
NOTE PAGE IS AN INTEGRAL PART OF
THIS DRAWING AS IT CONTAINS
SPECIFICATIONS AND CRITERIA USED IN
THE DESIGN OF THIS COMPONENT.





Scale = 1:57.4

TOTAL WEIGHT = 2 X 113 = 227 lb

LUMBER	N. L. G. A. RULES	CHORDS	SIZE	LUMBER	DESCR.
28-1	2x4	DRY	No.2	SPF	
1-7	2x4	DRY	No.2	SPF	
7-10	2x4	DRY	No.2	SPF	
10-14	2x4	DRY	No.2	SPF	
15-14	2x4	DRY	No.2	SPF	
28-19	2x4	DRY	No.2	SPF	
19-15	2x4	DRY	No.2	SPF	
ALL WEBS	2x3	DRY	No.2	SPF	
ALL GABLE WEBS	2x3	DRY	No.2	SPF	
DRY: SEASONED LUMBER.					
GABLE STUDS SPACED AT	2-0-0	OC.			

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
1	TMV+p	MT20	2.0	4.0		
2, 3, 4, 5, 6, 8, 9, 11, 12, 13						
2	TMV+w	MT20	2.0	4.0		
7	TS-I	MT20	3.0	6.0		
10	TTW+p	MT20	3.0	4.0	2.25	1.50
14	TMV+p	MT20	2.0	4.0		
15	BMV1+p	MT20	2.0	4.0		
16, 17, 18, 20, 21, 22, 23, 24, 25, 26, 27						
16	BMV1+w	MT20	2.0	4.0		
19	BS-I	MT20	3.0	6.0		
28	BMV1+p	MT20	2.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS
THIS TRUSS DESIGNED FOR CONTINUOUS BEARINGS.
THIS TRUSS REQUIRES RIGID SHEATHING ON EXPOSED FACE.
BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S)
BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.
ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.
1 - 1x4 LATERAL BRACE(S) AT 1/2 LENGTH OF 10-20, 9-21, 11-18. DBS = 20-0-0. CBF = 20 LBS.

DBS = DIAGONAL BRACE SPACING (MAX). CBF = CUMULATIVE BRACING FORCE (PER BRACE). FASTEN LATERAL BRACE(S) USING (0.122"x3") SPIRAL NAILS: 1 NAIL FOR 2x3 BRACE(S), 2 FOR 1x4, 2x4, 2x5, 3 FOR 2x6, 4 FOR 2x8, 5 FOR 2x10, AND 6 FOR 2x12.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

CHORDS	MAX. FACTORED MEMB. FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX	CS1 (LC)	UNBRAC LENGTH	WEBS	MAX. FACTORED MEMB. FORCE (LBS)	MAX. CS1 (LC)
						FR-TO		
28-1	-26/0	0.0	0.0	0.01 (1)	7.81	20-10	-159/0	0.10 (1)
1-2	-20/0	-77.4	-77.4	0.02 (1)	6.25	21-9	-158/0	0.08 (1)
2-3	-16/0	-77.4	-77.4	0.04 (1)	6.25	22-8	-153/0	0.15 (1)
3-4	-13/0	-77.4	-77.4	0.04 (1)	6.25	23-6	-154/0	0.10 (1)
4-5	-9/0	-77.4	-77.4	0.04 (1)	10.00	24-5	-154/0	0.06 (1)
5-6	-7/0	-77.4	-77.4	0.04 (1)	10.00	25-4	-152/0	0.04 (1)
6-7	-4/0	-77.4	-77.4	0.04 (1)	10.00	26-3	-158/0	0.03 (1)
7-8	-4/0	-77.4	-77.4	0.04 (1)	10.00	27-2	-105/0	0.02 (1)
8-9	-2/0	-77.4	-77.4	0.04 (1)	10.00	18-11	-158/0	0.08 (1)
9-10	0/0	-77.4	-77.4	0.04 (1)	10.00	17-12	-149/0	0.15 (1)
10-11	0/0	-77.4	-77.4	0.04 (1)	10.00	16-13	-173/0	0.11 (1)
11-12	-2/0	-77.4	-77.4	0.04 (1)	10.00			
12-13	-6/0	-77.4	-77.4	0.04 (1)	10.00			
13-14	-3/0	-77.4	-77.4	0.04 (1)	10.00			
15-14	-84/0	0.0	0.0	0.02 (1)	7.81			
28-27	0/22	-17.5	-17.5	0.02 (1)	10.00			
27-26	0/16	-17.5	-17.5	0.02 (4)	10.00			
26-25	0/11	-17.5	-17.5	0.02 (4)	10.00			
25-24	0/8	-17.5	-17.5	0.01 (4)	10.00			
24-23	0/6	-17.5	-17.5	0.01 (4)	10.00			
23-22	0/4	-17.5	-17.5	0.01 (4)	10.00			
22-21	0/2	-17.5	-17.5	0.01 (4)	10.00			
21-20	0/0	-17.5	-17.5	0.01 (4)	10.00			
20-19	0/0	-17.5	-17.5	0.01 (4)	10.00			
19-18	0/0	-17.5	-17.5	0.01 (4)	10.00			
18-17	0/2	-17.5	-17.5	0.01 (4)	10.00			
17-16	0/4	-17.5	-17.5	0.02 (4)	10.00			
16-15	0/6	-17.5	-17.5	0.02 (4)	10.00			

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 23.3 PSF
DL = 3.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.0 PSF
TOTAL LOAD = 33.3 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

(55% OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

CSI: TC=0.04/1.00 (12-13:1), BC=0.02/1.00 (15-16:4), WB=0.15/1.00 (8-22:1), SSI=0.06/1.00 (13-14:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 618 354 1667 822 2284 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.58 (10) (INPUT = 0.90)
JSI METAL= 0.06 (10) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





TOTAL WEIGHT = 2 X 10 = 21 lb [M]

LUMBER				
N. L. G. A. RULES	CHORDS	SIZE	DRY	LUMBER
5 - 2	2x4	DRY	No.2	SPF
1 - 3	2x4	DRY	No.2	SPF
5 - 4	2x4	DRY	No.2	SPF

DRY: SEASONED LUMBER.

PLATES (table is in inches)					
JT	TYPE	PLATES	W	LEN	Y X
2	TMV+p	MT20	2.0	4.0	
5	BMV1+p	MT20	2.0	4.0	

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG	REQRD BRG
	VERT	HORZ	DOWN	HORZ		
5	314	0	314	0	5-8	5-8
3	114	0	114	0	1-8	1-8
4	16	0	18	0	1-8	1-8

SEE MITEK STANDARD DETAIL B37579H FOR CONNECTION TO JOINT(S) 3, 4

UNFACTORED REACTIONS

JT	1ST LCASE	MAX./MIN. COMPONENT REACTIONS		WIND	DEAD	SOIL
		SNOW	LIVE			
5	216	177/0	0/0	0/0	38/0	0/0
3	77	68/0	0/0	0/0	9/0	0/0
4	13	0/0	0/0	0/0	13/0	0/0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 5

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (5)

MEMB.	CHORDS		WEBS	
	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED FORCE (LBS)	MAX. FACTORED FORCE (LBS)
FR-TO		FROM TO		LENGTH FR-TO
5-2	-295/0	0.0 0.0 0.01 (4)	7.81	
1-2	0/27	-77.4 -77.4 0.10 (1)	10.00	
2-3	-19/0	-77.4 -77.4 0.20 (1)	6.25	
5-4	0/0	-17.5 -17.5 0.02 (4)	10.00	

CANTILEVER ANALYSIS HAS BEEN CONSIDERED IN THIS DESIGN

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 23.3 PSF
DL = 3.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.0 PSF
TOTAL LOAD = 33.3 PSF

SPACING = 24.0 IN./C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

DESIGN ASSUMPTIONS
- OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55% OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL)= L/360 (0.19")
CALCULATED VERT. DEFL.(LL) = L/999 (0.00")
ALLOWABLE DEFL.(TL)= L/360 (0.19")
CALCULATED VERT. DEFL.(TL) = L/999 (0.00")

CSI: TC=0.20/1.00 (2-3:1), BC=0.02/1.00 (4-5:4), WB=0.00/1.00 (n/a:0), SSI=0.13/1.00 (2-3:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES					
PLATE	GRIP(DRY)	SHEAR	SECTION		
(PSI)	(PLI)	(PLI)			
MT20	618	354	1667	822	2284 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.


JSI GRIP= 0.18 (2) (INPUT = 0.90)
JSI METAL= 0.07 (2) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.




KOTT



TOTAL WEIGHT = 2 X 12 = 24 lb [M]

LUMBER

N. L. G. A. RULES

CHORDS	SIZE	DRY	LUMBER
5 - 2	2x4	DRY	No.2
1 - 3	2x4	DRY	No.2
5 - 4	2x4	DRY	No.2

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
2	TMV+p	MT20	2.0	4.0		
5	BMV1+p	MT20	2.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION	MAXIMUM FACTORED GROSS REACTION	INPUT BRG	REQD BRG
	VERT	HORZ	DOWN	HORZ
5	259	0	259	0
3	56	0	56	0
4	44	0	49	0

SEE MITEK STANDARD DETAIL B37579H FOR CONNECTION TO JOINT(S) 3, 4

UNFACTORED REACTIONS

JT	1ST LCASE	MAX/MIN. COMPONENT REACTIONS	PERM. LIVE	WIND	DEAD	SOIL
	COMBINED	SNOW	LIVE			
5	183	119 / 0	0 / 0	0 / 0	64 / 0	0 / 0
3	38	34 / 0	0 / 0	0 / 0	4 / 0	0 / 0
4	35	0 / 0	0 / 0	0 / 0	35 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 5, 3

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 10.00 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

MEMB.	CHORDS	WEBS
	MAX. FACTORED FORCE (LBS)	MAX. FACTORED FORCE (LBS)
FR-TO	VERT. LOAD (PLF)	MAX. MEMB. FORCE (LBS)
	FROM TO	LENGTH FR-TO
5-2	-198 / 0	0.0 0.0 0.12 (4) 7.81
1-2	0 / 27	-77.4 -77.4 0.10 (1) 10.00
2-3	-9 / 0	-77.4 -77.4 0.05 (1) 10.00
5-4	0 / 0	-17.5 -17.5 0.13 (4) 10.00

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 23.3 PSF
	DL = 3.0 PSF
BOT CH.	LL = 0.0 PSF
	DL = 7.0 PSF
TOTAL LOAD	= 33.3 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:

- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

DESIGN ASSUMPTIONS

- OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55 % OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.20")
CALCULATED VERT. DEFL.(LL) = L/999 (0.00")
ALLOWABLE DEFL.(TL) = L/360 (0.20")
CALCULATED VERT. DEFL.(TL) = L/999 (0.03")

CSI: TC=0.12/1.00 (2-5:4), BC=0.13/1.00 (4-5:4), WB=0.00/1.00 (n/a:0), SSI=0.08/1.00 (4-5:4)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE	GRIP(DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)	(PLI)
MT20	618	354	1667

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.12 (2) (INPUT = 0.90)
JSI METAL= 0.05 (2) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





Scale = 1:20.8

TOTAL WEIGHT = 2 X 15 = 30 lb [M]

LUMBER

N. L. G. A. RULES	CHORDS	SIZE	DRY	LUMBER	DESCR.
5 - 2	2x4	DRY	No.2	SPF	
1 - 3	2x4	DRY	No.2	SPF	
5 - 4	2x4	DRY	No.2	SPF	

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
2	TMV+p	MT20	2.0	4.0		
5	BMV1+p	MT20	2.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG	REQD BRG
	VERT	HORZ	DOWN	HORZ		
5	356	0	356	0	5-8	5-8
3	114	0	114	0	1-8	1-8
4	44	0	49	0	1-8	1-8

SEE MITEK STANDARD DETAIL B37579H FOR CONNECTION TO JOINT(S) 3, 4

UNFACTORED REACTIONS

JT	COMBINED	1ST LCASE MAX/MIN		LIVE	PERM.LIVE	WIND	DEAD	SOIL
		SNOW	WIND					
5	249	177/0	0/0	0/0	0/0	0/0	72/0	0/0
3	77	68/0	0/0	0/0	0/0	0/0	9/0	0/0
4	35	0/0	0/0	0/0	0/0	0/0	35/0	0/0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 5, 3

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

MEMB.	CHORDS		FACTORED		MAX. UNBRAC	MEMB.	WEBS	
	FORCE (LBS)	VERT. LOAD (PLF)	LC1 MAX (PLF)	CS1 (LC)			FORCE (LBS)	MAX. CS1 (LC)
FR-TO								
5-2	-295/0	0.0	0.0	0.12 (4)	7.81			
1-2	0/27	-77.4	-77.4	0.10 (1)	10.00			
2-3	-19/0	-77.4	-77.4	0.20 (1)	6.25			
5-4	0/0	-17.5	-17.5	0.13 (4)	10.00			

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 23.3 PSF
DL = 3.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.0 PSF
TOTAL LOAD = 33.3 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, CBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

DESIGN ASSUMPTIONS
- OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55% OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $L/360$ (0.20")
CALCULATED VERT. DEFL.(LL) = $L/999$ (0.00")
ALLOWABLE DEFL.(TL) = $L/360$ (0.20")
CALCULATED VERT. DEFL.(TL) = $L/999$ (0.03")

CS1: TC=0.20/1.00 (2-3:1), BC=0.13/1.00 (4-5:4), WB=0.00/1.00 (n/a:0), SS1=0.13/1.00 (2-3:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION
(PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 618 354 1667 822 2284 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.18 (2) (INPUT = 0.90)
JSI METAL= 0.07 (2) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





TOTAL WEIGHT = 10 X 18 = 176 lb [M]

LUMBER

N. L. G. A. RULES	CHORDS	SIZE	DRY	LUMBER	DESCR.
5 - 2	2x4	DRY	No.2	SPF	
1 - 3	2x4	DRY	No.2	SPF	
5 - 4	2x4	DRY	No.2	SPF	

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
2	TMV+p	MT20	2.0	4.0		
5	BMV1+p	MT20	2.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG	REQD BRG
	VERT	HORZ	DOWN	HORZ		
5	457	0	457	0	5-8	5-8
3	174	0	174	0	1-8	1-8
4	44	0	49	0	1-8	1-8

SEE MITEK STANDARD DETAIL B37579H FOR CONNECTION TO JOINT(S) 3, 4

UNFACTORED REACTIONS

JT	1ST LCASE	MAX./MIN. COMPONENT REACTIONS					
	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
5	318	238 / 0	0 / 0	0 / 0	0 / 0	80 / 0	0 / 0
3	118	105 / 0	0 / 0	0 / 0	0 / 0	14 / 0	0 / 0
4	35	0 / 0	0 / 0	0 / 0	0 / 0	35 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 5

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX CSI (LC)	MAX. UNBRACED LENGTH	MEMB.	MAX. FACTORED FORCE (LBS)	MAX CSI (LC)
FR-TO		FROM TO			FR-TO		
5-2	-396 / 0	0.0	0.0	0.12 (4)	7.81		
1-2	0 / 27	-77.4	-77.4	0.10 (1)	10.00		
2-3	-29 / 0	-77.4	-77.4	0.47 (1)	6.25		
5-4	0 / 0	-17.5	-17.5	0.13 (4)	10.00		

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 23.3	PSF
	DL = 3.0	PSF
BOT CH.	LL = 0.0	PSF
	DL = 7.0	PSF
TOTAL LOAD	= 33.3	PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:

- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

DESIGN ASSUMPTIONS

- OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55 % OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.20")
CALCULATED VERT. DEFL.(LL) = L/999 (0.00")
ALLOWABLE DEFL.(TL) = L/360 (0.20")
CALCULATED VERT. DEFL.(TL) = L/999 (0.03")

CSI: TC=0.47/1.00 (2-3:1), BC=0.13/1.00 (4-5:4), WB=0.00/1.00 (n/a:0), SSI=0.20/1.00 (2-3:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE	GRIP(DRY)	SHEAR	SECTION
	(PSI)	(PLI)	(PLI)
MT20	618	354	1667
	618	354	1667

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.24 (2) (INPUT = 0.90)
JSI METAL= 0.09 (2) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





Scale = 1:26.8

TOTAL WEIGHT = 4 X 17 = 70 lb [M]

LUMBER

N. L. G. A. RULES	CHORDS	SIZE	DRY	LUMBER	DESCR.
5 - 2	2x4	DRY	No.2	SPF	
1 - 3	2x4	DRY	No.2	SPF	
5 - 4	2x4	DRY	No.2	SPF	

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
2	TMV+p	MT20	2.0	4.0		
5	BMV1+p	MT20	2.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG	REQD BRG
	VERT	HORZ	DOWN	HORZ		
5	465	0	465	0	MECHANICAL	
3	161	0	161	0	1-8	1-8
4	41	0	46	0	1-8	1-8

A SUITABLE MECHANICAL CONNECTION IS REQUIRED AT JOINT 5 TO RESIST THE MAX FACTORED REACTIONS.

SEE MITEK STANDARD DETAIL B37579H FOR CONNECTION TO JOINT(S) 3, 4

UNFACTORED REACTIONS

JT	1ST LCASE	MAX/MIN COMPONENT REACTIONS					SOIL
	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	
5	323	246 / 0	0 / 0	0 / 0	0 / 0	76 / 0	0 / 0
3	109	97 / 0	0 / 0	0 / 0	0 / 0	12 / 0	0 / 0
4	33	0 / 0	0 / 0	0 / 0	0 / 0	33 / 0	0 / 0

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS					WEBS				
MEMB.	MAX. FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LOAD LC1	MAX CSI (LC)	MAX. UNBRAC LENGTH	MEMB.	MAX. FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX CSI (LC)
FR-TO		FROM	TO			FR-TO			
5-2	-409 / 0	0.0	0.0	0.09 (4)	7.81				
1-2	0 / 36	-77.4	-77.4	0.18 (1)	10.00				
2-3	-27 / 0	-77.4	-77.4	0.40 (1)	6.25				
5-4	0 / 0	-17.5	-17.5	0.11 (4)	10.00				

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 23.3	PSF
	DL = 3.0	PSF
BOT CH.	LL = 0.0	PSF
	DL = 7.0	PSF
TOTAL LOAD	= 33.3	PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:

- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

DESIGN ASSUMPTIONS

- OVERHANG NOT TO BE ALTERED OR CUT OFF.

(55% OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL)= L/360 (0.19")
CALCULATED VERT. DEFL.(LL) = L/999 (0.00")
ALLOWABLE DEFL.(TL)= L/360 (0.19")
CALCULATED VERT. DEFL.(TL) = L/999 (0.03")

CSI: TC=0.40/1.00 (2-3:1), BC=0.11/1.00 (4-5:4), WB=0.00/1.00 (n/a:0), SSI=0.18/1.00 (2-3:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS= 1.10

COMPANION LIVE LOAD FACTOR = 0.50

AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE	GRIP(DRY)	SHEAR (PSI)	SECTION (PLI)
MT20	618	354	1667
	822	2284	1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.25 (2) (INPUT = 0.90)
JSI METAL= 0.10 (2) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





TOTAL WEIGHT = 106 lb [M/JF]

LUMBER

N. L. G. A. RULES

CHORDS	SIZE	LUMBER	DESCR.
1 - 4	2x4	DRY No.2	SPF
4 - 6	2x4	DRY No.2	SPF
6 - 9	2x4	DRY No.2	SPF
15 - 2	2x4	DRY No.2	SPF
10 - 8	2x4	DRY No.2	SPF
15 - 12	2x4	DRY No.2	SPF
12 - 10	2x4	DRY No.2	SPF
ALL WEBS EXCEPT	2x3	DRY No.2	SPF

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
2	TMV+p	MT20	2.0	4.0		
3	TMWW-I	MT20	4.0	4.0	1.50	2.00
4	TTWW-m	MT20	4.0	6.0	1.75	2.25
5	TMW+w	MT20	2.0	4.0		
6	TTWW-m	MT20	4.0	6.0	1.75	2.25
7	TMWW-I	MT20	4.0	4.0	1.50	2.00
8	TMV+p	MT20	2.0	4.0		
10	BMVW1-I	MT20	4.0	5.0	2.00	2.00
11	BMWW-I	MT20	3.0	4.0		
12	BS-I	MT20	3.0	6.0		
13	BMWW-I	MT20	3.0	6.0		
14	BMWW-I	MT20	3.0	4.0		
15	BMVW1-I	MT20	4.0	5.0	2.00	2.00

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG	REQRD BRG
	VERT	HORZ	DOWN	HORZ		
15	1291	0	1291	0	5-8	5-8
10	1291	0	1291	0	5-8	5-8

UNFACTORED REACTIONS

	1ST LCASE	MAX./MIN. COMPONENT REACTIONS					
JT	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL
15	904	646 / 0	0 / 0	0 / 0	0 / 0	258 / 0	0 / 0
10	904	646 / 0	0 / 0	0 / 0	0 / 0	258 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 15, 10

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 5.38 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

MEMB.	CHORDS			WEBS		
	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. FACTORED VERT. LOAD (LC1) (LC)	MAX. MEMB. UNBRACED LENGTH (FR-TO)	MAX. FACTORED FORCE (LBS)	MAX. FACTORED VERT. LOAD (LC1) (LC)
1-2	0 / 27	-77.4	-77.4 0.10 (1)	10.00	3-14	-78 / 37
2-3	0 / 17	-77.4	-77.4 0.19 (1)	10.00	14-4	0 / 197
3-4	-1358 / 0	-77.4	-77.4 0.17 (1)	5.41	4-13	0 / 285
4-5	-1339 / 0	-77.4	-77.4 0.22 (1)	5.38	13-5	-423 / 0
5-6	-1339 / 0	-77.4	-77.4 0.22 (1)	5.38	13-6	0 / 285
6-7	-1358 / 0	-77.4	-77.4 0.17 (1)	5.41	11-6	0 / 197
7-8	0 / 17	-77.4	-77.4 0.19 (1)	10.00	11-7	-78 / 37
8-9	0 / 27	-77.4	-77.4 0.10 (1)	10.00	15-3	-1580 / 0
15-2	-227 / 0	0.0	0.0 0.02 (1)	7.81	7-10	-1580 / 0
10-8	-227 / 0	0.0	0.0 0.02 (1)	7.81		
15-14	0 / 1218	-17.5	-17.5 0.33 (1)	10.00		
14-13	0 / 1161	-17.5	-17.5 0.34 (4)	10.00		
13-12	0 / 1161	-17.5	-17.5 0.34 (4)	10.00		
12-11	0 / 1161	-17.5	-17.5 0.34 (4)	10.00		
11-10	0 / 1218	-17.5	-17.5 0.33 (1)	10.00		

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL = 23.3	PSF
	DL = 3.0	PSF
BOT CH.	LL = 0.0	PSF
	DL = 7.0	PSF
TOTAL LOAD	= 33.3	PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 2.00/12 MINIMUM

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

(55% OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.83")
CALCULATED VERT. DEFL.(LL) = L/999 (0.05")
ALLOWABLE DEFL.(TL) = L/360 (0.83")
CALCULATED VERT. DEFL.(TL) = L/999 (0.15")

CSI: TC=0.22/1.00 (4-5:1), BC=0.34/1.00 (11-13:4), WB=0.69/1.00 (7-10:1), SSI=0.17/1.00 (4-5:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS= 1.10

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES

PLATE	GRIP(DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)	
MAX MIN	MAX MIN	MAX MIN	
MT20	618	354	1667 822 2284 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.87 (13) (INPUT = 0.90)
JSI METAL= 0.57 (3) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





TOTAL WEIGHT = 107 lb
[M][F]

LUMBER				
N. L. G. A. RULES				
CHORDS	SIZE	LUMBER	DESCR.	
1 - 4	2x4	DRY	No.2	SPF
4 - 5	2x4	DRY	No.2	SPF
5 - 8	2x4	DRY	No.2	SPF
15 - 2	2x4	DRY	No.2	SPF
9 - 7	2x4	DRY	No.2	SPF
15 - 11	2x4	DRY	No.2	SPF
11 - 9	2x4	DRY	No.2	SPF

ALL WEBS 2x3 DRY No.2 SPF
EXCEPT
DRY: SEASONED LUMBER.

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

		FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT		REQD	
JT		VERT	HORZ	DOWN	HORZ	UPLIFT	IN-SX	IN-SX	BRG
15		1291	0	1291	0	0	5-8	5-8	
9		1291	0	1291	0	0	5-8	5-8	

UNFACTORED REACTIONS

		1ST LCASE		MAX/MIN. COMPONENT REACTIONS					
JT		COMBINED	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL	
15		904	646 / 0	0 / 0	0 / 0	0 / 0	258 / 0	0 / 0	
9		904	646 / 0	0 / 0	0 / 0	0 / 0	258 / 0	0 / 0	

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 15, 9

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 5.13 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX LC1	MEMB.	FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX LC1
FR-TO		FROM TO		FR-TO		FROM TO	
1-2	0 / 27	-77.4	-77.4 0.10 (1)	10-00	14-3	-150 / 39	0.04 (1)
2-3	-1466 / 0	-77.4	-77.4 0.27 (1)	5-13	3-13	-307 / 0	0.22 (1)
3-4	-1234 / 0	-77.4	-77.4 0.26 (1)	5-49	13-4	0 / 275	0.06 (1)
4-5	-1049 / 0	-77.4	-77.4 0.26 (1)	5-83	4-12	0 / 0	0.00 (1)
5-6	-1235 / 0	-77.4	-77.4 0.26 (1)	5-49	12-5	0 / 276	0.06 (1)
6-7	-1466 / 0	-77.4	-77.4 0.27 (1)	5-13	12-6	-306 / 0	0.22 (1)
7-8	0 / 27	-77.4	-77.4 0.10 (1)	10-00	10-6	-151 / 39	0.04 (1)
15-2	-1253 / 0	0.0	0.0 0.13 (1)	7-18	2-14	0 / 1309	0.29 (1)
9-7	-1253 / 0	0.0	0.0 0.13 (1)	7-19	10-7	0 / 1308	0.29 (1)
15-14	0 / 0	-17.5	-17.5 0.10 (4)	10-00			
14-13	0 / 1285	-17.5	-17.5 0.25 (1)	10-00			
13-12	0 / 1049	-17.5	-17.5 0.22 (1)	10-00			
12-11	0 / 1285	-17.5	-17.5 0.25 (1)	10-00			
11-10	0 / 1285	-17.5	-17.5 0.25 (1)	10-00			
10-9	0 / 0	-17.5	-17.5 0.10 (4)	10-00			

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH. LL = 23.3 PSF
DL = 3.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.0 PSF
TOTAL LOAD = 33.3 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 2.00/12 MINIMUM

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

(55 % OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL)= L/360 (0.83")
CALCULATED VERT. DEFL.(LL) = L/999 (0.05")
ALLOWABLE DEFL.(TL)= L/360 (0.83")
CALCULATED VERT. DEFL.(TL) = L/999 (0.09")

CSI: TC=0.27/1.00 (2-3:1), BC=0.25/1.00 (10-12:1), WB=0.29/1.00 (2-14:1), SSI=0.16/1.00 (6-7:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES					
PLATE	GRIP (DRY)	SHEAR (PSI)	SECTION (PLI)	MAX MIN	MAX MIN
MT20	618	354	1667	822	2284 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.89 (14) (INPUT = 0.90)
JSI METAL= 0.48 (14) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





LUMBER			
N. L. G. A. RULES			
CHORDS	SIZE	LUMBER	DESCR.
1 - 4	2x4	DRY	No.2
4 - 5	2x4	DRY	No.2
5 - 8	2x4	DRY	No.2
15 - 2	2x4	DRY	No.2
9 - 7	2x4	DRY	No.2
15 - 11	2x4	DRY	No.2
11 - 9	2x4	DRY	No.2

ALL WEBS 2x3 DRY No.2
EXCEPT
SPF

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
2	TMVW-t	MT20	4.0	6.0	2.00	3.00
3	TMWW-t	MT20	3.0	4.0	1.50	1.75
4	TTWW+m	MT20	5.0	5.0	2.50	1.25
5	TTW+m	MT20	3.0	4.0	2.00	1.25
6	TMWW-t	MT20	3.0	4.0	1.50	1.75
7	TMVW-t	MT20	4.0	6.0	2.00	3.00
9	BMV1+p	MT20	2.0	4.0		
10	BMWW-t	MT20	4.0	4.0	1.75	1.50
11	BS-t	MT20	3.0	6.0		
12	BMWWW-t	MT20	3.0	8.0		
13	BMWW-t	MT20	3.0	4.0		
14	BMWW-t	MT20	4.0	4.0	1.75	1.50
15	BMV1+p	MT20	2.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS		FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG		REQRD BRG	
JT	VERT	HORZ	DOWN	HORZ	UPLIFT	IN-SX	IN-SX	IN-SX	IN-SX
15	1291	0	1291	0	0	5-8	5-8		
9	1291	0	1291	0	0	5-8	5-8		

UNFACTORED REACTIONS

JT	1ST LCASE	MAX./MIN.	COMPONENT REACTIONS	DEAD	SOIL
15	904	646 / 0	0 / 0	258 / 0	0 / 0
9	904	646 / 0	0 / 0	258 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 15, 9

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 4.95 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	FORCE (LBS)	FACTORED VERT. LOAD (PLF)	FACTORED LC1 MAX (LC)	MEMB.	FORCE (LBS)	FACTORED VERT. LOAD (PLF)	FACTORED LC1 MAX (LC)
FR-TO		FROM	TO	FR-TO		FROM	TO
1-2	0 / 27	-77.4	-77.4 0.10 (1)	10-0	14-3	-85 / 77	0.03 (1)
2-3	-1470 / 0	-77.4	-77.4 0.41 (1)	4.95	3-13	-461 / 0	0.52 (1)
3-4	-1102 / 0	-77.4	-77.4 0.38 (1)	5.56	13-4	0 / 297	0.07 (1)
4-5	-934 / 0	-77.4	-77.4 0.02 (1)	6.25	4-12	0 / 35	0.01 (1)
5-6	-1106 / 0	-77.4	-77.4 0.38 (1)	5.55	12-5	0 / 334	0.08 (1)
6-7	-1469 / 0	-77.4	-77.4 0.41 (1)	4.96	12-6	-455 / 0	0.51 (1)
7-8	0 / 27	-77.4	-77.4 0.10 (1)	10.00	10-6	-92 / 74	0.03 (1)
15-2	-1248 / 0	0.0	0.0 0.13 (1)	7.19	2-14	0 / 1310	0.29 (1)
9-7	-1247 / 0	0.0	0.0 0.13 (1)	7.19	10-7	0 / 1309	0.29 (1)
15-14	0 / 0	-17.5	-17.5 0.16 (4)	10.00			
14-13	0 / 1294	-17.5	-17.5 0.29 (1)	10.00			
13-12	0 / 930	-17.5	-17.5 0.22 (1)	10.00			
12-11	0 / 1292	-17.5	-17.5 0.28 (1)	10.00			
11-10	0 / 1292	-17.5	-17.5 0.28 (1)	10.00			
10-9	0 / 0	-17.5	-17.5 0.15 (4)	10.00			

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 23.3 PSF
DL = 3.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.0 PSF
TOTAL LOAD = 33.3 PSF

SPACING = 24.0 IN. C/C

LOADING IN FLAT SECTION BASED ON A SLOPE OF 2.00/12 MINIMUM

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

(55% OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL)= L/360 (0.83")
CALCULATED VERT. DEFL.(LL) = L/999 (0.05")
ALLOWABLE DEFL.(TL)= L/360 (0.83")
CALCULATED VERT. DEFL.(TL) = L/999 (0.10")

CSI: TC=0.41/1.00 (2-3:1), BC=0.29/1.00 (13-14:1), WB=0.52/1.00 (3-13:1), SSI=0.20/1.00 (2-3:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 618 354 1667 822 2284 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.87 (14) (INPUT = 0.90)
JSI METAL= 0.48 (14) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





LUMBER				
N. L. G. A. RULES				
CHORDS	SIZE	LUMBER	DESCR.	
1 - 4	2x4	DRY	No.2	SPF
4 - 5	2x4	DRY	No.2	SPF
5 - 6	2x4	DRY	No.2	SPF
6 - 9	2x4	DRY	No.2	SPF
15 - 2	2x4	DRY	No.2	SPF
10 - 8	2x4	DRY	No.2	SPF
15 - 12	2x4	DRY	No.2	SPF
12 - 10	2x4	DRY	No.2	SPF
ALL WEBS EXCEPT	2x3	DRY	No.2	SPF

DRY: SEASONED LUMBER.

PLATES (table is in inches)				
JT	TYPE	PLATES	W	LEN Y X
2	TMVW-I	MT20	4.0	6.0 2.00 3.00
3	TMVW-I	MT20	3.0	4.0 1.50 1.75
4	TS-I	MT20	3.0	6.0
5	TTW+p	MT20	3.0	4.0 2.25 1.50
6	TS-I	MT20	3.0	6.0
7	TMVW-I	MT20	3.0	4.0 1.50 1.75
8	TMVW-I	MT20	4.0	6.0 2.00 3.00
10	BMV1+p	MT20	2.0	4.0
11	BMVW-I	MT20	4.0	4.0 1.75 1.50
12	BS-I	MT20	3.0	6.0
13	BMVW-I	MT20	4.0	6.0
14	BMVW-I	MT20	4.0	4.0 1.75 1.50
15	BMV1+p	MT20	2.0	4.0

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS		FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT		REQRD	
JT		VERT	HORZ	DOWN	HORZ	UPLIFT	IN-SX	BRG	IN-SX
15		1291	0	1291	0	0	5-8	5-8	
10		1291	0	1291	0	0	5-8	5-8	

UNFACTORED REACTIONS		1ST LCASE		MAX./MIN. COMPONENT REACTIONS					
JT		COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL	
15		904	646 / 0	0 / 0	0 / 0	0 / 0	258 / 0	0 / 0	
10		904	646 / 0	0 / 0	0 / 0	0 / 0	258 / 0	0 / 0	

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 15, 10

BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 4.91 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING
TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	LC1 MAX CSI (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. UNBRACED LENGTH FR-TO	MAX. FACTORED FORCE (LBS)
1-2	0 / 27	-77.4	-77.4 0.10 (1)	10-00	13-5	0 / 696	0.16 (1)
2-3	-1466 / 0	-77.4	-77.4 0.44 (1)	4.91	13-7	-489 / 0	0.59 (1)
3-4	-1075 / 0	-77.4	-77.4 0.41 (1)	5.56	11-7	-77 / 81	0.03 (1)
4-5	-1075 / 0	-77.4	-77.4 0.41 (1)	5.56	3-13	-489 / 0	0.59 (1)
5-6	-1075 / 0	-77.4	-77.4 0.41 (1)	5.56	14-3	-77 / 81	0.03 (1)
6-7	-1075 / 0	-77.4	-77.4 0.41 (1)	5.56	2-14	0 / 1307	0.29 (1)
7-8	-1466 / 0	-77.4	-77.4 0.44 (1)	4.91	11-8	0 / 1307	0.29 (1)
8-9	0 / 27	-77.4	-77.4 0.10 (1)	10.00			
15-2	-1245 / 0	0.0	0.0 0.13 (1)	7.20			
10-8	-1245 / 0	0.0	0.0 0.13 (1)	7.20			
15-14	0 / 0	-17.5	-17.5 0.16 (4)	10.00			
14-13	0 / 1292	-17.5	-17.5 0.29 (1)	10.00			
13-12	0 / 1292	-17.5	-17.5 0.29 (1)	10.00			
12-11	0 / 1292	-17.5	-17.5 0.29 (1)	10.00			
11-10	0 / 0	-17.5	-17.5 0.16 (4)	10.00			

DESIGN CRITERIA

SPECIFIED LOADS:			
TOP CH.	LL	=	23.3 PSF
	DL	=	3.0 PSF
BOT CH.	LL	=	0.0 PSF
	DL	=	7.0 PSF
TOTAL LOAD		=	33.3 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

(55% OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL)= L/360 (0.83")
CALCULATED VERT. DEFL.(LL)= L/999 (0.05")
ALLOWABLE DEFL.(TL)= L/360 (0.83")
CALCULATED VERT. DEFL.(TL)= L/999 (0.10")

CSI: TC=0.44/1.00 (7-8:1), BC=0.29/1.00 (11-13:1), WB=0.59/1.00 (7-13:1), SSI=0.20/1.00 (7-8:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS= 1.10

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES			
PLATE	GRIP(DRY)	SHEAR	SECTION
(PSI)	(PLI)	(PLI)	(PLI)
MT20	618	354	1667
	822	2284	1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.88 (5) (INPUT = 0.90)
JSI METAL= 0.48 (14) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





TOTAL WEIGHT = 12 X 110 = 1326 LB
(M) [F]

LUMBER

N. L. G. A. RULES	CHORDS	SIZE	DRY	LUMBER	DESCR.
1 - 3	2x4	DRY	No.2	SPF	
3 - 5	2x4	DRY	No.2	SPF	
5 - 7	2x4	DRY	No.2	SPF	
14 - 1	2x4	DRY	No.2	SPF	
8 - 7	2x4	DRY	No.2	SPF	
14 - 10	2x4	DRY	No.2	SPF	
10 - 8	2x4	DRY	No.2	SPF	
ALL WEBS EXCEPT	2x3	DRY	No.2	SPF	

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
1	TMVW-I	MT20	4.0	5.0	1.50	2.00
2	TMVW-I	MT20	3.0	4.0	1.50	1.75
3	TS-I	MT20	3.0	6.0		
4	TMVW-I	MT20	3.0	4.0	1.50	1.75
5	TTW+p	MT20	3.0	4.0	2.25	1.50
6	TMVW-I	MT20	3.0	4.0	2.00	0.75
7	TMVW+p	MT20	4.0	4.0	1.25	2.00
8	BMV1+p	MT20	2.0	4.0		
9	BMVW-I	MT20	3.0	5.0	2.00	1.50
10	BS-I	MT20	3.0	6.0		
11	BMVW-I	MT20	3.0	6.0		
12	BMVW-I	MT20	3.0	4.0		
13	BMVW-I	MT20	4.0	4.0	1.75	1.50
14	BMV1+p	MT20	2.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS	FACTORED	MAXIMUM FACTORED	INPUT	REQD
	GROSS REACTION	GROSS REACTION	BRG	BRG
JT	VERT	HORZ	DOWN	HORZ
14	1092	0	1092	0
8	1092	0	1092	0

A SUITABLE MECHANICAL CONNECTION IS REQUIRED AT JOINT 14, 8 TO RESIST THE MAX FACTORED REACTIONS.

UNFACTORED REACTIONS

JT	1ST LCASE	MAX/MIN	COMPONENT REACTIONS					
	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL	
14	767	536 / 0	0 / 0	0 / 0	0 / 0	230 / 0	0 / 0	
8	767	536 / 0	0 / 0	0 / 0	0 / 0	230 / 0	0 / 0	

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 5.33 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

1 - 1x4 LATERAL BRACE(S) AT 1/2 LENGTH OF 4-11. DBS = 20-0-0. CBF = 72 LBS.

DBS = DIAGONAL BRACE SPACING (MAX). CBF = CUMULATIVE BRACING FORCE (PER BRACE). FASTEN LATERAL BRACE(S) USING (0.122"x3") SPIRAL NAILS: 1 NAIL FOR 2x3 BRACE(S), 2 FOR 1x4, 2x4, 2x5, 3 FOR 2x6, 4 FOR 2x8, 5 FOR 2x10, AND 6 FOR 2x12.

END VERTICAL(S) MUST BE SHEATHED OR HAVE BRACES AS INDICATED IN THE MAX. UNBRACED LENGTH COLUMN OF THE TABLE BELOW

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX. CSI (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. CSI (LC)	
FR-TO		FROM TO		FR-TO			
1-2	-1343 / 0	-77.4	-77.4 0.25 (1)	5-33	-116 / 46	0.03 (1)	
2-3	-1107 / 0	-77.4	-77.4 0.21 (1)	5-79	-281 / 0	0.19 (1)	
3-4	-1107 / 0	-77.4	-77.4 0.21 (1)	5-79	0 / 259	0.06 (1)	
4-5	-731 / 0	-77.4	-77.4 0.21 (1)	6-25	-579 / 0	0.27 (1)	
5-6	-732 / 0	-77.4	-77.4 0.17 (1)	6-25	0 / 448	0.10 (1)	
6-7	-630 / 0	-77.4	-77.4 0.17 (1)	6-25	0 / 112	0.03 (1)	
14-1	-1055 / 0	0.0	0.0 0.11 (1)	7-66	-527 / 0	0.52 (1)	
8-7	-1062 / 0	0.0	0.0 0.46 (1)	7-64	0 / 1194	0.27 (1)	
				9-7	0 / 826	0.19 (1)	
14-13	0 / 0	-17.5	-17.5 0.10 (4)	10-00			
13-12	0 / 1175	-17.5	-17.5 0.23 (1)	10-00			
12-11	0 / 956	-17.5	-17.5 0.19 (1)	10-00			
11-10	0 / 560	-17.5	-17.5 0.13 (1)	10-00			
10-9	0 / 560	-17.5	-17.5 0.13 (1)	10-00			
9-8	0 / 0	-17.5	-17.5 0.07 (4)	10-00			

DESIGN CRITERIA

SPECIFIED LOADS:

TOP CH.	LL	=	23.3	PSF
	DL	=	3.0	PSF
BOT CH.	LL	=	0.0	PSF
	DL	=	7.0	PSF
TOTAL LOAD	=	33.3	PSF	

SPACING = 24.0 IN./C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

(55 % OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = $L/360$ (0.77")
CALCULATED VERT. DEFL.(LL) = $L/999$ (0.04")
ALLOWABLE DEFL.(TL) = $L/360$ (0.77")
CALCULATED VERT. DEFL.(TL) = $L/999$ (0.07")

CSI: TC=0.46/1.00 (7-8:1), BC=0.23/1.00 (12-13:1), WB=0.52/1.00 (6-9:1), SSI=0.16/1.00 (1-2:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION
(PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 618 354 1667 822 2284 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.88 (1) (INPUT = 0.90)
JSI METAL= 0.44 (13) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





TOTAL WEIGHT = 74 lb

LUMBER				N. L. G. A. RULES			
CHORDS	SIZE	DRY	LUMBER	DESCR.	SPF	FACTORED	MAXIMUM FACTORED
1 - 4	2x4	DRY	No.2	SPF	SPF	FACTORED	MAXIMUM FACTORED
4 - 6	2x4	DRY	No.2	SPF	SPF	FACTORED	MAXIMUM FACTORED
13 - 2	2x4	DRY	No.2	SPF	SPF	FACTORED	MAXIMUM FACTORED
7 - 6	2x4	DRY	No.2	SPF	SPF	FACTORED	MAXIMUM FACTORED
13 - 12	2x4	DRY	No.2	SPF	SPF	FACTORED	MAXIMUM FACTORED
12 - 3	2x3	DRY	No.2	SPF	SPF	FACTORED	MAXIMUM FACTORED
11 - 9	2x4	DRY	No.2	SPF	SPF	FACTORED	MAXIMUM FACTORED
8 - 5	2x3	DRY	No.2	SPF	SPF	FACTORED	MAXIMUM FACTORED
8 - 7	2x4	DRY	No.2	SPF	SPF	FACTORED	MAXIMUM FACTORED
ALL WEBS EXCEPT	2x3	DRY	No.2	SPF	SPF	FACTORED	MAXIMUM FACTORED
ALL GABLE WEBS	2x3	DRY	No.2	SPF	SPF	FACTORED	MAXIMUM FACTORED
DRY: SEASONED LUMBER.							
GABLE STUDS SPACED AT 2-0-0 OC.							

PLATES (table is in inches)							
JT	TYPE	PLATES	W	LEN	Y	X	
2	TMVW-I	MT20	3.0	5.0	1.50	1.75	
3	TMVW-I	MT20	3.0	4.0	1.50	1.25	
4	TTW+p	MT20	3.0	5.0			
5	TMVW-I	MT20	3.0	4.0	1.50	1.25	
6	TMVW-I	MT20	3.0	5.0	1.50	1.75	
7	BMVW1-I	MT20	3.0	4.0			
8	BMV+p	MT20	2.0	4.0			
9	BMVWVW-I	MT20	5.0	6.0	3.00	4.00	
10	BMVWVW-I	MT20	3.0	6.0			
11	BMVWVW-I	MT20	5.0	6.0	3.00	4.00	
12	BMV+p	MT20	2.0	4.0			
13	BMVW1-I	MT20	3.0	4.0			
14	NP-p	MT20	2.0	4.0	1.00	2.00	
14, 15, 16, 17, 18, 19, 20, 21, 22, 23							
14	NP+w	MT20	2.0	4.0			
21	NP-p	MT20	2.0	4.0	1.00	2.00	

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

JT	FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG IN-SX	REQRD BRG IN-SX
	VERT	HORZ	DOWN	HORZ		
13	755	0	755	0	5-8	5-8
7	648	0	648	0	5-8	5-8

JT	UNFACTORED REACTIONS		MAX/MIN. COMPONENT REACTIONS		WIND	DEAD	SOIL
	1ST LCASE	MAX/MIN.	LIVE	PERM.LIVE			
13	528	383 / 0	0 / 0	0 / 0	0 / 0	145 / 0	0 / 0
7	455	318 / 0	0 / 0	0 / 0	0 / 0	137 / 0	0 / 0

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 13, 7

BRACING
TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 7.81 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	FACTORED LC1 MAX (LC)	MEMB.	MAX. FACTORED FORCE (LBS)	MAX. FACTORED FORCE (LC)	
FR-TO				FR-TO			
1-2	0 / 34	-77.4	-77.4 0.11 (1)	10-4	0 / 363	0.08 (1)	
2-3	-743 / 0	-77.4	-77.4 0.13 (1)	10-5	-259 / 0	0.10 (1)	
3-4	-506 / 0	-77.4	-77.4 0.15 (1)	10-6	-259 / 0	0.10 (1)	
4-5	-506 / 0	-77.4	-77.4 0.15 (1)	10-7	0 / 595	0.13 (1)	
5-6	-743 / 0	-77.4	-77.4 0.13 (1)	10-8	0 / 595	0.13 (1)	
13-2	-729 / 0	0.0	0.0 0.08 (1)	13-11	-6 / 0	0.00 (1)	
7-6	-622 / 0	0.0	0.0 0.07 (1)	9-7	-6 / 0	0.00 (1)	
13-12	0 / 5	-17.5	-17.5 0.04 (4)	10-10			
12-11	0 / 27	0.0	0.0 0.02 (1)	10-11			
11-3	-16 / 38	0.0	0.0 0.02 (4)	7-8			
11-10	0 / 594	-17.5	-17.5 0.14 (1)	10-12			
10-9	0 / 594	-17.5	-17.5 0.14 (1)	10-13			
8-9	0 / 27	0.0	0.0 0.02 (1)	10-14			
9-5	-16 / 38	0.0	0.0 0.02 (4)	7-9			
8-7	0 / 5	-17.5	-17.5 0.04 (4)	10-15			

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 23.3 PSF
DL = 3.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.0 PSF
TOTAL LOAD = 33.3 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

(55 % OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL)= L/360 (0.46")
CALCULATED VERT. DEFL.(LL)= L/999 (0.01")
ALLOWABLE DEFL.(TL)= L/360 (0.46")
CALCULATED VERT. DEFL.(TL)= L/999 (0.03")

CSI: TC=0.15/1.00 (4-5:1), BC=0.14/1.00 (9-10:1), WB=0.13/1.00 (6-9:1), SSI=0.11/1.00 (4-5:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 0.50

AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION
(PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 618 354 1667 822 2284 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.87 (6) (INPUT = 0.90)
JSI METAL= 0.26 (2) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





TOTAL WEIGHT = 63 lb [M/F]

LUMBER			
N. L. G. A. RULES			
CHORDS	SIZE	LUMBER	DESCR.
1 - 3	2x4	DRY No.2	SPF
3 - 5	2x4	DRY No.2	SPF
12 - 1	2x4	DRY No.2	SPF
6 - 5	2x4	DRY No.2	SPF
12 - 11	2x4	DRY No.2	SPF
11 - 2	2x3	DRY No.2	SPF
10 - 8	2x4	DRY No.2	SPF
7 - 4	2x3	DRY No.2	SPF
7 - 6	2x4	DRY No.2	SPF
ALL WEBS EXCEPT	2x3	DRY No.2	SPF

DRY: SEASONED LUMBER.

PLATES (table is in inches)

JT	TYPE	PLATES	W	LEN	Y	X
1	TMVW-I	MT20	3.0	5.0	1.50	1.75
2	TMVW-I	MT20	3.0	4.0	1.50	1.25
3	TTW+p	MT20	3.0	4.0	2.50	1.50
4	TMVW-I	MT20	3.0	4.0	1.50	1.25
5	TMVW-I	MT20	3.0	5.0	1.50	1.75
6	BMVW-I	MT20	3.0	4.0		
7	BMV+p	MT20	2.0	4.0		
8	BVMWW-I	MT20	5.0	6.0	3.00	4.00
9	BMVWW-I	MT20	3.0	6.0		
10	BVMWW-I	MT20	5.0	6.0	3.00	4.00
11	BMV+p	MT20	2.0	4.0		
12	BMVW-I	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS		FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG		REQRD BRG	
JT		VERT	HORZ	DOWN	HORZ	IN-SX	IN-SX	IN-SX	IN-SX
12	626	0	626	0	0	5-8	5-8		
6	626	0	626	0	0	MECHANICAL			

A SUITABLE MECHANICAL CONNECTION IS REQUIRED AT JOINT 6 TO RESIST THE MAX FACTORED REACTIONS.

UNFACTORED REACTIONS

JT	1ST CASE	MAX/MIN	COMPONENT REACTIONS					
	COMBINED	SNOW	LIVE	PERM.LIVE	WIND	DEAD	SOIL	
12	440	308 / 0	0 / 0	0 / 0	0 / 0	132 / 0	0 / 0	
6	440	308 / 0	0 / 0	0 / 0	0 / 0	132 / 0	0 / 0	

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 12

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 7.81 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX LC1 (LC)	MEMB.	FORCE (LBS)	FACTORED MAX. UNBRACED LENGTH	MAX. FACTORED CSI (LC)
FR-TO		FROM	TO	FR-TO			
1-2	-713 / 0	-77.4	-77.4 0.13 (1)	6.25	2-9	-261 / 0	0.10 (1)
2-3	-474 / 0	-77.4	-77.4 0.15 (1)	6.25	9-3	0 / 322	0.07 (1)
3-4	-473 / 0	-77.4	-77.4 0.15 (1)	6.25	9-4	-178 / 0	0.07 (1)
4-5	-618 / 0	-77.4	-77.4 0.12 (1)	6.25	1-10	0 / 573	0.13 (1)
12-1	-601 / 0	0.0	0.0 0.06 (1)	7.81	8-5	0 / 521	0.12 (1)
6-5	-605 / 0	0.0	0.0 0.07 (1)	7.81	12-10	-5 / 0	0.00 (1)
					8-6	-5 / 0	0.00 (1)
12-11	0 / 5	-17.5	-17.5 0.04 (4)	10.00			
11-10	0 / 27	0.0	0.0 0.02 (1)	10.00			
10-2	-14 / 39	0.0	0.0 0.02 (4)	7.81			
10-9	0 / 571	-17.5	-17.5 0.14 (1)	10.00			
9-8	0 / 501	-17.5	-17.5 0.13 (1)	10.00			
7-8	0 / 22	0.0	0.0 0.02 (1)	10.00			
8-4	-105 / 10	0.0	0.0 0.01 (1)	7.81			
7-6	0 / 4	-17.5	-17.5 0.03 (4)	10.00			

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 23.3 PSF
DL = 3.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.0 PSF
TOTAL LOAD = 33.3 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

(55% OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL) = L/360 (0.44")
CALCULATED VERT. DEFL.(LL) = L/999 (0.01")
ALLOWABLE DEFL.(TL) = L/360 (0.44")
CALCULATED VERT. DEFL.(TL) = L/999 (0.02")

CSI: TC=0.15/1.00 (3-4:1), BC=0.14/1.00 (9-10:1), WB=0.13/1.00 (1-10:1), SSI=0.11/1.00 (2-3:1)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10 COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 0.50

AUTOSOLVE HEELS OFF

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES
PLATE GRIP(DRY) SHEAR SECTION (PSI) (PLI) (PLI)
MAX MIN MAX MIN MAX MIN
MT20 618 354 1667 822 2284 1656

PLATE PLACEMENT TOL. = 0.250 inches

PLATE ROTATION TOL. = 5.0 Deg.


JSI GRIP= 0.86 (3) (INPUT = 0.90)
JSI METAL= 0.23 (1) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.



Version 8.210 S Mar 12 2018 MiTek Industries, Inc. Tue Aug 14 13:10:26 2018 Page 1
ID: w_6JogZnfv1q7BUYX2Ki0Uz3oDL-rPSWCpJ9WSqP13iaQwY97H2LU3vUvUGNyColpeynxJx



TOTAL WEIGHT = 2 X 60 = 120 lb
(M)F

LUMBER				DESCR.	
N. L. G. A. RULES	CHORDS	SIZE	LUMBER		
1 - 3	2x4	DRY	No.2	SPF	
3 - 5	2x4	DRY	No.2	SPF	
8 - 1	2x4	DRY	No.2	SPF	
8 - 5	2x4	DRY	No.2	SPF	
8 - 6	2x4	DRY	No.2	SPF	
ALL WEBS EXCEPT	2x3	DRY	No.2	SPF	

DRY: SEASONED LUMBER.

PLATES (table is in inches)						
JT	TYPE	PLATES	W	LEN	Y	X
1	TMV+p	MT20	2.0	4.0		
2	TMWW+1	MT20	3.0	5.0	2.25	1.50
3	TTW+p	MT20	3.0	4.0	2.50	1.50
4	TMWW-1	MT20	3.0	4.0		
5	TMV+p	MT20	2.0	4.0		
6	BMVW1-1	MT20	3.0	4.0		
7	BMVWW-1	MT20	3.0	6.0		
8	BMVW1-1	MT20	3.0	4.0		

DIMENSIONS, SUPPORTS AND LOADINGS SPECIFIED BY FABRICATOR TO BE VERIFIED BY BUILDING DESIGNER

BEARINGS		FACTORED GROSS REACTION		MAXIMUM FACTORED GROSS REACTION		INPUT BRG		REQD BRG	
JT		VERT	HORZ	DOWN	HORZ	UPLIFT	IN-SX	IN-SX	
8		626	0	626	0	0	5-8	5-8	
6		626	0	626	0	0	MECHANICAL		

A SUITABLE MECHANICAL CONNECTION IS REQUIRED AT JOINT 6 TO RESIST THE MAX FACTORED REACTIONS.

UNFACTORED REACTIONS

JT	1ST LCASE	MAX / MIN	COMPONENT REACTIONS						
	COMBINED	SNOW	LIVE	PERM. LIVE	WIND	DEAD	SOIL		
8	440	308 / 0	0 / 0	0 / 0	0 / 0	132 / 0	0 / 0		
6	440	308 / 0	0 / 0	0 / 0	0 / 0	132 / 0	0 / 0		

BEARING MATERIAL TO BE SPF NO.2 OR BETTER AT JOINT(S) 8

BRACING

TOP CHORD TO BE SHEATHED OR MAX. PURLIN SPACING = 6.25 FT.
MAX. UNBRACED BOTTOM CHORD LENGTH = 10.00 FT OR RIGID CEILING DIRECTLY APPLIED.

ALL PITCH BREAKS AND PERIMETER CORNER JOINTS MUST BE Laterally RESTRAINED.

LOADING

TOTAL LOAD CASES: (4)

CHORDS				WEBS			
MEMB.	MAX. FACTORED FORCE (LBS)	FACTORED VERT. LOAD (PLF)	MAX LC1 CS1 (LC)	MAX. UNBRAC LENGTH	MEMB.	MAX. FACTORED FORCE (LBS)	MAX CS1 (LC)
FR-TO		FROM TO			FR-TO		
1-2	0 / 20	-77.4	-77.4 0.14 (1)	10.00	2-7	-133 / 3	0.06 (1)
2-3	-420 / 0	-77.4	-77.4 0.11 (1)	6.25	7-3	0 / 305	0.07 (1)
3-4	-418 / 0	-77.4	-77.4 0.10 (1)	6.25	7-4	-77 / 16	0.04 (1)
4-5	0 / 19	-77.4	-77.4 0.13 (1)	10.00	8-2	-620 / 0	0.29 (1)
8-1	-101 / 0	0.0	0.0 0.01 (1)	7.81	4-6	-615 / 0	0.25 (1)
6-5	-85 / 0	0.0	0.0 0.01 (1)	7.81			
8-7	0 / 393	-17.5	-17.5 0.25 (4)	10.00			
7-6	0 / 357	-17.5	-17.5 0.24 (4)	10.00			

DESIGN CRITERIA

SPECIFIED LOADS:
TOP CH. LL = 23.3 PSF
DL = 3.0 PSF
BOT CH. LL = 0.0 PSF
DL = 7.0 PSF
TOTAL LOAD = 33.3 PSF

SPACING = 24.0 IN. C/C

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA 086-09
- TPIC 2011

(55% OF 27.2 P.S.F. G.S.L. PLUS 8.4 P.S.F. RAIN LOAD) EQUALS 23.3 P.S.F. SPECIFIED ROOF LIVE LOAD

ALLOWABLE DEFL.(LL)= L/360 (0.44")
CALCULATED VERT. DEFL.(LL) = L/999 (0.01")
ALLOWABLE DEFL.(TL)= L/360 (0.44")
CALCULATED VERT. DEFL.(TL) = L/999 (0.05")

CSI: TC=0.14/1.00 (1-2:1), BC=0.25/1.00 (7-8:4), WB=0.29/1.00 (2-8:1), SSI=0.10/1.00 (7-8:4)

DOL LUMBER=1.00 NAIL=1.00 LS BEND=1.10
COMP=1.10 SHEAR=1.10 TENS=1.10

COMPANION LIVE LOAD FACTOR = 0.50

TRUSS PLATE MANUFACTURER IS NOT RESPONSIBLE FOR QUALITY CONTROL IN THE TRUSS MANUFACTURING PLANT.

NAIL VALUES					
PLATE	GRIP(DRY)	SHEAR	SECTION		
	(PSI)	(PLI)	(PLI)		
MT20	618	354	1667	822	2284 1656

PLATE PLACEMENT TOL. = 0.250 inches


PLATE ROTATION TOL. = 5.0 Deg.

JSI GRIP= 0.89 (2) (INPUT = 0.90)
JSI METAL= 0.28 (2) (INPUT = 1.00)



READ ALL NOTES ON THIS PAGE AND ON ENGINEERING NOTE PAGE ENP-1. THIS NOTE PAGE IS AN INTEGRAL PART OF THIS DRAWING AS IT CONTAINS SPECIFICATIONS AND CRITERIA USED IN THE DESIGN OF THIS COMPONENT.





TOTAL WEIGHT = $8 \times 17 = 138$ lb

KOTT


BEARING ANCHORAGE BY TOE-NAILS FOR LATERAL CAPACITY

B37579H1

NAIL TYPE	LENGTH (IN)	DIAMETER (IN)	NAIL LATERAL CAPACITY (LB)	
			S-P-F	D. FIR
COMMON WIRE	3.00	0.144	132	147
	3.25	0.144	132	147
	3.50	0.160	159	177

NOTES:

1. Rafter and ceiling members may be anchored to top and bottom chords of girder truss by toe-nailing rafter and ceiling members to girder chords provided the reaction does not exceed the lateral capacities in the table. Hangers (specified by others) are required for reactions higher than the maximum toe-nail capacity. Reactions are based on factored loads.
2. Toe nail capacities shown in the table are for **one** toe-nail. For additional toe-nails multiply values in table by the number of toe-nails used. Toe-nail capacities take into account toe-nailing factor J_A in CSA O86-09, section 10.9.4.1.
3. For 9- 3/4 gauge 3.25" common wire gun nails (diameter = 0.120") use 3" common spiral nail values.
4. Maximum number of toe-nails allowed depends on the lumber size & species to be toe-nailed to supporting member and nail diameter, as shown in tables below.
5. Nail values in table are based on the following relative lumber densities: G = 0.42 (SPF), G = 0.49 (D. Fir).
6. Toe-nails shall be driven at approximately 1/3 the nail length from the edge of the joist/truss chord and driven at an angle of 30° to the grain of the member (See next page for nailing on bearing plate).
7. For loads due to wind the nail lateral capacity in this table may be multiplied by 1.15 (K_D factor).
8. Lumber must be dry (< 19% moisture content) at the time of nail installation.
9. Nail values in this table comply with CSA O86-09, section 10.9.4
10. This design is not valid after April 30, 2019.



Nail type	Common wire	Common spiral	Common wire
Nail dia. (in)	0.160	0.152	0.144
	(3.5" nail)		(3" and 3.25" nail)
LUMBER SIZE	MAXIMUM NUMBER OF TOE-NAILS		
2X4 SPF	2	2	3
2X4 D. Fir	2	2	2
2X6 SPF	4	4	4
2X6 D. Fir	3	3	3



MiTek Canada Inc
100 Industrial Rd.
Bradford, Ontario L3Z 3G7

PEO
Certificate No. 10889485



April 26, 2017

BEARING ANCHORAGE BY TOE-NAILS FOR WIND LOADING

B37579H2



NAIL TYPE	LENGTH (IN)	DIAMETER (IN)	NAIL WITHDRAWAL CAPACITY (LB)	
			S-P-F	D. FIR
COMMON	3.00	0.144	30	42
	3.25	0.144	32	45
	3.50	0.160	38	52

Note: If using truss with D. Fir lumber and S-P-F bearing plate, use values in table for S-P-F.



NOTES:

1. Truss chord, rafter, or ceiling members may be anchored to bearing plate by toe-nails, provided that the actual factored uplift force due to **wind or earthquake** load does not exceed the withdrawal capacities in the table. Hangers (specified by others) are required for uplift forces that are higher than the maximum toe-nail withdrawal capacity.
2. Toe nail capacities shown in the table are for **one** toe-nail. For additional toe-nails multiply values in table by the number of toe-nails used. Toe-nail capacities take into account toe-nailing factor J_A in CSA O86-09, section 10.9.5.2.
3. For 9- 3/4 gauge 3.25" common wire gun nails (diameter = 0.120") use 3" common spiral nail values.
4. Maximum number of toe-nails allowed depends on the lumber size & species to be toe-nailed to supporting member and nail diameter, as shown in table above.
5. Nail values in table are based on the following relative lumber densities: $G = 0.42$ (SPF), $G = 0.49$ (D. Fir).
6. Toe-nails shall be driven at approximately 1/3 the nail length from the edge of the joist/truss chord and driven at an angle of 30° to the grain of the member (See drawing on detail B37579H1).
7. Lumber must be dry (< 19% moisture content) at the time of nail installation.
8. Nail values in this table comply with CSA O86-09, section 10.9.5
9. This design is not valid after April 30, 2019

Toe-nailing on 2x6 Bearing Plate



Toe-nailing on 2x4 Bearing Plate



MiTek® MiTek Canada Inc
100 Industrial Rd.
Bradford, Ontario L3Z 3G7

PEO
Certificate No. 10889485




April 26, 2017

READ ALL NOTES ON THIS PAGE AND ON
ENGINEERING NOTE PAGE ENP-1. THIS
NOTE PAGE IS AN INTEGRAL PART OF
THIS DRAWING AS IT CONTAINS
SPECIFICATIONS AND CRITERIA USED IN
THE DESIGN OF THIS COMPONENT.



18-331266-000-00 RR-Roof
101619



For conventional wood framing shall conform to OBC 9.8.28

CITY OF BRAMPTON
BUILDING DIVISION
REVIEWED
JAN 05 2019
BY
MARK DERKSEN

THIS CERTIFICATION IS FOR THE ENGINEERING REVIEW OF
STRUCTURAL COMPONENTS SHOWN ON THIS DRAWING
AND IS LIMITED TO THE COMPONENTS SUPPLIED BY KOTT
LUMBER FOR THE LOADS AND CONDITIONS SHOWN ON
THE CALCULATION PAGE OF EACH COMPONENT. THE
PLACEMENT OF THESE COMPONENTS ON THIS LAYOUT IS
SHOWN FOR REFERENCE ONLY. ROOF TRUSSES MUST BE
INSTALLED ACCORDING TO MANUFACTURER'S GUIDELINES
AT 24" C/C UNLESS NOTED OTHERWISE. CONVENTIONAL
FRAMING SHOWN ON THE LAYOUT MUST BE DESIGNED
AND APPROVED BY THE PROJECT ENGINEER. TEMPORARY
AND PERMANENT BRACINGS OF THE ROOF AND BUILDING
ARE THE RESPONSIBILITY OF THE PROJECT ENGINEER
AND TO CONFORM TO BCSI GUIDELINES.

All work shall conform to the Ontario
Building Code O. Reg. 332/12 as amended

Architectural Drawing Info
Date: JULY 26, 2018
Project number: 18-24
Model: GRANDBROOKE 1



CONVENTIONAL
FRAMING BY OTHERS

ALL CONVENTIONAL FRAMING TO CONFORM WITH
PART 9 OF THE O.B.C.
ROOF RAFTERS THAT CROSS MEET OVER TRUSSES
TO BE 2x4 S.P.F. @ 24" O/C WITH A 2x4 VERTICAL
POST TO THE TRUSS UNDERNEATH EACH CROSS
POINT. VERTICAL POST LONGER THAN 6' TO HAVE
LATERAL BRACING SO THAT THE DISTANCE BETWEEN
END POINT AND BETWEEN ROWS OF BRACING
DOES NOT EXCEED 6'.

SIZE AND LOCATION OF CONVENTIONAL FRAMING
IS APPROXIMATE. ALL AREAS MAY NOT BE SHOWN.
REFER TO ARCHITECTURAL PLANS FOR DETAILS.

HANGER LEGEND:

- ▼ LUS24
- LJS26DS
- HGUS26
- ✕ HGUS26-2

DESIGN CRITERIA
SPECIFIED LOADS:
TOP CH. LL = 23.3 PSF
DL = 3 PSF
BOT CH. LL = 0 PSF
DL = 7 PSF
TOTAL LOAD = 33.3 PSF
SPACING = 24" O/C.

THIS TRUSS IS DESIGNED FOR RESIDENTIAL OR
SMALL BUILDING REQUIREMENTS OF PART 9, NBCC 2010

THIS DESIGN COMPLIES WITH:
- PART 9 OF OBC 2012, BCBC 2012, ABC 2014
- CSA D89-09
- TPIC 2011

Model: **GRANDBROOKE 1 EL 2**
Customer: GREENPARK
Project: MINNISALE HOMES
Location: BRAMPTON
Date: 6/22/2018 Drawn by: BB

60713