

THIS STRUCTURE MUST BE
 CONSTRUCTED TO MEET OR
 EXCEED THE PROVISIONS OF
 THE ONTARIO BUILDING CODE

SITE NAME: LAMBERT'S LANE PH.2

BUILDER: GREENPARK HOMES

TYPE: KINMOUNT 6A

GFA: 3062

DATE: Jul-19

LO#: 81358

WINTER NATURAL AIR CHANGE RATE 0.221

HEAT LOSS AT °F. 74

CSA-F280-12

SUMMER NATURAL AIR CHANGE RATE 0.072

HEAT GAIN AT °F. 11

ENERGYSSTAR

ROOM USE	EXP. WALL	CLG. HT.	FACTORS	MBR	ENS	WIC	BED-2	BED-3	BED-4	BATH	ENS-4
EXP. WALL	33			33	37	13	15	35	31	14	6
CLG. HT.	8			8	8	8	8	8	8	8	8
GRS.WALL AREA	LOSS	GAIN	267	299	105	121	283	251	113		48
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS
NORTH	18.6	14.1	0	0	0	0	0	0	0	0	7
EAST	18.6	37.6	0	0	0	0	0	45	835	1690	130
SOUTH	18.6	22.3	0	0	16	297	357	0	0	0	0
WEST	18.6	37.6	32	594	1202	25	464	939	0	0	0
SKYLT.	31.2	99.9	0	0	0	0	0	0	0	0	0
DOORS	24.7	3.7	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	3.5	0.5	235	825	122	258	908	135	105	370	55
NET EXPOSED BSMT WALL ABOVE GR	3.5	0.5	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.3	0.6	270	338	151	255	320	142	195	244	109
NO ATTIC EXPOSED CLG	2.7	1.2	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.5	0.4	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			1757		1988	614	988	2059	2464	769	658
SUB TOTAL HT GAIN			1475	1572	163	554	1986	1768	314		215
LEVEL FACTOR / MULTIPLIER	0.20	0.21		0.20	0.21	0.20	0.21	0.20	0.21	0.20	0.21
AIR CHANGE HEAT LOSS			362		410	127	204	424	508	158	136
AIR CHANGE HEAT GAIN			77	82	8	29	103	92	16		11
DUCT LOSS			0	0	0	0	0	297	0	0	79
DUCT GAIN			0	0	0	0	0	286	0	0	23
HEAT GAIN PEOPLE	240	2	480	0	0	0	1	240	1	240	0
HEAT GAIN APPLIANCES/LIGHTS			563	0	0	0	563	563	563	0	0
TOTAL HT LOSS BTU/H			2120	2397	740	1191	2483	3269	927		872
TOTAL HT GAIN x 1.3 BTU/H			3372	2150	224	1802	3760	3808	430		323

ROOM USE	EXP. WALL	CLG. HT.	FACTORS	LIV	KIT	FAM	LAUN	WR	FOY	OFF	BAS
EXP. WALL	33			33	43	38	29	7	19	19	182
CLG. HT.	10			10	10	10	12	10	10	10	9
GRS.WALL AREA	LOSS	GAIN	330	430	380	348	70	190	190		1092
GLAZING	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS
NORTH	18.6	14.1	0	0	0	0	7	130	99	0	6
EAST	18.6	37.6	0	0	0	0	0	0	0	28	0
SOUTH	18.6	22.3	30	557	669	0	0	0	0	0	8
WEST	18.6	37.6	0	0	0	0	0	0	0	0	6
SKYLT.	31.2	99.9	0	0	0	0	0	0	0	0	0
DOORS	24.7	3.7	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	3.5	0.5	300	1055	156	375	1319	195	333	1171	174
NET EXPOSED BSMT WALL ABOVE GR	3.5	0.5	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.3	0.6	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.7	1.2	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.5	0.4	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			1611	2461	2043	1752	351	1604	1089		9132
SUB TOTAL HT GAIN			825	1583	1939	339	189	447	1136		846
LEVEL FACTOR / MULTIPLIER	0.30	0.32		0.30	0.32	0.30	0.32	0.30	0.32	0.30	0.32
AIR CHANGE HEAT LOSS			516	788	654	561	112	513	349		5821
AIR CHANGE HEAT GAIN			43	82	101	18	10	23	59		44
DUCT LOSS			0	0	0	0	0	0	0	0	0
DUCT GAIN			0	0	0	0	0	0	0	0	0
HEAT GAIN PEOPLE	240	0	0	0	0	0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS			563	563	563	563	563	563	563	563	563
TOTAL HT LOSS BTU/H			2127	3249	2697	2312	464	2117	1438		14953
TOTAL HT GAIN x 1.3 BTU/H			1860	2897	3383	1196	258	611	2285		1888

RECEIVED
 JUL 30 2019

TOWN OF CALEDON
 BUILDING SECTION
 FILE NO.

TOTAL HEAT GAIN BTU/H: 30483

TONS: 2.54

LOSS DUE TO VENTILATION LOAD BTU/H: 1593

STRUCTURAL HEAT LOSS: 43358

TOTAL COMBINED HEAT LOSS BTU/H: 44951

Michael O'Rourke

SITE NAME: LAMBERT'S LANE PH.2
BUILDER: GREENPARK HOMES

TYPE: KINMOUNT 6A

DATE: Feb-19

GFA: 3062 LO# 81358

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 45,140 TOTAL HEAT GAIN 30,485
AIR FLOW RATE CFM 25.06 AIR FLOW RATE CFM 37.1furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35#GOODMAN
GMCE960603BNA 60AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	12	9	4
R/A	0	0	4	2	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5'Ø unless noted otherwise on layout.

plenum pressure s/a 0.18
max s/a dif press. loss 0.02
min adjusted pressure s/a 0.16
r/a pressure 0.17
r/a grille press. Loss 0.02
adjusted pressure r/a 0.15MEDLOW
MEDIUM
MEDIUM HIGH
HIGHDESIGN CFM = 1131
CFM @ .5"E.S.P.

TEMPERATURE RISE 47 °F

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	BATH	BED-4	BED-3	MBR	ENS-4	LIV	FAM	KIT	KIT	FAM	LAUN	W/R	FOY	OFF	BAS	BAS	BAS	BAS
RM LOSS MBH	1.19	1.69	0.79	1.25	1.38	1.77	0.98	1.77	1.38	1.19	0.90	2.16	1.37	1.65	1.65	1.37	2.35	0.47	2.15	1.46	3.84	3.84	3.84	3.84
CFM PER RUN HEAT	30	42	20	31	35	44	25	44	35	30	22	54	34	41	41	34	59	12	54	37	96	96	96	96
RM GAIN MBH	1.71	1.45	0.23	1.81	1.91	1.93	0.44	1.93	1.91	1.71	0.33	1.86	1.69	1.45	1.45	1.69	1.20	0.26	0.61	2.29	0.47	0.47	0.47	0.47
CFM PER RUN COOLING	63	54	9	67	71	72	16	72	71	63	12	69	63	54	54	63	44	10	23	85	18	18	18	18
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	57	49	37	21	45	47	37	37	47	44	33	14	38	35	31	46	46	8	37	28	51	30	11	28
EQUIVALENT LENGTH	190	130	180	140	130	200	140	170	90	150	170	140	160	140	120	130	140	120	170	140	150	170	130	190
TOTAL EFFECTIVE LENGTH	247	179	217	161	175	247	177	207	137	194	203	154	198	175	151	176	186	128	207	168	201	200	141	218
ADJUSTED PRESSURE	0.07	0.1	0.08	0.11	0.1	0.07	0.1	0.08	0.13	0.09	0.08	0.11	0.09	0.1	0.11	0.1	0.09	0.13	0.08	0.1	0.08	0.08	0.11	0.07
ROUND DUCT SIZE	6	5	4	5	5	6	4	6	5	5	4	5	5	5	5	5	5	4	5	6	6	6	6	6
HEATING VELOCITY (f/min)	153	308	229	228	257	224	287	224	257	220	252	396	250	301	301	250	433	138	396	189	489	489	489	489
COOLING VELOCITY (f/min)	321	396	103	492	521	367	184	367	521	463	138	507	463	396	396	463	323	115	169	433	92	92	92	92
OUTLET GRILL SIZE	4X10	3X10	3X10	3X10	3X10	4X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10	4X10
TRUNK	B	B	E	C	D	E	E	E	D	B	E	E	A	B	B	A	A	C	D	D	A	B	C	D

RUN #	25
ROOM NAME	ENS
RM LOSS MBH	0.84
CFM PER RUN HEAT	21
RM GAIN MBH	0.72
CFM PER RUN COOLING	27
ADJUSTED PRESSURE	0.17
ACTUAL DUCT LGH.	19
EQUIVALENT LENGTH	130
TOTAL EFFECTIVE LENGTH	149
ADJUSTED PRESSURE	0.12
ROUND DUCT SIZE	4
HEATING VELOCITY (f/min)	241
COOLING VELOCITY (f/min)	310
OUTLET GRILL SIZE	3X10
TRUNK	C

THIS STRUCTURE SHALL BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE

SUPPLY AIR TRUNK SIZE

	TRUNK	STATIC	ROUND	RECT	VELOCITY				TRUNK	STATIC	ROUND	RECT	VELOCITY							
	CFM	PRESS.	DUCT	DUCT			(f/min)		CFM	PRESS.	DUCT	DUCT			(f/min)					
TRUNK A	223	0.08	8	8	x	8	502	TRUNK G	0	0.00	0	0	x	8	0					
TRUNK B	280	0.07	9	10	x	8	504	TRUNK H	0	0.00	0	0	x	8	0					
TRUNK C	663	0.07	12.4	18	x	8	663	TRUNK I	0	0.00	0	0	x	8	0					
TRUNK D	257	0.07	8.7	10	x	8	463	TRUNK J	0	0.00	0	0	x	8	0					
TRUNK E	466	0.07	10.9	14	x	8	599	TRUNK K	0	0.00	0	0	x	8	0					
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0					

RETURN AIR TRUNK SIZE

	TRUNK	STATIC	ROUND	RECT		VELOCITY
	CFM	PRESS.	DUCT	DUCT		(ft/min)
TRUNK O	0	0.06	0	0	x	8 0
TRUNK P	0	0.06	0	0	x	8 0
TRUNK Q	0	0.06	0	0	x	8 0
TRUNK R	0	0.06	0	0	x	8 0
TRUNK S	0	0.06	0	0	x	8 0
TRUNK T	0	0.06	0	0	x	8 0
TRUNK U	0	0.06	0	0	x	8 0
TRUNK V	0	0.06	0	0	x	8 0
TRUNK W	0	0.06	0	0	x	8 0
TRUNK X	786	0.06	13.8	22	x	8 643
TRUNK Y	345	0.06	10.1	12	x	8 518
TRUNK Z	0	0.06	0	0	x	8 0
DROP	1131	0.06	15.8	24	x	10 679

RETURN AIR #	1	2	3	4	5	6																		BR
AIR VOLUME	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	
ACTUAL DUCT LGH.	58	43	56	56	20	32	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
EQUIVALENT LENGTH	180	175	165	190	135	170	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
TOTAL EFFECTIVE LH	238	218	221	246	155	202	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
ADJUSTED PRESSURE	0.08	0.07	0.07	0.06	0.10	0.07	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	
ROUND DUCT SIZE	7.5	7.5	6	6	8.3	7.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
INLET GRILL SIZE	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
INLET GRILL SIZE	14	14	14	14	24	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

TYPE: KINMOUNT 6A
SITE NAME: LAMBERT'S LANE PH.2

LO # 81358

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	3 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	4 @ 10.6 cfm	42.4 cfm
Table 9.32.3.A.	TOTAL	169.6 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		79.5 cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.6.
Total Ventilation Capacity	169.6	cfm
Less Principal Ventil. Capacity	79.5	cfm
Required Supplemental Capacity	90.1	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE 65H	Location: BSMT
79.5 cfm	3.0 sones ☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
79.5 CFM	74 F	1.08	X	0.25

SUPPLEMENTAL FANS		PANASONIC		
Location	Model	cfm	HVI	Sones
ENS	FV-05-11VK1	50	☒	0.3
BATH	FV-05-11VK1	50	☒	0.3
ENS-4	FV-05-11VK1	50	☒	0.3
W/R	FV-05-11VK1	50	☒	0.3

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE 65H		
155	cfm high	64 cfm low
75	% Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	February-19

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669 *Michael O'Rourke* MICHAEL O'ROURKE

THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations
Formula Sheet (For Air Leakage / Ventilation Calculation)

LO#: 81358

Model: KINMOUNT 6A

Builder: GREENPARK HOMES

Date: 01/02/2019

Volume Calculation
Air Change & Delta T Data

House Volume			
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)
Bsmt	1371	9	12339
First	1371	10	13710
Second	1691	9	15219
Third	0	9	0
Fourth	0	9	0
Total:			41,268.0 ft³
Total:			1168.6 m³

WINTER NATURAL AIR CHANGE RATE	0.227
SUMMER NATURAL AIR CHANGE RATE	0.074

Design Temperature Difference				
	Tin °C	Tout °C	ΔT °C	ΔT °F
Winter DTDh	22	-19	41	74
Summer DTDc	24	30	6	11

5.2.3.1 Heat Loss due to Air Leakage
6.2.6 Sensible Gain due to Air Leakage

$$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$$

$$0.227 \times 324.61 \times 41^\circ\text{C} \times 1.2 = 3651 \text{ W}$$

$$= 12456 \text{ Btu/h}$$

$$HG_{salb} = LR_{aire} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$$

$$0.074 \times 324.61 \times 6^\circ\text{C} \times 1.2 = 176 \text{ W}$$

$$= 600 \text{ Btu/h}$$

5.2.3.2 Heat Loss due to Mechanical Ventilation
6.2.7 Sensible heat Gain due to Ventilation

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 74^\circ\text{F} \times 1.08 \times 0.25 = 1593 \text{ Btu/h}$$

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 11^\circ\text{F} \times 1.08 \times 0.25 = 236 \text{ Btu/h}$$

5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)

$$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) + (HL_{agcleve} + HL_{bgcleve})\}$$

Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)
1	0.5	12,456	9,132	0.682
2	0.3		10,911	0.342
3	0.2		12,238	0.204
4	0		0	0.000
5	0		0	0.000


*HLairbv = Air leakage heat loss + ventilation heat loss

*For a balanced or supply only ventilation system HLairve = 0

THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Brampton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	17.4	 Insulation Configuration
Floor Width (m):	10.4	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	1.9	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	1860	


TYPE: KINMOUNT 6A
LO# 81358THIS DOCUMENT IS A PRELIMINARY
CONSTRUCTION TO MEET OR
EXCEED THE REQUIREMENTS OF
THE ONTARIO BUILDING CODE

Air Infiltration Residential Load Calculator


Supplemental tool for CAN/CSA-F280

Weather Station Description			
Province:	Ontario		
Region:	Brampton		
Weather Station Location:	Open flat terrain, grass		
Anemometer height (m):	10		
Local Shielding			
Building Site:	Suburban, forest		
Walls:	Heavy		
Flue:	Heavy		
Highest Ceiling Height (m):	6.71		
Building Configuration			
Type:	Detached		
Number of Stories:	Two		
Foundation:	Full		
House Volume (m ³):	1168.6		
Air Leakage/Ventilation			
Air Tightness Type:	Energy Star Detached (2.5 ACH)		
Custom BDT Data:	ELA @ 10 Pa.	1090.9 cm ²	
	2.50	ACH @ 50 Pa	
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust	
	37.5	37.5	
Flue Size			
Flue #:	#1	#2	#3 #4
Diameter (mm):	0	0	0 0
Natural Infiltration Rates			
Heating Air Leakage Rate (ACH/H):	0.227		
Cooling Air Leakage Rate (ACH/H):	0.074		

TYPE: KINMOUNT 6A
LO# 81358THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE



GROUND FLOOR PLAN ELEV. 1



GROUND FLOOR PLAN ELEV. 2
GROUND FLOOR PLAN ELEV. 3

ENERGY STAR FOR NEW HOMES STANDARD 4.7.2.2
ALL DUCTS FOR HEATING, VENTILATION AND AIR CONDITIONING SHALL BE LOCATED WITHIN THE HEATED BOUNDARY.

DUCTS LOCATED IN UNCONDITIONED SPACES SHALL BE SEALED TO A CLASS A SEAL LEVEL IN ACCORDANCE WITH THE SMACNA MANUAL

I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C.32.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

RECEIVED
JUL 30 2019
TOWN OF CALEDON
BUILDING SECTION
FILE NO.

CSA-F280-12

ENERGY STAR

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	FLOOR SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	FLOOR SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client

GREENPARK HOMES

Project Name

LAMBERT'S LANE HOME CORP PH 2
CALEDON, ONTARIO

KINMOUNT 6A 3062 sqft

375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdsgns.ca
Specializing in Residential Mechanical Design Services

Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE

Sheet Title

FIRST FLOOR
HEATING
LAYOUT

Date


FEB/2019

Scale

3/16" = 1'-0"


BCIN# 19669

LO# 81358



SECOND FLOOR PLAN ELEV. 1

SECOND FLOOR PLAN ELEV. 2



SECOND FLOOR PLAN ELEV. 3

I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

RECEIVED
JUL 30 2019
TOWN OF CALEDON
BUILDING SECTION
FILE NO _____

CSA-F280-12

ENERGY STAR

HVAC LEGEND						REVISIONS		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	No.	Description	Date
	FLOOR SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE	3.		
	FLOOR SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE	2.		
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE	1.		
					REDUCER	No.		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client

GREENPARK HOMES

Project Name

LAMBERT'S LANE HOME CORP PH 2
CALEDON, ONTARIO

KINMOUNT 6A 3062 sqft

375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdsgns.ca
Specializing in Residential Mechanical Design Services
Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE

Sheet Title

SECOND FLOOR
HEATING
LAYOUT

Date

FEB/2019

Scale

3/16" = 1'-0"

BCIN# 19669

LO#

81358