

THIS STRUCTURE MUST BE
 CONSTRUCTED TO MEET OR
 EXCEED THE PROVISIONS OF
 THE ONTARIO BUILDING CODE

SITE NAME: LAMBERT'S LANE PH.2				TYPE: PRESTON 1				GFA: 2507				DATE: Jul-19				WINTER NATURAL AIR CHANGE RATE 0.242				HEAT LOSS AT °F. 74				CSA-F280-12			
BUILDER: GREENPARK HOMES												LO# 81347				SUMMER NATURAL AIR CHANGE RATE 0.079				HEAT GAIN AT °F. 11				ENERGYSTAR			
ROOM USE		MBR		ENS		WIC		BED-2		BED-3		BED-4		BATH				ENS-2									
EXP. WALL		32		23		8		32		36		13		6				9									
CLG. HT.		8		8		8		8		8		8		8				8									
FACTORS																											
GRS.WALL AREA		259		186		65		259		291		105		48				73									
LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN				LOSS GAIN									
GLAZING																											
NORTH		18.6	15.1	0	0	0	8	148	121	0	0	0	0	0	0	0	0	0	16	297	242	0	0				
EAST		18.6	40.7	0	0	0	0	0	0	0	0	30	557	1222	30	557	1222	0	0	0	0	0	0				
SOUTH		18.6	24.1	0	0	0	0	0	0	0	0	0	0	0	0	16	297	385	7	130	168	0	0				
WEST		18.6	40.7	32	594	1303	16	297	651	0	0	0	0	0	0	0	0	0	0	0	0	0	0				
SKYL.T.		31.2	99.9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				
DOORS		24.7	3.7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				
NET EXPOSED WALL		3.5	0.5	227	797	118	162	569	84	65	227	34	229	804	119	261	918	136	89	313	46	41	146	22			
NET EXPOSED BSMT WALL ABOVE GR		3.5	0.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				
EXPOSED CLG		1.3	0.6	252	316	140	132	165	74	136	170	76	258	323	144	143	179	80	225	282	125	108	135	60			
NO ATTIC EXPOSED CLG		2.7	1.2	0	0	0	0	0	0	0	0	0	26	70	31	0	0	0	0	0	0	0	0	0			
EXPOSED FLOOR		2.5	0.4	0	0	0	0	0	0	0	0	258	642	95	30	75	11	42	105	16	0	0	0	0			
BASEMENT/CRAWL HEAT LOSS																											
SLAB ON GRADE HEAT LOSS																											
SUBTOTAL HT LOSS				1707		1180		398		2326		1798		997		411											
SUB TOTAL HT GAIN					1562		931		110		1580		1479		572		250										
LEVEL FACTOR / MULTIPLIER		0.20	0.20			0.20	0.20		0.20	0.20		0.20	0.20		0.20	0.20		0.20	0.20								
AIR CHANGE HEAT LOSS				343		237		80		467		381		200		83											
AIR CHANGE HEAT GAIN				80		48		6		81		76		29		13											
DUCT LOSS				0		0		0		279		216		120		0											
DUCT GAIN				0		0		0		244		233		138		0											
HEAT GAIN PEOPLE		240		2	480	0	0	0	0	1	240	1	240	1	240	0	0		0	0		0	0	0			
HEAT GAIN APPLIANCES/LIGHTS					539	0		0		539		539		539		539											
TOTAL HT LOSS BTU/H				2049		1417		478		3073		2375		1316		494											
TOTAL HT GAIN x 1.3 BTU/H				3459		1272		150		3489		3338		1974		342											

RECEIVED

JUL 26 2019

TOWN OF CALEDON
BUILDING SECTION
FILE NO 163

RECEIVED
 JUL 26 2019
 TOWN OF CALEDON
 BUILDING SECTION
 FILE NO. 163

ROOM USE	EXP. WALL	CLG. HT.		LVDN		KIT	FAM	LAUN	WIR	FOY	MUD															
				40		39	36	12	14	18	25															
				10		10	10	8	10	10	10															
FACTORS																										
GRS.WALL AREA	LOSS	GAIN		400		390	360	97	140	180	250															
GLAZING	LOSS	GAIN		LOSS	GAIN	LOSS	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN														
NORTH	18.6	15.1	0	0	0	0	0	0	8	148	121	0	0	0	0	0	0	10	186	151						
EAST	18.6	40.7	0	0	0	0	0	0	0	0	0	0	0	0	6	111	244	0	0	0	0	0	0	0	0	0
SOUTH	18.6	24.1	28	519	674	0	0	0	0	0	0	0	0	0	9	167	217	0	0	0	0	0	0	0	0	0
WEST	18.6	40.7	0	0	0	66	1224	2687	28	519	1140	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
SKYL.T.	31.2	99.9	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	24.7	3.7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	40	988	148	20	493	73			
NET EXPOSED WALL	3.5	0.5	372	1308	194	324	1139	169	332	1168	173	89	313	46	131	461	68	134	471	70	220	774	115			
NET EXPOSED BSMT WALL ABOVE GR	3.5	0.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
EXPOSED CLG	1.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
NO ATTIC EXPOSED CLG	2.7	1.2	0	0	0	0	0	0	10	27	12	0	0	0	0	0	0	0	0	0	0	0	0			
EXPOSED FLOOR	2.5	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
BASEMENT/CRAWL HEAT LOSS																										
SLAB ON GRADE HEAT LOSS																										
SUBTOTAL HT LOSS				1828		2364		1714		642		628		1569		1452										
SUB TOTAL HT GAIN				868		2856		1325		248		285		460		339										
LEVEL FACTOR / MULTIPLIER	0.30	0.32				0.30	0.32		0.30	0.32		0.30	0.32		0.30	0.32		0.30	0.32		0.30	0.32				
AIR CHANGE HEAT LOSS				592		765		555		129		203		508		470										
AIR CHANGE HEAT GAIN				44		146		68		13		15		24		17										
DUCT LOSS				0		0		0		0		0		0		0										
DUCT GAIN				0		0		0		0		0		0		0										
HEAT GAIN PEOPLE	240		0	0		0		0		0		0		0		0		0		0		0				
HEAT GAIN APPLIANCES/LIGHTS				539		539		539		539		539		539		539										
TOTAL HT LOSS BTU/H				2419		3128		2269		771		831		2076		1922										
TOTAL HT GAIN x 1.3 BTU/H				1886		4604		2511		1039		389		629		1164										

TOTAL HEAT GAIN BTU/H: 29188 TONS: 2.43 LOSS DUE TO VENTILATION LOAD BTU/H: 1593 STRUCTURAL HEAT LOSS: 39640 TOTAL COMBINED HEAT LOSS BTU/H: 41233

Michael O'Rourke

SITE NAME: LAMBERT'S LANE PH.2
BUILDER: GREENPARK HOMES

TYPE: PRESTON 1

DATE: Jul-19

GFA: 2507

LO# 81347

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 39,640 TOTAL HEAT GAIN 28,952
AIR FLOW RATE CFM 28.53 AIR FLOW RATE CFM 39.06

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

plenum pressure s/a 0.18
max s/a dif press. loss 0.02
min adjusted pressure s/a 0.16

r/a pressure 0.17
r/a grille press. loss 0.02
adjusted pressure r/a 0.15

#GOODMAN
GMEC960603BNA 60
FAN SPEED LOW
MEDLOW
MEDIUM
MEDIUM HIGH
HIGH 1131

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600
DESIGN CFM = 1131
CFM @ .5" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	12	8	4
R/A	0	0	4	2	1

All S/A diffusers 4"x10" unless noted otherwise on layout.
All S/A runs 5"x10" unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	BATH	BED-2	BED-3	MBR	ENS-2	LV/DN	KIT	KIT	FAM	FAM	LAUN	W/R	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.02	1.42	0.48	1.54	1.19	1.32	0.49	1.54	1.19	1.02	1.07	2.42	1.56	1.56	1.13	1.13	0.77	0.83	2.08	1.92	3.49	3.49	3.49	3.49
CFM PER RUN HEAT	29	40	14	44	34	38	14	44	34	29	31	69	45	45	32	32	22	24	59	55	99	99	99	99
RM GAIN MBH.	1.73	1.27	0.15	1.74	1.67	1.97	0.34	1.74	1.67	1.73	0.54	1.89	2.30	2.30	1.26	1.26	1.04	0.39	0.63	1.16	0.54	0.54	0.54	0.54
CFM PER RUN COOLING	68	50	6	68	65	77	13	68	65	68	21	74	90	90	49	49	41	15	25	45	21	21	21	21
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.16	0.16
ACTUAL DUCT LGH.	61	73	48	48	35	37	41	50	28	51	41	13	41	45	52	42	47	20	30	36	36	47	23	17
EQUIVALENT LENGTH	140	190	190	190	130	220	210	160	140	150	180	190	170	170	190	160	150	150	160	160	210	160	170	170
TOTAL EFFECTIVE LENGTH	201	263	238	238	165	257	251	210	168	201	221	203	211	215	242	202	197	170	180	196	196	257	183	187
ADJUSTED PRESSURE	0.09	0.07	0.07	0.07	0.1	0.07	0.07	0.08	0.1	0.09	0.08	0.08	0.08	0.08	0.07	0.09	0.09	0.1	0.1	0.09	0.08	0.06	0.09	0.09
ROUND DUCT SIZE	5	5	4	5	5	6	4	5	5	5	4	5	6	6	5	5	4	4	5	5	6	6	6	6
HEATING VELOCITY (ft/min)	213	294	161	323	250	194	161	323	250	213	356	507	229	229	235	235	252	275	433	404	505	505	505	505
COOLING VELOCITY (ft/min)	499	367	69	499	477	393	149	499	477	499	241	543	459	459	360	360	470	172	184	330	107	107	107	107
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10
TRUNK	A	A	B	B	C	B	B	C	C	A	B	C	A	A	A	A	B	C	C	B	A	A	B	C

RUN #	ROOM NAME	RM LOSS MBH.	CFM PER RUN HEAT	RM GAIN MBH.	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH.	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK
-------	-----------	--------------	------------------	--------------	---------------------	-------------------	------------------	-------------------	------------------------	-------------------	-----------------	---------------------------	---------------------------	-------------------	-------

THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE

SUPPLY AIR TRUNK SIZE

TEST 1 - 100% FLOW					TEST 2 - 100% FLOW					TEST 3 - 100% FLOW					
	TRUNK	STATIC	ROUND	RECT		VELOCITY		TRUNK	STATIC	ROUND	RECT		VELOCITY		
	CFM	PRESS.	DUCT	DUCT		(ft/min)		CFM	PRESS.	DUCT	DUCT		(ft/min)		
	TRUNK A	450	0.06	11.2	14	x	8	579	0	0.00	0	0	x	8	0
	TRUNK B	811	0.06	13.9	22	x	8	664	0	0.00	0	0	x	8	0
	TRUNK C	319	0.08	9.1	10	x	8	574	0	0.00	0	0	x	8	0
	TRUNK D	0	0.00	0	0	x	8	0	0	0.00	0	0	x	8	0
	TRUNK E	0	0.00	0	0	x	8	0	0	0.00	0	0	x	8	0
	TRUNK F	0	0.00	0	0	x	8	0	0	0.00	0	0	x	8	0

RETURN AIR TRUNK SIZE

RETURN AIR FROM SIZE							VELOCITY
TRUNK	STATIC	ROUND	RECT				(ft/min)
CFM	PRESS.	DUCT	DUCT				
TRUNK O	0	0.05	0	0	x	8	0
TRUNK P	0	0.05	0	0	x	8	0
TRUNK Q	0	0.05	0	0	x	8	0
TRUNK R	0	0.05	0	0	x	8	0
TRUNK S	0	0.05	0	0	x	8	0
TRUNK T	0	0.05	0	0	x	8	0
TRUNK U	0	0.05	0	0	x	8	0
TRUNK V	0	0.05	0	0	x	8	0
TRUNK W	0	0.05	0	0	x	8	0
TRUNK X	1131	0.05	16.5	32	x	8	636
TRUNK Y	265	0.05	9.6	10	x	8	477
TRUNK Z	0	0.05	0	0	x	8	0
DROP	1131	0.05	16.5	24	x	10	679

RETURN AIR

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
AIR VOLUME	130	135	130	95	310	135	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	61	48	49	47	40	71	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	185	225	175	145	255	190	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	246	273	224	192	295	261	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.06	0.05	0.07	0.08	0.05	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	7	7.5	6.8	5.8	10.2	7.1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	30	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

TYPE: PRESTON 1
SITE NAME: LAMBERT'S LANE PH.2

LO # 81347

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒	I Type a) or b) appliance only, no solid fuel	
☐	II Type I except with solid fuel (including fireplaces)	
☐	III Any Type c) appliance	
☐	IV Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐	1 Exhaust only/Forced Air System	
☐	2 HRV with Ducting/Forced Air System	
☒	3 HRV Simplified/connected to forced air system	
☐	4 HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	2 @ 21.2 cfm	42.4 cfm
Other Bedrooms	3 @ 10.6 cfm	31.8 cfm
Kitchen & Bathrooms	5 @ 10.6 cfm	53 cfm
Other Rooms	6 @ 10.6 cfm	63.6 cfm
Table 9.32.3.A.	TOTAL	190.8 cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1	Bedroom	31.8 cfm
2	Bedroom	47.7 cfm
3	Bedroom	63.6 cfm
4	Bedroom	79.5 cfm
5	Bedroom	95.4 cfm
TOTAL		79.5 cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	190.8	cfm
Less Principal Ventil. Capacity	79.5	cfm
Required Supplemental Capacity	111.3	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE 65H
Location:	BSMT
79.5 cfm	3.0 sones
☒ HVI Approved	

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
79.5 CFM	74 F	1.08	X	0.25


SUPPLEMENTAL FANS		PANASONIC		
Location	Model	cfm	HVI	Sones
ENS	FV-05-11VK1	50	☒	0.3
BATH	FV-05-11VK1	50	☒	0.3
ENS-2	FV-05-11VK1	50	☒	0.3
W/R	FV-05-11VK1	50	☒	0.3


HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE 65H	
155	cfm high	64 cfm low
75	% Sensible Efficiency	☒ HVI Approved
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER:		GREENPARK HOMES
Name:		
Address:		
City:		
Telephone #:	Fax #:	

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	
HRAI #	001820
Date:	July-19

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669  MICHAEL O'ROURKE

THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 81347	Model: PRESTON 1	Builder: GREENPARK HOMES	Date: 7/12/2019																																																									
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr><td>Bsmt</td><td>1087</td><td>9</td><td>9783</td></tr> <tr><td>First</td><td>1087</td><td>10</td><td>10870</td></tr> <tr><td>Second</td><td>1418</td><td>8</td><td>11461.694</td></tr> <tr><td>Third</td><td>0</td><td>9</td><td>0</td></tr> <tr><td>Fourth</td><td>0</td><td>9</td><td>0</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>32,114.7 ft³</td></tr> <tr><td colspan="3" style="text-align: right;">Total:</td><td>909.4 m³</td></tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1087	9	9783	First	1087	10	10870	Second	1418	8	11461.694	Third	0	9	0	Fourth	0	9	0	Total:			32,114.7 ft³	Total:			909.4 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%; text-align: center;">0.242</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td style="text-align: center;">0.079</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td style="text-align: center;">22</td> <td style="text-align: center;">-19</td> <td style="text-align: center;">41</td> <td style="text-align: center;">74</td> </tr> <tr> <td>Summer DTDc</td> <td style="text-align: center;">24</td> <td style="text-align: center;">30</td> <td style="text-align: center;">6</td> <td style="text-align: center;">11</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.242	SUMMER NATURAL AIR CHANGE RATE	0.079	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-19	41	74	Summer DTDc	24	30	6	11
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	1087	9	9783																																																									
First	1087	10	10870																																																									
Second	1418	8	11461.694																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			32,114.7 ft³																																																									
Total:			909.4 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.242																																																											
SUMMER NATURAL AIR CHANGE RATE	0.079																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-19	41	74																																																								
Summer DTDc	24	30	6	11																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.242 x 252.61 x 41 °C x 1.2 = 3022 W = 10312 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.079 x 252.61 x 6 °C x 1.2 = 146 W = 497 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 74 °F x 1.08 x 0.25 = 1593 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 11 °F x 1.08 x 0.25 = 236 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$ <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairve Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{level})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)</th> </tr> </thead> <tbody> <tr><td>1</td><td>0.5</td><td rowspan="5" style="text-align: center; vertical-align: middle;">10,312</td><td style="text-align: center;">8,793</td><td style="text-align: center;">0.586</td></tr> <tr><td>2</td><td>0.3</td><td style="text-align: center;">9,553</td><td style="text-align: center;">0.324</td></tr> <tr><td>3</td><td>0.2</td><td style="text-align: center;">10,269</td><td style="text-align: center;">0.201</td></tr> <tr><td>4</td><td>0</td><td style="text-align: center;">0</td><td style="text-align: center;">0.000</td></tr> <tr><td>5</td><td>0</td><td style="text-align: center;">0</td><td style="text-align: center;">0.000</td></tr> </tbody> </table>					Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)	1	0.5	10,312	8,793	0.586	2	0.3	9,553	0.324	3	0.2	10,269	0.201	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	10,312	8,793	0.586																																																								
2	0.3		9,553	0.324																																																								
3	0.2		10,269	0.201																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																												

THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE

HEAT LOSS AND GAIN SUMMARY SHEET**MODEL:** PRESTON 1**BUILDER:** GREENPARK HOMES**SFQT:** 2507**LO#** 81347**SITE:** LAMBERT'S LANE PH.2**DESIGN ASSUMPTIONS**

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-2	OUTDOOR DESIGN TEMP.	86
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	2.50	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	TIGHT	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	32114.7	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.50	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	6.0 ft
LENGTH: 54.0 ft	WIDTH: 30.0 ft	EXPOSED PERIMETER:	168.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package****ENERGYSTAR****Nominal Min. Eff.**

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.20
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.70
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	R22+R5	21.10
Basement Walls Minimum RSI (R)-Value	20	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	ZONE 2	-
Skylights Maximum U-Value	ZONE 2	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.9	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE

2012 OBC COMPLIANCE
EXCEEDS THE PROVISIONS OF
THE ONTARIO BUILDING CODE

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Brampton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	16.5	
Floor Width (m):	9.1	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.7	
Depth Below Grade (m):	1.83	
Window Area (m ²):	1.9	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1693



TYPE: PRESTON 1
LO# 81347THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description			
Province:	Ontario		
Region:	Brampton		
Weather Station Location:	Open flat terrain, grass		
Anemometer height (m):	10		
Local Shielding			
Building Site:	Suburban, forest		
Walls:	Heavy		
Flue:	Heavy		
Highest Ceiling Height (m):	7.34		
Building Configuration			
Type:	Detached		
Number of Stories:	Two		
Foundation:	Full		
House Volume (m ³):	909.4		
Air Leakage/Ventilation			
Air Tightness Type:	Energy Star Detached (2.5 ACH)		
Custom BDT Data:	ELA @ 10 Pa.	848.9 cm ²	
	2.50	ACH @ 50 Pa	
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust	
	37.5	37.5	
Flue Size			
Flue #:	#1	#2	#3 #4
Diameter (mm):	0	0	0 0
Natural Infiltration Rates			
Heating Air Leakage Rate (ACH/H):	0.242		
Cooling Air Leakage Rate (ACH/H):	0.079		

TYPE: PRESTON 1
LO# 81347THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE



ENERGY STAR FOR NEW HOMES STANDARD 4.7.2.2
ALL DUCTS FOR HEATING, VENTILATION AND AIR CONDITIONING
SHALL BE LOCATED WITHIN THE HEATED BOUNDARY.

GROUND FLOOR PLAN - ELEV. '1'

DUCTS LOCATED IN UNCONDITIONED SPACES SHALL BE SEALED TO A CLASS A SEAL LEVEL IN ACCORDANCE WITH THE SMACNA MANUAL

RECEIVED
JUL 26 2019
TOWN OF CALEDON
BUILDING SECTION
FILE NO.

CSA-F280-12

Energy Star

ENERGY STAR


I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 12.3 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.


HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdsgns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services	THIS SYSTEM SHALL BE COMPLETED IN ACCORDANCE WITH THE LATEST MUNICIPAL AND ONTARIO BUILDING CODE	Sheet Title FIRST FLOOR HEATING LAYOUT		
Project Name LAMBERTS LANE HOME CORP PH 2 CALEDON, ONTARIO				Date FEB/2019	Scale 3/16" = 1'-0"	
PRESTON 1 2507 sqft		Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.		BCIN# 19669		
				LO#	81347	



SECOND FLOOR PLAN - ELEV. '1'



SECOND FLOOR PLAN - ELEV. '2'

I MICHAEL O'Rourke HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 32.5 OF THE BUILDING CODE.
Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

RECEIVED
JUL 26 2019
TOWN OF CALEDON
BUILDING SECTION
FILE NO. _____

CSA-F280-12

ENERGY STAR

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GREENPARK HOMES

Project Name
**LAMBERTS LANE HOME CORP PH 2
CALEDON, ONTARIO**

PRESTON 1 2507 sqft

HVAC DESIGNS LTD.

375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdesigns.ca
Web: www.hvacdesigns.ca
Specializing in Residential Mechanical Design Services

Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE

Sheet Title
**SECOND FLOOR
HEATING
LAYOUT**

Date FEB/2019

Scale 3/16" = 1'-0"

BCIN# 19669

LO# 81347