


APPROVED
For construction as per the
Ontario Building Code
Town of Caledon Building Department
Initial _____
Date _____
File # _____

AUG 23 2019

TOWN OF CALEDON
BUILDING SECTION
FILE NO. _____



THIS STRUCTURE MUST BE
CONSTRUCTED TO MEET OR TOP
EXCEED THE PROVISIONS OF
THE ONTARIO BUILDING CODE.

JUL 30 2019

TOWN COPY PRESTON 2
ENERGY STAR

EXTERIOR RAILINGS:
3'-6" HIGH RAILING IF LANDING IS MORE
THAN 5'-11" ABOVE FINISHED GRADE
AND 3'-0" HIGH RAILING WHEN LANDING
IS LESS THAN 5'-11" ABOVE ADJACENT
FINISHED GRADE.

It is the builder's complete responsibility to ensure that all plans submitted for approval fully comply with the Architectural Guidelines and all applicable regulations and requirements including zoning provisions and any provisions in the subdivision agreement. The Control Architect is not responsible in any way for examining or approving site (lotting) plans or working drawings with respect to any zoning or building code or permit matter or that any house can be properly built or located on a lot.

This is to certify that these plans comply with the applicable Architectural Design Guidelines approved by the Town of CALEDON

JOHN C. WILLIAMS LTD., ARCHITECT
ARCHITECTURAL CONTROL REVIEW
AND APPROVAL

APPROVED BY: _____
DATE: JUL 31, 2019

This stamp certifies compliance with the applicable
Design Guidelines only and bears no further
product or company responsibility.

ELEVATIONS NOT DRAWN TO ACTUAL GRADE.
REFER TO FINAL GRADING PLAN.

Lot 69

6x6 WOOD COLUMN, 4x4
BRACING 24" LONG AT 45
DEGREES AT TOP SIDE FOR
POSTS OVER 7'-0" HIGH
ON 12" CONC. PIER

18			9				The undersigned has reviewed and taken responsibility for this design and has the questionnaire and made the requirements set out in the General Building Code to be a design. qualification information Richard Wink  signature	244
17			8					
16			7					
15			6					
14			5	ADD UPGRADE REAR WOB PER CLIENT.	JUL 30/19	GW		
13			4	ISSUED FOR PERMIT.	DEC 18/18	GW		
12			3	ROOF-FLOOR-ENG. CO-ORD.	NOV. 30/18	GW		428
11			2	ELEV. 2 ROOF SLOPES REVERSED PER A.C.	SEP. 25/18	GW		
10			1	PRELIMINARY. ISSUED FOR CLIENT REVIEW.	SEP. 19/18	GW		
no. description		date	by	no. description	date	by		

The undersigned has reviewed and takes responsibility for this design and for the qualifications and meets the requirements as set in the Ontario Building Code to be a Designer.

qualification information *5/1/0*

Richard Vink	<i>R Vink</i>	244
name	signature	
contacting information		

Contractor must verify all dimensions on the job and report any discrepancy to the Designer before proceeding with the work. All drawings and specifications are instruments of service and the property of the Designer which must be returned at the completion of the services or any not to be used.

VA3
DESIGN

DESIGN
255 Consumers Rd Suite 120
Toronto ON M2J 1R4
t 416.830.2255 f 416.630.4782
va@design.com

Project Name: LAMBERTS LANE HOME CORP. PH.2 Municipality: CALEDON

SEP. 2018 UPGRADED REAR ELEV. 2 (4 BE

1. $\frac{1}{2} \times \frac{1}{2} = \frac{1}{4}$

[illegible]

PRESTON 2
11.6m

project no.
18023

1994-1995	1996-1997
-----------	-----------

WALKOUT

2023-0315TON-2 A160

21 52 519 - 525 21

ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED DATE 08-14-2010 BY 60322 UCBAW/STP