

Schedule 1: Designer Information

Use one form for each individual who reviews and takes responsibility for design activities with respect to the project.

A. Project Information			
Building number, street name		Unit no.	Lot/con.
Municipality RICHMOND HILL	Postal code	Plan number/ other description	
B. Individual who reviews and takes responsibility for design activities			
Name MICHAEL O'ROURKE		Firm HVAC DESIGNS LTD.	
Street address 375 FINLEY AVE		Unit no. 202	Lot/con. N/A
Municipality AJAX	Postal code L1S 2E2	Province ONTARIO	E-mail info@hvacdesigns.ca
Telephone number (905) 619-2300	Fax number (905) 619-2375	Cell number ()	
C. Design activities undertaken by individual identified in Section B. [Building Code Table 3.5.2.1 OF Division C]			
☐ House ☐ Small Buildings ☐ Large Buildings ☐ Complex Buildings ☒ HVAC – House ☐ Building Services ☐ Detection, Lighting and Power ☐ Fire Protection ☐ Building Structural ☐ Plumbing – House ☐ Plumbing – All Buildings ☐ On-site Sewage Systems			
Description of designer's work HEAT LOSS / GAIN CALCULATIONS DUCT SIZING RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY RESIDENTIAL SYSTEM DESIGN per CSA-F280-12		Model: AVIGNON 3 18 DENHAM DRIVE Project: BALTRIO	
D. Declaration of Designer			
I, <u>MICHAEL O'ROURKE</u> declare that (choose one as appropriate): (print name)			
☐ I review and take responsibility for the design work on behalf of a firm registered under subsection 3.2.4. of Division C, of the Building Code. I am qualified, and the firm is registered, in the appropriate classes/categories. Individual BCIN: _____ Firm BCIN: _____			
☒ I review and take responsibility for the design and am qualified in the appropriate category as an "other designer" under subsection 3.2.5. of Division C, of the Building Code. Individual BCIN: <u>19669</u> Basis for exemption from registration and qualification: <u>O.B.C SENTENCE 3.2.4.1 (4)</u>			
☐ The design work is exempt from the registration and qualification requirements of the Building Code. Basis for exemption from registration and qualification: _____			
I certify that:			
1. The information contained in this schedule is true to the best of my knowledge. 2. I have submitted this application with the knowledge and consent of the firm.			
September 30, 2020		 Signature of Designer	
Date			

NOTE:

- For the purposes of this form, "individual" means the "person" referred to in Clause 3.2.4.7(1) d) of Division C, Article 3.2.5.1. of Division C, and all other persons who are exempt from qualification under Subsections 3.2.4. and 3.2.5. of Division C.
- Schedule 1 is not required to be completed by a holder of a license, temporary license, or a certificate of authorization, issued by the Ontario Association of Architects. Schedule 1 is also not required to be completed by a holder of a license to practise, a limited license to practise, or a certificate of authorization, issued by the Association of Professional Engineers of Ontario.

Application for a Permit Construct or Demolish – Effective January 1, 2015

SITE NAME: BALTRIO					18 DENHAM DRIVE					DATE Sep-20					WINTER NATURAL AIR CHANGE RATE 0.332					HEAT LOSS AT °F. 78					CSA-F280-12									
BUILDER: GREENPARK HOMES					TYPE: AVIGNON 3					GFA: 6495					LO# 83730					SUMMER NATURAL AIR CHANGE RATE 0.107					HEAT GAIN AT °F. 14					SB-12 PACKAGE A1				
ROOM USE					MBR		ENS		WICS		BED-2		BED-3		BED-4		ENS-2		BED-5		ENS-3		ENS-4		FAM		H-OFF							
EXP. WALL					25		37		0		22		75		38		17		21		0		0		25		30							
CLG. HT.					10		9		9		9		9		9		9		10		9		9		14		11							
FACTORS																																		
GRS.WALL AREA					250		333		0		198		675		342		153		210		0		0		350		330							
GLAZING					LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN							
NORTH					21.8	16.3	0	0	0	0	0	0	0	23	501	374	24	523	390	0	0	0	0	0	0	0	0	0	0					
EAST					21.8	41.8	73	1590	3054	22	479	920	0	0	0	24	523	1004	22	479	920	0	0	0	12	261	502	0	0					
SOUTH					21.8	25.2	0	0	0	24	523	604	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
WEST					21.8	41.8	0	0	0	0	0	0	0	0	0	23	501	962	46	1002	1924	0	0	0	51	1111	2133	0	0					
SKYLT.					38.1	102.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0						
DOORS					25.8	4.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0						
NET EXPOSED WALL					4.6	0.8	177	809	143	287	1311	233	0	0	0	174	795	141	607	2773	492	272	1243	220	141	644	114	159	726					
NET EXPOSED BSMT WALL ABOVE GR					3.7	0.7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
EXPOSED CLG					1.3	0.6	425	558	257	310	407	187	216	284	131	370	486	224	472	620	285	336	441	203	70	92	42	346						
NO ATTIC EXPOSED CLG					2.8	1.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
EXPOSED FLOOR					2.6	0.5	0	0	0	0	0	0	0	0	0	0	395	1031	183	312	815	144	0	0	0	0	0	56						
BASEMENT/CRAWL HEAT LOSS							0		0		0		0		0		0		0		0		0		0		0							
SLAB ON GRADE HEAT LOSS							0		0		0		0		0		0		0		0		0		0		0							
SUBTOTAL HT LOSS							2957		2720		284		1804		5906		4023		998		2292		76		220		3114							
SUB TOTAL HT GAIN							3454		1945		131		1369		3216		2882		659		2471		35		60		3894							
LEVEL FACTOR / MULTIPLIER					0.20	0.34		0.20	0.34	0.20	0.34	0.20	0.34	0.20	0.34	0.20	0.34	0.20	0.34	0.20	0.34	0.20	0.34	0.20	0.34	0.30	0.55	0.30	0.55					
AIR CHANGE HEAT LOSS							1001		921		96		611		2000		1362		338		776		26		74		1698							
AIR CHANGE HEAT GAIN							263		148		10		104		245		219		50		188		3		5		296							
DUCT LOSS							0		0		0		0		791		539		0		0		0		29		0							
DUCT GAIN							0		0		0		0		450		414		0		0		0		6		0							
HEAT GAIN PEOPLE					240	2	480	0	0	0	0	0	1	240	1	240	1	240	0	0	1	240	0	0	0	0	0	0	0					
HEAT GAIN APPLIANCES/LIGHTS							802		0		0		802		802		802		0		802		0		0		802							
TOTAL HT LOSS BTU/H							3959		3642		380		2415		8696		5924		1335		3068		102		324		4812							
TOTAL HT GAIN x 1.3 BTU/H							6499		2720		183		3269		6440		5926		921		4812		49		92		6490							

ROOM USE			ENS-5				DIN			KIT			LIV			LAUN			PWD			FOY			MUD			REC			HALL			WUB			BAS		
EXP. WALL			0				42			56			44			23			11			7			36			131			37			25			123		
CLG. HT.			9				11			11			14			9			11			11			13			10			9			10			10		
FACTORS																																							
GRS.WALL AREA			0				462			616			616			207			121			77			468			917			333			250			861		
GLAZING			LOSS GAIN				LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN		
NORTH	21.8	16.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	12	261	195	0	0	0	0	0	0				
EAST	21.8	41.8	0	0	0	0	0	0	86	1873	3598	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5	109	209	0	0	0	0	0	0	0				
SOUTH	21.8	25.2	0	0	0	0	0	0	25	545	629	52	1133	1309	0	0	0	8	174	201	0	0	0	0	0	0	0	27	588	680	0	0	0	0	0	0			
WEST	21.8	41.8	0	0	0	57	1242	2384	0	0	0	77	1677	3221	11	240	460	0	0	0	16	349	669	0	0	0	0	0	0	0	0	0	0	0	0	0			
SKYLT.	38.1	102.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				
DOORS	25.8	4.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	48	1241	220	60	1551	275	20	517	92	0	0	0	40	1034	183	0	0	0				
NET EXPOSED WALL	4.6	0.8	0	0	0	405	1850	328	505	2307	409	487	2225	395	196	895	159	113	516	92	13	59	11	408	1864	331	0	0	0	294	1343	238	210	959	170	0	0		
NET EXPOSED BSMT WALL ABOVE GR	3.7	0.7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	393	1448	257	0	0	0	0	0	369	1359	241			
EXPOSED CLG	1.3	0.6	80	105	48	0	0	0	0	0	0	0	0	0	126	166	76	0	0	0	0	0	0	0	0	0	0	0	662	870	400	0	0	0	0	0	0		
NO ATTIC EXPOSED CLG	2.8	1.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
EXPOSED FLOOR	2.6	0.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
BASEMENT/CRAWL HEAT LOSS																																							
SLAB ON GRADE HEAT LOSS																																							
SUBTOTAL HT LOSS				105			3092			4725			5035			1301			691			1649			3415			6168			3062			2241			3193		
SUB TOTAL HT GAIN					48			2713			4636			4925			695			293			900			606		558			1513			354			241		
LEVEL FACTOR / MULTIPLIER			0.20	0.34			0.30	0.55		0.30	0.55		0.30	0.55		0.20	0.34		0.30	0.55		0.30	0.55		0.30	0.55		0.50	1.36			0.20	0.34			0.50	1.36		
AIR CHANGE HEAT LOSS				36				1686			2576			2745			440			377			899			1862			8373			1037					7376		
AIR CHANGE HEAT GAIN					4			206			353			375			53			22			68			46		42			115					45			
DUCT LOSS				0				0			0			0			0			0			0			0		0			0					0			
DUCT GAIN				0				0			0			0			0			0			0			0		0			0					0			
HEAT GAIN PEOPLE	240			0		0		0		0	0		0	0		0	0		0	0		0	0		0	0		0	0		0	0		0		0			
HEAT GAIN APPLIANCES/LIGHTS				0				802			802			802			802			0			0			0		802			0					802			
TOTAL HT LOSS BTU/H				141				4778			7302			7780			1741			1067			2548			5277			14541			4099			2489		10569		
TOTAL HT GAIN x 1.3 BTU/H					68			4838			7529			7933			2015			410			1259			847		1823			2117			460		1411			

SITE NAME: BALTRIO				18 DENHAM DRIVE				DATE: Sep-20		WINTER NATURAL AIR CHANGE RATE 0.332		HEAT LOSS AT °F. 78		CSA-F280-12	
BUILDER: GREENPARK HOMES				TYPE: AVIGNON 3				GFA: 6495		LO# 83730		SUMMER NATURAL AIR CHANGE RATE 0.107		HEAT GAIN AT °F. 14	
ROOM USE				NANN				B-ENS		B-KIT		B-PWD			
EXP. WALL				40				6		38		0			
CLG. HT.				10				10		10		10			
FACTORS															
GRS.WALL AREA				LOSS GAIN 280				42		266		0			
GLAZING				LOSS GAIN				LOSS GAIN		LOSS GAIN		LOSS GAIN			
NORTH				21.8	16.3	0	0	0	0	0	0	0	0	0	0
EAST				21.8	41.8	0	0	0	0	0	0	0	0	0	0
SOUTH				21.8	25.2	0	0	0	0	0	0	0	0	0	0
WEST				21.8	41.8	5	109	209	0	0	0	5	109	209	0
SKYLT.				38.1	102.0	0	0	0	0	0	0	0	0	0	0
DOORS				25.8	4.6	0	0	0	0	0	0	20	517	92	0
NET EXPOSED WALL				4.6	0.8	0	0	0	0	0	0	0	0	0	0
NET EXPOSED BSMT WALL ABOVE GR				3.7	0.7	120	442	78	18	66	12	114	420	74	0
EXPOSED CLG				1.3	0.6	0	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG				2.8	1.3	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR				2.6	0.5	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS				1250				188		1188		167			
SLAB ON GRADE HEAT LOSS				0				0		0		0			
SUBTOTAL HT LOSS				1801				254		2234		167			
SUB TOTAL HT GAIN				288				12		375		0			
LEVEL FACTOR / MULTIPLIER				0.50	1.36			0.50	1.36	0.50	1.36	0.50	1.36		
AIR CHANGE HEAT LOSS				2445				345		3032		226			
AIR CHANGE HEAT GAIN				22				1		29		0			
DUCT LOSS				0				0		0		0			
DUCT GAIN				0				0		0		0			
HEAT GAIN PEOPLE				240	1			0	0	0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS				802				0		802		0			
TOTAL HT LOSS BTU/H				4246				598		5265		393			
TOTAL HT GAIN x 1.3 BTU/H				1757				16		1568		0			

ROOM USE															
EXP. WALL															
CLG. HT.															
FACTORS															
GRS.WALL AREA				LOSS GAIN											
GLAZING															
NORTH				21.8	16.3										
EAST				21.8	41.8										
SOUTH				21.8	25.2										
WEST				21.8	41.8										
SKYLT.				38.1	102.0										
DOORS				25.8	4.6										
NET EXPOSED WALL				4.6	0.8										
NET EXPOSED BSMT WALL ABOVE GR				3.7	0.7										
EXPOSED CLG				1.3	0.6										
NO ATTIC EXPOSED CLG				2.8	1.3										
EXPOSED FLOOR				2.6	0.5										
BASEMENT/CRAWL HEAT LOSS															
SLAB ON GRADE HEAT LOSS															
SUBTOTAL HT LOSS															
SUB TOTAL HT GAIN															
LEVEL FACTOR / MULTIPLIER															
AIR CHANGE HEAT LOSS															
AIR CHANGE HEAT GAIN															
DUCT LOSS															
DUCT GAIN															
HEAT GAIN PEOPLE				240											
HEAT GAIN APPLIANCES/LIGHTS															
TOTAL HT LOSS BTU/H															
TOTAL HT GAIN x 1.3 BTU/H															

TOTAL HEAT GAIN BTU/H:

75974

TONS: 6.33

LOSS DUE TO VENTILATION LOAD BTU/H: 6512

STRUCTURAL HEAT LOSS: 110990

TOTAL COMBINED HEAT LOSS BTU/H: 117502

SITE NAME: BALTRIO
BUILDER: GREENPARK HOMES

18 DENHAM DRIVE
TYPE: AVIGNON 3

DATE: Sep-20

GFA: 6495 LO# 83730

FURNACE 1

HEATING CFM 1131 COOLING CFM 1131
TOTAL HEAT LOSS 53,965 TOTAL HEAT GAIN 34,275
AIR FLOW RATE CFM 20.96 AIR FLOW RATE CFM 33

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

3256 BTHU
HRV VENTILATION
3256+53965= 57,221

#GOODMAN
GMEC960603BNA 60
FAN SPEED LOW

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	8	6	7
R/A	0	0	3	3	2

plenium pressure s/a 0.18
max s/a dif press. loss 0.03
min adjusted pressure s/a 0.15

r/a pressure 0.17
r/a grille press. Loss 0.02
adjusted pressure r/a 0.15

DESIGN CFM = 1131
CFM @ .6" E.S.P.
MEDIUM HIGH 1131

TEMPERATURE RISE 47 °F

All S/A diffusers 4"x10" unless noted otherwise on layout.
All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
ROOM NAME	LAUN	BED-5	BED-5	BED-4	BED-4	ENS-4	ENS-5	LIV	LIV	FOY	DIN	DIN	HALL	BAS	BAS	NANN	B-KIT	LIV	BAS	B-PWD	B-ENS
RM LOSS MBH.	1.74	1.53	1.53	2.96	2.96	0.32	0.14	2.59	2.59	2.55	2.39	2.39	4.10	4.35	4.35	4.25	5.27	2.59	4.35	0.39	0.60
CFM PER RUN HEAT	36	32	32	62	62	7	3	54	54	53	50	50	86	91	91	89	110	54	91	8	13
RM GAIN MBH.	2.02	2.41	2.41	2.96	2.96	0.09	0.07	2.64	2.64	1.26	2.42	2.42	2.12	0.62	0.62	1.76	1.57	2.64	0.62	0.00	0.02
CFM PER RUN COOLING	67	79	79	98	98	3	2	87	87	42	80	80	70	21	21	58	52	87	21	0	1
ADJUSTED PRESSURE	0.17	0.17	0.17	0.16	0.16	0.17	0.17	0.16	0.16	0.17	0.17	0.17	0.16	0.16	0.16	0.16	0.15	0.16	0.16	0.17	0.17
ACTUAL DUCT LGH.	45	39	50	53	51	63	23	45	30	25	36	31	30	35	23	24	36	37	28	27	18
EQUIVALENT LENGTH	150	180	160	170	180	120	120	140	150	150	130	110	190	120	110	170	160	150	140	110	100
TOTAL EFFECTIVE LENGTH	195	219	210	223	231	183	143	185	180	175	166	141	220	155	133	194	196	187	168	137	118
ADJUSTED PRESSURE	0.09	0.08	0.08	0.07	0.07	0.09	0.12	0.09	0.09	0.1	0.1	0.12	0.07	0.1	0.12	0.08	0.08	0.09	0.1	0.13	0.15
ROUND DUCT SIZE	5	6	6	6	6	4	4	5	5	4	5	5	6	5	5	6	6	5	5	4	4
HEATING VELOCITY (ft/min)	264	163	163	316	316	80	34	396	396	608	367	367	438	668	668	454	561	396	668	92	149
COOLING VELOCITY (ft/min)	492	403	403	500	500	34	23	639	639	482	587	587	357	154	154	296	265	639	154	0	11
OUTLET GRILL SIZE	3X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10
TRUNK	B	A	A	E	E	D	D	B	B	A	A	A	E	C	C	A	B	E	C	C	E

RUN #	ROOM NAME	RM LOSS MBH.	CFM PER RUN HEAT	RM GAIN MBH.	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH.	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK
1	LAUN	1.74	36	2.02	67	0.17	45	150	195	0.09	5	264	492	3X10	B
2	BED-5	1.53	32	2.41	79	0.17	39	180	219	0.08	6	163	403	4X10	A
3	BED-5	1.53	32	2.41	79	0.17	50	160	210	0.08	6	163	403	4X10	A
4	BED-4	2.96	62	2.96	98	0.16	53	170	223	0.07	6	316	500	4X10	E
5	BED-4	2.96	62	2.96	98	0.16	51	180	231	0.07	6	316	500	4X10	E
6	ENS-4	0.32	7	0.09	3	0.17	63	120	183	0.09	4	80	34	3X10	D
7	ENS-5	0.14	3	0.07	2	0.17	23	120	143	0.12	4	34	23	3X10	D
8	LIV	2.59	54	2.64	87	0.16	45	140	185	0.09	5	396	639	3X10	B
9	LIV	2.59	54	2.64	87	0.16	30	150	180	0.09	5	396	639	3X10	B
10	FOY	2.55	53	1.26	42	0.17	25	150	175	0.1	4	608	482	3X10	A
11	DIN	2.39	50	2.42	80	0.17	36	130	166	0.1	5	367	587	3X10	A
12	DIN	2.39	50	2.42	80	0.17	31	110	141	0.12	5	367	587	3X10	A
13	HALL	4.10	86	2.12	70	0.16	30	190	220	0.07	6	438	357	4X10	E
14	BAS	4.35	91	0.62	21	0.16	35	120	155	0.1	5	668	154	3X10	C
15	BAS	4.35	91	0.62	21	0.16	23	110	133	0.12	5	668	154	3X10	C
16	NANN	4.25	89	1.76	58	0.16	24	170	194	0.08	6	454	296	4X10	A
17	B-KIT	5.27	110	1.57	52	0.15	36	160	196	0.08	6	561	265	4X10	B
18	LIV	2.59	54	2.64	87	0.16	37	150	187	0.09	5	396	639	3X10	E
19	BAS	4.35	91	0.62	21	0.16	28	140	168	0.1	5	668	154	3X10	C
20	B-PWD	0.39	8	0.00	0	0.17	27	110	137	0.13	4	92	0	3X10	C
21	B-ENS	0.60	13	0.02	1	0.17	18	100	118	0.15	4	149	11	3X10	E

SUPPLY AIR TRUNK SIZE	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK A	306	0.08	9	10	x 8 551	TRUNK G	0	0.00	0	0 x 8 0
TRUNK B	560	0.08	11.3	14	x 8 720	TRUNK H	0	0.00	0	0 x 8 0
TRUNK C	281	0.10	8.2	8	x 8 632	TRUNK I	0	0.00	0	0 x 8 0
TRUNK D	1128	0.07	15.2	26	x 8 781	TRUNK J	0	0.00	0	0 x 8 0
TRUNK E	837	0.07	13.6	22	x 8 685	TRUNK K	0	0.00	0	0 x 8 0
TRUNK F	0	0.00	0	0	x 8 0	TRUNK L	0	0.00	0	0 x 8 0

RETURN AIR #	1	2	3	4	5	6	7	BR
AIR VOLUME	130	130	130	165	145	235	100	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	64	43	43	38	17	26	20	1
EQUIVALENT LENGTH	155	155	185	175	220	215	150	0
TOTAL EFFECTIVE LH	219	198	228	213	237	241	170	1
ADJUSTED PRESSURE	0.07	0.07	0.06	0.07	0.06	0.06	0.09	14.80
ROUND DUCT SIZE	6.8	6.8	7	7.4	7.3	8.8	5.7	0
INLET GRILL SIZE	8	8	8	8	8	8	8	0
INLET GRILL SIZE	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	30	14	0

RETURN AIR TRUNK SIZE	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT	VELOCITY (ft/min)
TRUNK O	0	0.06	0	0	x 8 0
TRUNK P	0	0.06	0	0	x 8 0
TRUNK Q	0	0.06	0	0	x 8 0
TRUNK R	0	0.06	0	0	x 8 0
TRUNK S	0	0.06	0	0	x 8 0
TRUNK T	0	0.06	0	0	x 8 0
TRUNK U	0	0.06	0	0	x 8 0
TRUNK V	0	0.06	0	0	x 8 0
TRUNK W	0	0.06	0	0	x 8 0
TRUNK X	1131	0.06	15.8	30	x 8 679
TRUNK Y	265	0.06	9.2	10	x 8 477
TRUNK Z	0	0.06	0	0	x 8 0
DROP	1131	0.06	15.8	24	x 10 679

SITE NAME: BALTRIO
BUILDER: GREENPARK HOMES

18 DENHAM DRIVE
TYPE: AVIGNON 3

DATE: Sep-20

GFA: 6495 LO# 83730

FURNACE 2

HEATING CFM 1504 COOLING CFM 1504
TOTAL HEAT LOSS 56,014 TOTAL HEAT GAIN 40,292
AIR FLOW RATE CFM 26.85 AIR FLOW RATE CFM 37.33

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

3256 BTHU
HRV VENTILATION
3256+56014 = 59,270
#*GOODMAN
GMEC960804CNA
FAN SPEED 80

AFUE = 96 %
INPUT (BTU/H) = 80,000
OUTPUT (BTU/H) = **76,800**

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	14	10	4
R/A	0	0	3	2	1

plenium pressure s/a 0.18
max s/a dif press. loss 0.03
min adjusted pressure s/a 0.15
r/a pressure 0.17
r/a grille press. Loss 0.02
adjusted pressure r/a 0.15

DESIGN CFM = **1504**
CFM @ .6" E.S.P.
MEDIUM HIGH 1504
HIGH 1615
TEMPERATURE RISE 47 °F

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	BED-3	BED-3	ENS-3	ENS-4	BED-2	BED-2	MBR	MBR	WICS	ENS	ENS	KIT	KIT	FAM	FAM	H-OFF	PWD	REC	REC	REC	REC	MUD	BED-3	MBR
RM LOSS MBH.	2.90	2.90	0.10	0.32	1.21	1.21	1.32	1.32	0.19	1.82	1.82	2.43	2.43	2.41	2.41	1.75	1.07	3.64	3.64	3.64	3.64	2.64	2.90	1.32
CFM PER RUN HEAT	78	78	3	9	32	32	35	35	5	49	49	65	65	65	65	47	29	98	98	98	98	71	78	35
RM GAIN MBH.	2.15	2.15	0.05	0.09	1.63	1.63	2.17	2.17	0.09	1.36	1.36	2.51	2.51	3.24	3.24	1.97	0.41	0.46	0.46	0.46	0.46	0.42	2.15	2.17
CFM PER RUN COOLING	80	80	2	3	61	61	81	81	3	51	51	94	94	121	121	74	15	17	17	17	17	16	80	81
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.17	0.17	0.17	0.16	0.16	0.15	0.15	0.17	0.17	0.16	0.16	0.16	0.16	0.17	0.17	0.16
ACTUAL DUCT LGH.	74	73	46	72	69	54	50	73	33	80	71	52	46	43	57	66	54	68	41	44	68	14	64	77
EQUIVALENT LENGTH	170	160	140	180	210	150	150	120	190	140	140	150	130	130	110	150	100	130	140	120	100	100	180	130
TOTAL EFFECTIVE LENGTH	244	233	186	252	279	204	200	193	223	220	211	202	176	173	167	216	154	198	181	164	188	114	244	207
ADJUSTED PRESSURE	0.07	0.07	0.09	0.07	0.06	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.09	0.09	0.09	0.08	0.11	0.08	0.09	0.1	0.09	0.15	0.07	0.08
ROUND DUCT SIZE	6	6	4	4	5	5	6	6	4	5	5	6	6	6	6	5	4	6	6	6	6	5	6	6
HEATING VELOCITY (ft/min)	398	398	34	103	235	235	178	178	57	360	360	331	331	331	331	345	333	500	500	500	500	521	398	178
COOLING VELOCITY (ft/min)	408	408	23	34	448	448	413	413	34	374	374	479	479	617	617	543	172	87	87	87	87	117	408	413
OUTLET GRILL SIZE	4X10	4X10	3X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	3X10	4X10	4X10	4X10	4X10	3X10	3X10	4X10	4X10	4X10	4X10	3X10	4X10	4X10
TRUNK	D	D	D	C	C	D	D	B	B	A	A	C	C	B	B	A	A	C	D	B	A	E	D	B

RUN #	25	26	27	28
ROOM NAME	WICS	KIT	H-OFF	MUD
RM LOSS MBH.	0.19	2.43	1.75	2.64
CFM PER RUN HEAT	5	65	47	71
RM GAIN MBH.	0.09	2.51	1.97	0.42
CFM PER RUN COOLING	3	94	74	16
ADJUSTED PRESSURE	0.17	0.16	0.17	0.17
ACTUAL DUCT LGH.	65	37	70	10
EQUIVALENT LENGTH	150	120	140	130
TOTAL EFFECTIVE LENGTH	215	157	210	140
ADJUSTED PRESSURE	0.08	0.1	0.08	0.12
ROUND DUCT SIZE	4	6	5	5
HEATING VELOCITY (ft/min)	57	331	345	521
COOLING VELOCITY (ft/min)	34	479	543	117
OUTLET GRILL SIZE	3X10	4X10	3X10	3X10
TRUNK	B	D	A	E

SUPPLY AIR TRUNK SIZE										RETURN AIR TRUNK SIZE									
TRUNK	STATIC	ROUND	RECT	VELOCITY			TRUNK	STATIC	ROUND	RECT	VELOCITY	TRUNK	STATIC	ROUND	RECT	VELOCITY			
CFM	PRESS.	DUCT	DUCT			(ft/min)	CFM	PRESS.	DUCT	DUCT	(ft/min)	CFM	PRESS.	DUCT	DUCT			(ft/min)	
TRUNK A	319	0.08	9.1	10	x	8	574	0	0.00	0	0	x	8	0	0	x	8	0	
TRUNK B	627	0.08	11.8	16	x	8	705	0	0.00	0	0	x	8	0	0	x	8	0	
TRUNK C	269	0.06	9.2	10	x	8	484	0	0.00	0	0	x	8	0	0	x	8	0	
TRUNK D	736	0.06	13.4	20	x	8	662	0	0.00	0	0	x	8	0	0	x	8	0	
TRUNK E	1505	0.06	17.6	28	x	10	774	0	0.00	0	0	x	8	0	0	x	8	0	
TRUNK F	0	0.00	0	0	x	8	0	0	0.00	0	0	x	8	0	0	x	8	0	

RETURN AIR #	1	2	3	4	5	BR									
AIR VOLUME	185	205	130	405	385	0	0	0	0	0	0	0	0	0	194
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	40	51	61	62	68	1	1	1	1	1	1	1	1	1	45
EQUIVALENT LENGTH	220	175	175	150	190	0	0	0	0	0	0	0	0	0	185
TOTAL EFFECTIVE LH	260	226	236	212	258	1	1	1	1	1	1	1	1	1	230
ADJUSTED PRESSURE	0.06	0.07	0.06	0.07	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.06
ROUND DUCT SIZE	8	8	7	10.3	10.5	0	0	0	0	0	0	0	0	0	8.2
INLET GRILL SIZE	8	8	8	8	8	0	0	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	30	14	14	30	30	0	0	0	0	0	0	0	0	0	24

TYPE: AVIGNON 3
SITE NAME: BALTRIO

LO # 83730
18 DENHAM DRIVE

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>1</u> @ 21.2 cfm <u>21.2</u> cfm	
Other Bedrooms	<u>5</u> @ 10.6 cfm <u>53</u> cfm	
Kitchen & Bathrooms	<u>10</u> @ 10.6 cfm <u>106</u> cfm	
Other Rooms	<u>9</u> @ 10.6 cfm <u>95.4</u> cfm	
Table 9.32.3.A.	TOTAL <u>275.6</u> cfm	

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
6 Bedrooms		
As Per Ashrea 62.2 Dwelling- Unit Ventilation		
4.1.1 Total Ventilation Rate		
$Q_{tot}=0.03A_{floor}+7.5(N_{br}+1)$		
TOTAL <u>247.4</u> cfm		

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>275.6</u>	cfm
Less Principal Ventil. Capacity	<u>155</u>	cfm
Required Supplemental Capacity	<u>120.6</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE 65H	Location: BSMT
<u>155.0</u> cfm	<u>3.0</u> sones ☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
155.0 CFM	X 78 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		NUTONE		
Location	Model	cfm	HVI	Sones
ENS	QTXEN050C	50	☒	0.3
ENS-2	QTXEN050C	50	☒	0.3
ENS-4	QTXEN050C	50	☒	0.3
PWD	QTXEN050C	50	☒	0.3

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE 65H	INSTALL 2 HRV'S	
<u>155</u> cfm high	<u>64</u> cfm low	
X 2 = 310 cfm	% Sensible Efficiency ☒ HVI Approved	
<u>75</u>	@ 32 deg F (0 deg C)	

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: GREENPARK HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	September-20

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 83730	Model: AVIGNON 3	Builder: GREENPARK HOMES	Date: 9/30/2020																																																									
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>2979</td> <td>10</td> <td>29790</td> </tr> <tr> <td>First</td> <td>2979</td> <td>11</td> <td>32769</td> </tr> <tr> <td>Second</td> <td>3516</td> <td>9</td> <td>31644</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>94,203.0 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>2667.5 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	2979	10	29790	First	2979	11	32769	Second	3516	9	31644	Third	0	9	0	Fourth	0	9	0	Total:			94,203.0 ft³	Total:			2667.5 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%; text-align: center;">0.332</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td style="text-align: center;">0.107</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td style="text-align: center;">22</td> <td style="text-align: center;">-21</td> <td style="text-align: center;">43</td> <td style="text-align: center;">78</td> </tr> <tr> <td>Summer DTDc</td> <td style="text-align: center;">23</td> <td style="text-align: center;">31</td> <td style="text-align: center;">8</td> <td style="text-align: center;">14</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.332	SUMMER NATURAL AIR CHANGE RATE	0.107	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-21	43	78	Summer DTDc	23	31	8	14
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	2979	10	29790																																																									
First	2979	11	32769																																																									
Second	3516	9	31644																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			94,203.0 ft³																																																									
Total:			2667.5 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.332																																																											
SUMMER NATURAL AIR CHANGE RATE	0.107																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-21	43	78																																																								
Summer DTDc	23	31	8	14																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.332 x 740.98 x 43 °C x 1.2 = 12777 W = 43594 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.107 x 740.98 x 8 °C x 1.2 = 731 W = 2493 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 155 CFM x 78 °F x 1.08 x 0.25 = 6512 Btu/h X 2			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 155 CFM x 14 °F x 1.08 x 0.25 = 578 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$																																																												
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	43,594	16,058	1.357																																																								
2	0.3		23,985	0.545																																																								
3	0.2		25,748	0.339																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																												

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: AVIGNON 3	18 DENHAM DRIVE	BUILDER: GREENPARK HOMES
SFQT: 6495	LO# 83730	SITE: BALTRIO

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-6	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	74

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	WEST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	94203.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	7
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	7.0 ft
LENGTH: 62.0 ft	WIDTH: 65.0 ft	EXPOSED PERIMETER:	254.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package
A1****Nominal Min. Eff.**

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280


Weather Station Description		
Province:	Ontario	
Region:	Richmond Hill	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	18.9	 Insulation Configuration
Floor Width (m):	19.8	
Exposed Perimeter (m):	0.0	
Wall Height (m):	3.0	
Depth Below Grade (m):	2.13	
Window Area (m ²):	0.5	
Door Area (m ²):	5.6	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		2555

TYPE: AVIGNON 3
LO# 83730

18 DENHAM DRIVE

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Richmond Hill	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	2.4	
Width (m):	5.2	
Exposed Perimeter (m):	7.6	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		73

TYPE: AVIGNON 3
LO# 83730

18 DENHAM DRIVE

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Richmond Hill			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.01			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	2667.5			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	3555.9 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	73.2	73.2		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.332			
Cooling Air Leakage Rate (ACH/H):	0.107			

TYPE: AVIGNON 3
LO# 83730

18 DENHAM DRIVE