

NOT THE GRANTING OF A PERMIT NOR REVIEWING OF SPECS & DRAWINGS NOR INSPECTIONS MADE DURING INSTALLATION BY THE OFFICIAL HAVING JURISDICTION SHALL RELIEVE THE OWNER FROM REQUIREMENTS OF THE ONTARIO BUILDING CODE AND ANY OTHER REFERENCED REQUIREMENTS.

Garden 4 - Elevation 2

SITE NAME: BARLASSINA WOB DATE: Aug-22 WINTER NATURAL AIR CHANGE RATE 0.352 HEAT LOSS ΔT °F. 72 CSA-F280-12
 BUILDER: GREENPARK HOMES TYPE: GARDEN 4 GFA: 2615 LO# 98643 SUMMER NATURAL AIR CHANGE RATE 0.096 HEAT GAIN ΔT °F. 9 SB-12 PACKAGE A1

ROOM USE	MBR		ENS		WIC		BED-2		BED-3		BED-4		ENS-3		BATH		
EXP. WALL	33		23		8		30		34		18		10		16		
CLG. HT.	9		9		9		9		9		9		9		9		
FACTORS		297		207		72		270		306		162		90		144	
GRS.WALL AREA	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	
GLAZING																	
NORTH	20.3	15.0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EAST	20.3	40.5	0	0	0	0	0	0	27	547	1095	42	851	1703	0	0	
SOUTH	20.3	23.9	0	0	9	182	215	0	0	0	0	24	487	573	15	304	
WEST	20.3	40.5	20	405	811	9	182	365	0	0	0	0	0	0	0	0	
SKYLT.	35.5	99.8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
DOORS	19.1	2.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
NET EXPOSED WALL	4.3	0.5	277	1178	150	189	803	102	72	306	39	243	1033	131	264	1122	
NET EXPOSED BSMT WALL ABOVE GR	3.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED CLG	1.2	0.5	260	318	137	142	174	75	104	127	55	228	279	120	267	326	
NO ATTIC EXPOSED CLG	2.6	1.1	0	0	0	0	0	0	14	37	16	18	47	20	0	0	
EXPOSED FLOOR	2.4	0.3	0	0	0	0	0	0	242	588	75	0	0	0	0	0	
BASEMENT/CRAWL HEAT LOSS																	
SLAB ON GRADE HEAT LOSS																	
SUBTOTAL HT LOSS			1901		1342		433		2484		2347		1356		715		
SUB TOTAL HT GAIN			1098		757		94		1437		2006		770		438		
LEVEL FACTOR / MULTIPLIER	0.20	0.27	0.20	0.27	0.20	0.27	0.20	0.27	0.20	0.27	0.20	0.27	0.20	0.27	0.20	0.27	
AIR CHANGE HEAT LOSS			517		365		118		676		639		369		194		
AIR CHANGE HEAT GAIN			48		33		4		63		88		34		19		
DUCT LOSS			0		0		0		316		0		0		0		
DUCT GAIN			0		0		0		234		0		0		0		
HEAT GAIN PEOPLE	240	2	480	0	0	0	0	0	1	240	1	240	1	240	0	0	
HEAT GAIN APPLIANCES/LIGHTS			604		0		0		604		604		604		0		
TOTAL HT LOSS BTU/H			2418		1707		551		3476		2986		1725		909		
TOTAL HT GAIN x 1.3 BTU/H			2899		1027		127		3352		3820		2142		595		

ROOM USE	LIV/D		K/B/F/D		LAUN		W/R		FOY		WOB		BAS		
EXP. WALL	38		90		20		13		19		34		140		
CLG. HT.	10		10		11		10		11		8		8		
FACTORS		380		900		220		130		209		272		700	
GRS.WALL AREA	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	
GLAZING															
NORTH	20.3	15.0	0	0	0	0	0	0	0	0	0	0	0	0	
EAST	20.3	40.5	0	0	0	0	9	182	365	30	608	1216	0	0	
SOUTH	20.3	23.9	28	568	669	14	284	334	0	0	0	0	10	203	
WEST	20.3	40.5	0	0	0	81	1642	3284	0	0	0	0	0	0	
SKYLT.	35.5	99.8	0	0	0	0	0	0	0	0	0	0	0	0	
DOORS	19.1	2.4	0	0	0	0	0	0	21	401	51	18	344	44	
NET EXPOSED WALL	4.3	0.5	352	1496	190	805	3422	435	199	846	108	121	514	65	
NET EXPOSED BSMT WALL ABOVE GR	3.4	0.4	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED CLG	1.2	0.5	0	0	0	0	0	0	0	0	0	0	0	0	
NO ATTIC EXPOSED CLG	2.6	1.1	0	0	0	0	0	0	0	0	0	0	0	0	
EXPOSED FLOOR	2.4	0.3	0	0	0	0	0	0	0	0	0	0	0	0	
BASEMENT/CRAWL HEAT LOSS															
SLAB ON GRADE HEAT LOSS															
SUBTOTAL HT LOSS			2064		5348		1247		697		1636		375		
SUB TOTAL HT GAIN			859		4053		158		430		1347		2556		
LEVEL FACTOR / MULTIPLIER	0.30	0.43	0.30	0.43	0.30	0.43	0.30	0.43	0.30	0.43	0.30	0.43	0.50	1.19	
AIR CHANGE HEAT LOSS			880		2281		532		297		698		7814		
AIR CHANGE HEAT GAIN			38		179		7		19		59		140		
DUCT LOSS			0		0		0		0		0		0		
DUCT GAIN			0		0		0		0		0		0		
HEAT GAIN PEOPLE	240	0	0	0	0	0	0	0	0	0	0	0	0	0	
HEAT GAIN APPLIANCES/LIGHTS			604		604		604		604		604		604		
TOTAL HT LOSS BTU/H			2944		7629		1779		994		2334		2556		
TOTAL HT GAIN x 1.3 BTU/H			1951		6287		1000		584		1828		3519		

TOTAL HEAT GAIN BTU/H: 31163 TONS: 2.60 LOSS DUE TO VENTILATION LOAD BTU/H: 1554 STRUCTURAL HEAT LOSS: 45107 TOTAL COMBINED HEAT LOSS BTU/H: 46662



SITE NAME: BARLASSINA
BUILDER: GREENPARK HOMES

WOB
TYPE: GARDEN 4

DATE: Aug-22

GFA: 2615 LO# 98643

HEATING CFM 928 COOLING CFM 928
TOTAL HEAT LOSS 45,107 TOTAL HEAT GAIN 30,966
AIR FLOW RATE CFM 20.57 AIR FLOW RATE CFM 29.97

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

#GOODMAN
GMEC960603BNA
FAN SPEED 60
LOW
MEDLOW
MEDIUM 928
MEDIUM HIGH 1017
HIGH 1131

AFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = **57,600**
DESIGN CFM = **928**
CFM @ .6" E.S.P.
TEMPERATURE RISE 57 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	11	7	4
R/A	0	0	5	1	1

All S/A diffusers 4"x10" unless noted otherwise on layout.
All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	13	14	15	16	17	18	19	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	ENS-3	BED-2	BED-3	MBR	BATH	LIV/D	K/B/F/D	K/B/F/D	K/B/F/D	LAUN	W/R	FOY	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.21	1.71	0.55	1.74	1.49	1.72	0.91	1.74	1.49	1.21	1.27	2.94	2.54	2.54	2.54	1.78	0.99	2.33	3.60	3.60	3.60	3.60
CFM PER RUN HEAT	25	35	11	36	31	35	19	36	31	25	26	61	52	52	52	37	20	48	74	74	74	74
RM GAIN MBH.	1.45	1.03	0.13	1.68	1.91	2.14	0.60	1.68	1.91	1.45	0.25	1.95	2.10	2.10	2.10	1.00	0.58	1.83	1.28	1.28	1.28	1.28
CFM PER RUN COOLING	43	31	4	50	57	64	18	50	57	43	8	58	63	63	63	30	18	55	38	38	38	38
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	61	43	21	62	65	33	71	67	70	44	37	41	37	36	20	29	57	48	34	39	17	40
EQUIVALENT LENGTH	160	200	120	180	150	200	210	180	140	160	180	110	130	120	170	140	140	120	140	130	130	100
TOTAL EFFECTIVE LENGTH	221	243	141	242	215	233	281	247	210	204	217	151	167	156	190	169	197	168	174	169	147	140
ADJUSTED PRESSURE	0.08	0.07	0.12	0.07	0.08	0.07	0.06	0.07	0.08	0.08	0.08	0.11	0.1	0.11	0.09	0.1	0.09	0.1	0.1	0.1	0.12	0.12
ROUND DUCT SIZE	5	4	4	5	5	6	4	5	5	5	4	5	5	5	5	4	4	5	5	5	5	5
HEATING VELOCITY (ft/min)	184	402	126	264	228	178	218	264	228	184	298	448	382	382	382	424	229	352	543	543	543	543
COOLING VELOCITY (ft/min)	316	356	46	367	419	326	207	367	419	316	92	426	463	463	463	344	207	404	279	279	279	279
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10
TRUNK	C	C	D	A	A	C	A	A	A	C	B	B	C	C	C	B	A	A	C	C	B	B

RUN #	ROOM NAME	RM LOSS MBH.	CFM PER RUN HEAT	RM GAIN MBH.	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH.	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK

SUPPLY AIR TRUNK SIZE															
TRUNK	STATIC	ROUND	RECT	VELOCITY	TRUNK	STATIC	ROUND	RECT	VELOCITY						
CFM	PRESS.	DUCT	DUCT	(ft/min)	CFM	PRESS.	DUCT	DUCT	(ft/min)						
TRUNK A	221	0.06	8.6	10	x	8	398	TRUNK G	0	0.00	0	0	x	8	0
TRUNK B	493	0.06	11.6	16	x	8	555	TRUNK H	0	0.00	0	0	x	8	0
TRUNK C	424	0.07	10.5	14	x	8	545	TRUNK I	0	0.00	0	0	x	8	0
TRUNK D	928	0.06	14.7	26	x	8	642	TRUNK J	0	0.00	0	0	x	8	0
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0

RETURN AIR TRUNK SIZE															
TRUNK	STATIC	ROUND	RECT	VELOCITY	TRUNK	STATIC	ROUND	RECT	VELOCITY						
CFM	PRESS.	DUCT	DUCT	(ft/min)	CFM	PRESS.	DUCT	DUCT	(ft/min)						
TRUNK O	0	0.05	0	0	x	8	0	TRUNK P	0	0.05	0	0	x	8	0
TRUNK Q	0	0.05	0	0	x	8	0	TRUNK R	0	0.05	0	0	x	8	0
TRUNK S	0	0.05	0	0	x	8	0	TRUNK T	0	0.05	0	0	x	8	0
TRUNK U	0	0.05	0	0	x	8	0	TRUNK V	0	0.05	0	0	x	8	0
TRUNK W	0	0.05	0	0	x	8	0	TRUNK X	928	0.05	15.3	28	x	8	597
TRUNK Y	515	0.05	12.3	18	x	8	515	TRUNK Z	0	0.05	0	0	x	8	0
TRUNK DROP	928	0.05	15.3	24	x	10	557								

RETURN AIR #	1	2	3	4	5	6	7	8	9	10	11	13	14	15	16	17	18	19	21	22	23	24
AIR VOLUME	115	115	75	85	95	325	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	40	73	72	43	38	36	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	17
EQUIVALENT LENGTH	245	225	255	215	185	250	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	215
TOTAL EFFECTIVE LH	285	298	327	258	223	286	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	232
ADJUSTED PRESSURE	0.05	0.05	0.05	0.06	0.07	0.05	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.06
ROUND DUCT SIZE	7	7	6	6	6	10.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	6.8
INLET GRILL SIZE	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	8
INLET GRILL SIZE	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	30	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	14

TYPE: GARDEN 4
SITE NAME: BARLASSINA

LO # 98643
WOB

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES 9.32.3.1(1)

a) Direct vent (sealed combustion) only

b) Positive venting induced draft (except fireplaces)

c) Natural draft, B-vent or induced draft gas fireplace

d) Solid Fuel (including fireplaces)

e) No Combustion Appliances

HEATING SYSTEM

Forced Air Non Forced Air

Electric Space Heat

HOUSE TYPE 9.32.1(2)

I Type a) or b) appliance only, no solid fuel

II Type I except with solid fuel (including fireplaces)

III Any Type c) appliance

IV Type I, or II with electric space heat

Other: Type I, II or IV no forced air

SYSTEM DESIGN OPTIONS O.N.H.W.P.

1 Exhaust only/Forced Air System

2 HRV with Ducting/Forced Air System

3 HRV Simplified/connected to forced air system

4 HRV with Ducting/non forced air system

Part 6 Design

TOTAL VENTILATION CAPACITY 9.32.3.3(1)

Basement + Master Bedroom	<u>2</u>	@ 21.2 cfm	<u>42.4</u>	cfm
Other Bedrooms	<u>3</u>	@ 10.6 cfm	<u>31.8</u>	cfm
Kitchen & Bathrooms	<u>5</u>	@ 10.6 cfm	<u>53</u>	cfm
Other Rooms	<u>5</u>	@ 10.6 cfm	<u>53.0</u>	cfm
Table 9.32.3.A.		TOTAL	<u>180.2</u>	cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED 9.32.3.4.(1)

1	Bedroom	31.8	cfm
2	Bedroom	47.7	cfm
3	Bedroom	63.6	cfm
4	Bedroom	79.5	cfm
5	Bedroom	95.4	cfm
	TOTAL	79.5	cfm

SUPPLEMENTAL VENTILATION CAPACITY 9.32.3.5.

Total Ventilation Capacity	<u>180.2</u>	cfm
Less Principal Ventil. Capacity	<u>79.5</u>	cfm
Required Supplemental Capacity	<u>100.7</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY

Model: VANEE V150H Location: BSMT

79.5 cfm HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION

CFM		ΔT °F		FACTOR		% LOSS
79.5 CFM	X	72 F	X	1.08	X	0.25

SUPPLEMENTAL FANS BY INSTALLING CONTRACTOR

Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
ENS-3	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
BATH	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5
W/R	BY INSTALLING CONTRACTOR	50	<input checked="" type="checkbox"/>	3.5

HEAT RECOVERY VENTILATOR 9.32.3.11.

Model: VANEE V150H

150 cfm high 35 cfm low

75 % Sensible Efficiency @ 32 deg F (0 deg C) HVI Approved

LOCATION OF INSTALLATION

Lot: Concession

Township: Plan:

Address:

Roll # Building Permit #

BUILDER: GREENPARK HOMES

Name:

Address:

City:

Telephone #: Fax #:

INSTALLING CONTRACTOR

Name:

Address:

City:

Telephone #: Fax #:

DESIGNER CERTIFICATION

I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.

Name: HVAC Designs Ltd.

Signature: *Michael O'Rourke*

HRAI # 001820

Date: August-22

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

INDIVIDUAL BCIN: 19669

Michael O'Rourke

MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																																
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																																
LO#: 98643	Model: GARDEN 4	Builder: GREENPARK HOMES	Date: 8/25/2022																																																													
Volume Calculation			Air Change & Delta T Data																																																													
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="4">House Volume</th> </tr> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1189</td> <td>8</td> <td>9512</td> </tr> <tr> <td>First</td> <td>1189</td> <td>10</td> <td>11890</td> </tr> <tr> <td>Second</td> <td>1426</td> <td>9</td> <td>12834</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>34,236.0 ft³</td> </tr> <tr> <td colspan="3" style="text-align: right;">Total:</td> <td>969.5 m³</td> </tr> </tbody> </table>			House Volume				Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)	Bsmt	1189	8	9512	First	1189	10	11890	Second	1426	9	12834	Third	0	9	0	Fourth	0	9	0	Total:			34,236.0 ft ³	Total:			969.5 m ³	<table border="1" style="width:100%; border-collapse: collapse;"> <tbody> <tr> <td style="width: 70%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 30%;">0.352</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.096</td> </tr> </tbody> </table> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5">Design Temperature Difference</th> </tr> <tr> <th></th> <th>T_{in} °C</th> <th>T_{out} °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> </thead> <tbody> <tr> <td>Winter DTD_h</td> <td>22</td> <td>-18</td> <td>40</td> <td>72</td> </tr> <tr> <td>Summer DTD_c</td> <td>24</td> <td>29</td> <td>5</td> <td>9</td> </tr> </tbody> </table>		WINTER NATURAL AIR CHANGE RATE	0.352	SUMMER NATURAL AIR CHANGE RATE	0.096	Design Temperature Difference						T _{in} °C	T _{out} °C	ΔT °C	ΔT °F	Winter DTD _h	22	-18	40	72	Summer DTD _c	24	29	5	9
House Volume																																																																
Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)																																																													
Bsmt	1189	8	9512																																																													
First	1189	10	11890																																																													
Second	1426	9	12834																																																													
Third	0	9	0																																																													
Fourth	0	9	0																																																													
Total:			34,236.0 ft ³																																																													
Total:			969.5 m ³																																																													
WINTER NATURAL AIR CHANGE RATE	0.352																																																															
SUMMER NATURAL AIR CHANGE RATE	0.096																																																															
Design Temperature Difference																																																																
	T _{in} °C	T _{out} °C	ΔT °C	ΔT °F																																																												
Winter DTD _h	22	-18	40	72																																																												
Summer DTD _c	24	29	5	9																																																												
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																													
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ <p>0.352 x 269.29 x 40 °C x 1.2 = 4580 W</p> <p>= 15628 Btu/h</p>			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ <p>= 0.096 x 269.29 x 5 °C x 1.2 = 159 W</p> <p>= 543 Btu/h</p>																																																													
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																													
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ <p>80 CFM x 72 °F x 1.08 x 0.25 = 1554 Btu/h</p>			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ <p>80 CFM x 9 °F x 1.08 x 0.25 = 197 Btu/h</p>																																																													
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																																
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{ (HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel}) \}$																																																																
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HL_{air} Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{level})</th> <th>Air Leakage Heat Loss Multiplier (LF x HL_{airbv} / HL_{level})</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5" style="text-align: center;">15,628</td> <td>6,570</td> <td>1.189</td> </tr> <tr> <td>2</td> <td>0.3</td> <td>10,993</td> <td>0.427</td> </tr> <tr> <td>3</td> <td>0.2</td> <td>11,485</td> <td>0.272</td> </tr> <tr> <td>4</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> </tbody> </table>					Level	Level Factor (LF)	HL _{air} Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HL _{airbv} / HL _{level})	1	0.5	15,628	6,570	1.189	2	0.3	10,993	0.427	3	0.2	11,485	0.272	4	0	0	0.000	5	0	0	0.000																																		
Level	Level Factor (LF)	HL _{air} Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{level})	Air Leakage Heat Loss Multiplier (LF x HL _{airbv} / HL _{level})																																																												
1	0.5	15,628	6,570	1.189																																																												
2	0.3		10,993	0.427																																																												
3	0.2		11,485	0.272																																																												
4	0		0	0.000																																																												
5	0		0	0.000																																																												
<p>*HL_{airbv} = Air leakage heat loss + ventilation heat loss</p> <p>*For a balanced or supply only ventilation system HL_{airv} = 0</p>																																																																
				Michael O'Rourke BCIN# 19669 																																																												

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: GARDEN 4	WOB	BUILDER: GREENPARK HOMES
SFQT: 2615	LO# 98643	SITE: BARLASSINA

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	0	OUTDOOR DESIGN TEMP.	84
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.50

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft ³):	34236.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft ²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	5.0 ft
LENGTH: 63.0 ft	WIDTH: 24.0 ft	EXPOSED PERIMETER:	140.0 ft
WOB INSULATION CONFIGURATION	SCB_9	WOB EXPOSED PERIMETER	34.0 ft

2012 OBC - COMPLIANCE PACKAGE

Component	Compliance Package A1	
	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV/ERV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKE

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Cambridge	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	4.6	<p>Insulation Configuration</p>
Floor Width (m):	7.3	
Exposed Perimeter (m):	42.7	
Wall Height (m):	2.4	
Depth Below Grade (m):	1.24	
Window Area (m ²):	0.9	
Door Area (m ²):	2.0	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	577	

TYPE: GARDEN 4
 LO# 98643

WOB

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Cambridge	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	1.5	
Width (m):	7.3	
Exposed Perimeter (m):	10.4	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):	110	

TYPE: GARDEN 4
 LO# 98643

WOB

Air Infiltration Residential Load Calculator


Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Cambridge			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	8.23			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	969.5			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1292.3 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.352			
Cooling Air Leakage Rate (ACH/H):	0.096			



TYPE: GARDEN 4
 LO# 98643

WOB

BASEMENT PLAN EL-2



BASEMENT PLAN EL-3



BASEMENT PLAN EL-1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.


CSA-F280-12
WOB PACKAGE A1

HVAC LEGEND							3.	
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	


ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. © AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client GREENPARK HOMES	Project Name BARLASSINA CAMBRIDGE, ONTARIO	Garden 4 - Elevation 2 GARDEN 4 WOB 2615 sqft	 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdsgns.ca Web: www.hvacdsgns.ca Specializing in Residential Mechanical Design Services	HEAT LOSS 46662 BTU/H	# OF RUNS	S/A	R/A	FANS	Sheet Title BASEMENT HEATING LAYOUT	
				UNIT DATA	3RD FLOOR					
				MAKE GOODMAN	2ND FLOOR	11	5	3	Date AUG/2022	
				MODEL GMEC960603BNA	1ST FLOOR	7	1	3	Scale 3/16" = 1'-0"	
				INPUT 60 MBTU/H	BASEMENT	4	1	0	BCIN# 19669	
				OUTPUT 57.6 MBTU/H	ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A RUNS 5"Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A					LO# 98643
				COOLING 2.5 TONS						
				FAN SPEED 928 cfm @ 0.6" w.c.						

FIRST FLOOR PLAN EL-2



FIRST FLOOR PLAN EL-3



FIRST FLOOR PLAN EL-1

INSULATE DUCTS ROUTING THRU GARAGE MIN 2.1 RSI

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
 Michael O'Rourke, BCIN# 19669
 HVAC DESIGNS LTD.

CSA-F280-12

WOB PACKAGE A1

HVAC LEGEND							3.		
[Symbol]	SUPPLY AIR GRILLE	[Symbol]	6" SUPPLY AIR BOOT ABOVE	[Symbol]	14"x8" RETURN AIR GRILLE	[Symbol]	RETURN AIR STACK ABOVE	1.	
[Symbol]	SUPPLY AIR GRILLE 6" BOOT	[Symbol]	SUPPLY AIR STACK FROM 2nd FLOOR	[Symbol]	30"x8" RETURN AIR GRILLE	[Symbol]	RETURN AIR STACK 2nd FLOOR	No.	Description Date
[Symbol]	SUPPLY AIR BOOT ABOVE	[Symbol]	6" SUPPLY AIR STACK 2nd FLOOR	[Symbol]	FRA- FLOOR RETURN AIR GRILLE	[Symbol]	REDUCER	REVISIONS	

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD. © AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GREENPARK HOMES

Project Name
**BARLASSINA
 CAMBRIDGE, ONTARIO**

Garden 4 - Elevation 2


GARDEN 4 WOB 2615 sqft

375 Finley Ave. Suite 202 - Ajax, Ontario
 L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
 Email: info@hvacdsgns.ca
 Web: www.hvacdsgns.ca
 Specializing in Residential Mechanical Design Services


Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

Sheet Title	FIRST FLOOR HEATING LAYOUT
Date	AUG/2022
Scale	3/16" = 1'-0"
	BCIN# 19669
LO#	98643

SECOND FLOOR PLAN EL-2



SECOND FLOOR PLAN EL-3



SECOND FLOOR PLAN EL-1

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

CSA-F280-12

WOB PACKAGE A1

HVAC LEGEND

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	No.	Description	Date
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	3.		
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	2.		
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	1.		
								REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client
GREENPARK HOMES

Project Name
**BARLASSINA
CAMBRIDGE, ONTARIO**

Garden 4 - Elevation 2

GARDEN 4 WOB 2615 sqft

HVACDESIGNS LTD.

375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdsgns.ca

Specializing in Residential Mechanical Design Services

Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

Sheet Title
**SECOND FLOOR
HEATING
LAYOUT**

Date **AUG/2022**

Scale **3/16" = 1'-0"**

BCIN# **19669**

LO# **98643**