


SITE NAME: TRINITGROUP				WOB				GFA: 3005				DATE: Feb-24				WINTER NATURAL AIR CHANGE RATE 0.377				HEAT LOSS ΔT °F. 78				CSA-F280-12			
BUILDER: GREENPARK HOMES				TYPE: ROSE 2				LO# 102623				SUMMER NATURAL AIR CHANGE RATE 0.118				HEAT GAIN ΔT °F. 13				SB-12 PACKAGE A1							
ROOM USE	EXP. WALL	CLG. HT.	FACTORS	MBR	ENS	WIC	BED-2	BED-3	BED-4	S-BATH	FLEX	ENS-2															
				34	24	0	27	36	18	6	14	6															
				9	9	9	9	9	9	9	9	9															
GRS.WALL AREA	LOSS	GAIN		309	218	0	246	328	164	55	127	55															
GLAZING	LOSS	GAIN		LOSS	GAIN	LOSS	LOSS	LOSS	LOSS	LOSS	LOSS	LOSS															
NORTH	21.8	16.0	0	0	0	0	0	0	0	0	0	0															
EAST	21.8	41.6	0	0	0	0	0	0	0	0	0	0															
SOUTH	21.8	24.9	0	0	0	7	152	174	0	0	0	0															
WEST	21.8	41.6	22	479	914	16	349	665	0	0	0	0															
SKYLT.	38.1	101.5	0	0	0	0	0	0	0	0	0	0															
DOORS	20.5	3.4	0	0	0	0	0	0	0	0	0	0															
NET EXPOSED WALL	4.6	0.8	287	1313	216	195	893	147	0	0	0	0															
NET EXPOSED BSMT WALL ABOVE GR	3.7	0.6	0	0	0	0	0	0	0	0	0	0															
EXPOSED CLG	1.3	0.6	402	528	236	145	190	85	29	38	17	181															
NO ATTIC EXPOSED CLG	2.8	1.3	0	0	0	0	0	0	0	0	0	0															
EXPOSED FLOOR	2.6	0.4	0	0	0	0	0	0	0	0	0	0															
BASEMENT/CRAWL HEAT LOSS																											
SLAB ON GRADE HEAT LOSS																											
SUBTOTAL HT LOSS				2320		1584		114		2590		2668															
SUB TOTAL HT GAIN					1366		1071		2164		2392		624		254		951										
LEVEL FACTOR / MULTIPLIER			0.20	0.31		0.20	0.31		0.20	0.31		0.20	0.31		0.20	0.31		0.20	0.31		0.20	0.31					
AIR CHANGE HEAT LOSS				718		490		35		801		825				145		498									
AIR CHANGE HEAT GAIN					96		75		2		151		167		44		67										
DUCT LOSS				0		0		15		339		0				0		211									
DUCT GAIN					0		0		3		310		0		0		102										
HEAT GAIN PEOPLE	240		2		480	0	0	0	1		240	1		240	1		240	0	0		0						
HEAT GAIN APPLIANCES/LIGHTS					546		0		0		546			546			546		0								
TOTAL HT LOSS BTU/H				3038		2074		164		3730		3493		1676		613		2321									
TOTAL HT GAIN x 1.3 BTU/H					3235		1490		45		4436		4350		1890		353		1455								



ROOM USE	EXP. WALL	CLG. HT.	FACTORS	H-OFF	DIN	KT/BF	FAM	LAUN	PWD	FOY	MUD	WOB	BAS
				10	32	37	34	7	12	31	15	44	130
				10	10	10	10	9	10	10	10	9	9
GRS.WALL AREA	LOSS	GAIN		101	323	374	343	64	121	313	152	374	715
GLAZING	LOSS	GAIN		LOSS	LOSS	LOSS	LOSS	LOSS	LOSS	LOSS	LOSS	LOSS	LOSS
NORTH	21.8	16.0	0	0	0	0	0	0	0	0	0	0	0
EAST	21.8	41.6	0	0	0	0	0	0	0	0	0	0	0
SOUTH	21.8	24.9	22	479	548	29	632	722	0	0	0	6	131
WEST	21.8	41.6	0	0	0	52	1133	2161	0	0	0	60	1307
SKYLT.	38.1	101.5	0	0	0	0	0	0	0	0	0	0	0
DOORS	20.5	3.4	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	4.6	0.8	79	361	59	294	1344	221	322	1470	242	321	1468
NET EXPOSED BSMT WALL ABOVE GR	3.7	0.6	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.3	0.6	0	0	0	0	0	0	0	0	0	0	0
NO ATTIC EXPOSED CLG	2.8	1.3	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.6	0.4	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS													
SLAB ON GRADE HEAT LOSS													
SUBTOTAL HT LOSS				840		1976		2602		1948		576	
SUB TOTAL HT GAIN					607		943		2402		1156		4350
LEVEL FACTOR / MULTIPLIER			0.30	0.56		0.30	0.56		0.30	0.56		0.30	0.56
AIR CHANGE HEAT LOSS				469		1102		1452		1087		3421	
AIR CHANGE HEAT GAIN					42		66		168		81		222
DUCT LOSS				0		0		0		0		0	
DUCT GAIN					0		0		0		0		0
HEAT GAIN PEOPLE	240		0		0	0	0	0	0	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS					546		546		546		546		546
TOTAL HT LOSS BTU/H				1309		3078		4054		3034		3421	
TOTAL HT GAIN x 1.3 BTU/H					1555		2022		4052		2318		1399

TOTAL HEAT GAIN BTU/H:

36206

TONS: 3.02

LOSS DUE TO VENTILATION LOAD BTU/H: 1670

STRUCTURAL HEAT LOSS: 53901

TOTAL COMBINED HEAT LOSS BTU/H: 55571

SITE NAME: TRINITGROUP
BUILDER: GREENPARK HOMESWOB
TYPE: ROSE 2

DATE: Feb-24

GFA: 3005 LO# 102623

HEATING CFM 1083 COOLING CFM 1083
TOTAL HEAT LOSS 53,901 TOTAL HEAT GAIN 35,932
AIR FLOW RATE CFM 20.09 AIR FLOW RATE CFM 30.14furnace pressure 0.7
furnace filter 0.14
a/c coil pressure 0.26
available pressure
for s/a & r/a 0.30#GOODMAN
GMEC960603BNA 60
FAN SPEED LOWAFUE = 96 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 57,600

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	14	8	5
R/A	0	0	5	2	1

plenium pressure s/a 0.16
max s/a dif press. loss 0.01
min adjusted pressure s/a 0.15
r/a pressure 0.14
r/a grille press. Loss 0.02
adjusted pressure r/a 0.12DESIGN CFM = 1083
CFM @ .7" E.S.P.
MEDIUM HIGH 928
MEDIUM HIGH 1083
HIGH 1131


TEMPERATURE RISE 49 °F

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-2	BED-3	BED-4	S-BATH	FLEX	BED-2	MBR	ENS-2	H-OFF	DIN	KT/BF	KT/BF	FAM	LAUN	PWD	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.52	1.04	0.16	1.87	1.75	1.68	0.61	2.32	1.87	1.52	0.67	1.31	3.08	2.03	2.03	3.03	0.48	1.16	3.22	1.60	3.64	3.64	3.64	3.64
CFM PER RUN HEAT	31	21	3	37	35	34	12	47	37	31	13	26	62	41	41	61	10	23	65	32	73	73	73	73
RM GAIN MBH.	1.62	0.74	0.05	2.22	2.17	1.89	0.35	1.45	2.22	1.62	0.15	1.55	2.02	2.03	2.03	2.32	0.83	0.75	1.63	0.24	1.03	1.03	1.03	1.03
CFM PER RUN COOLING	49	22	1	67	66	57	11	44	67	49	4	47	61	61	61	70	25	23	49	7	31	31	31	31
ADJUSTED PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	48	43	45	59	71	48	51	57	63	45	51	48	37	36	29	20	35	56	56	17	42	51	24	45
EQUIVALENT LENGTH	180	190	140	170	190	160	170	140	190	180	130	120	120	140	90	130	190	170	140	160	140	130	150	150
TOTAL EFFECTIVE LENGTH	228	233	185	229	261	208	221	197	253	225	181	168	157	176	119	150	225	226	196	177	182	181	174	195
ADJUSTED PRESSURE	0.06	0.06	0.08	0.06	0.06	0.07	0.07	0.07	0.06	0.06	0.08	0.09	0.09	0.08	0.12	0.1	0.06	0.06	0.07	0.08	0.08	0.08	0.08	0.07
ROUND DUCT SIZE	5	4	4	6	6	6	4	5	6	5	4	5	5	5	5	6	4	4	6	4	6	6	6	6
HEATING VELOCITY (ft/min)	228	241	34	189	178	173	138	345	189	228	149	191	455	301	301	311	115	264	331	367	372	372	372	372
COOLING VELOCITY (ft/min)	360	252	11	342	337	291	126	323	342	360	46	345	448	448	448	357	287	264	250	80	158	158	158	158
OUTLET GRILL SIZE	3X10	3X10	3X10	4X10	4X10	4X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	4X10	3X10	4X10	4X10	4X10	4X10
TRUNK	C	D	C	B	A	D	C	B	B	D	C	B	C	D	E	E	C	A	A	C	D	D	E	B

RUN #	25	26	27
ROOM NAME	BAS	BED-3	ENS
RM LOSS MBH.	3.64	1.75	1.04
CFM PER RUN HEAT	73	35	21
RM GAIN MBH.	1.03	2.17	0.74
CFM PER RUN COOLING	31	66	22
ADJUSTED PRESSURE	0.15	0.15	0.15
ACTUAL DUCT LGH.	53	69	51
EQUIVALENT LENGTH	160	200	130
TOTAL EFFECTIVE LENGTH	213	269	181
ADJUSTED PRESSURE	0.07	0.05	0.08
ROUND DUCT SIZE	6	6	4
HEATING VELOCITY (ft/min)	372	178	241
COOLING VELOCITY (ft/min)	158	337	252
OUTLET GRILL SIZE	4X10	4X10	3X10
TRUNK	A	A	D



Richmond Hill City of Richmond Hill
Building Division
HVAC REVIEWED
Initials: PXV

SUPPLY AIR TRUNK SIZE

	TRUNK	STATIC	ROUND	RECT			VELOCITY		TRUNK	STATIC	ROUND	RECT			VELOCITY
	CFM	PRESS.	DUCT	DUCT			(ft/min)		CFM	PRESS.	DUCT	DUCT			(ft/min)
TRUNK A	231	0.05	9.1	10	x	8	416	TRUNK G	0	0.00	0	0	x	8	0
TRUNK B	451	0.05	11.7	18	x	8	451	TRUNK H	0	0.00	0	0	x	8	0
TRUNK C	614	0.05	13.1	22	x	8	502	TRUNK I	0	0.00	0	0	x	8	0
TRUNK D	294	0.06	9.5	10	x	8	529	TRUNK J	0	0.00	0	0	x	8	0
TRUNK E	469	0.06	11.3	14	x	8	603	TRUNK K	0	0.00	0	0	x	8	0
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0

RETURN AIR TRUNK SIZE

	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)	
TRUNK O	0	0.05	0	0	x	8	0
TRUNK P	0	0.05	0	0	x	8	0
TRUNK Q	0	0.05	0	0	x	8	0
TRUNK R	0	0.05	0	0	x	8	0
TRUNK S	0	0.05	0	0	x	8	0
TRUNK T	0	0.05	0	0	x	8	0
TRUNK U	0	0.05	0	0	x	8	0
TRUNK V	0	0.05	0	0	x	8	0
TRUNK W	195	0.05	8.6	8	x	8	439
TRUNK X	1083	0.05	16.3	30	x	8	650
TRUNK Y	941	0.05	15.4	28	x	8	605
TRUNK Z	378	0.05	11	14	x	8	486
DROP	1083	0.05	16.3	30	x	10	650

RETURN AIR #	1	2	3	4	5	6	7									BR
AIR VOLUME	115	95	88	90	95	100	358	0	0	0	0	0	0	0	0	142
PLENUM PRESSURE	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12
ACTUAL DUCT LGH.	43	66	66	48	73	46	37	1	1	1	1	1	1	1	1	14
EQUIVALENT LENGTH	175	195	200	190	200	205	230	0	0	0	0	0	0	0	0	135
TOTAL EFFECTIVE LH	218	261	266	238	273	251	267	1	1	1	1	1	1	1	1	149
ADJUSTED PRESSURE	0.06	0.05	0.05	0.05	0.05	0.05	0.05	12.40	12.40	12.40	12.40	12.40	12.40	12.40	12.40	0.08
ROUND DUCT SIZE	6.7	6.5	6.3	6.4	6.5	6.7	10.7	0	0	0	0	0	0	0	0	6.8
INLET GRILL SIZE	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	14	30	0	0	0	0	0	0	0	0	14

CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024

RECEIVED
Per: joshua.nabua

TYPE: ROSE 2
SITE NAME: TRINITGROUPLO # 102623
WOB

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES	9.32.3.1(1)
a) ☒ Direct vent (sealed combustion) only	
b) ☐ Positive venting induced draft (except fireplaces)	
c) ☐ Natural draft, B-vent or induced draft gas fireplace	
d) ☐ Solid Fuel (including fireplaces)	
e) ☐ No Combustion Appliances	

HEATING SYSTEM
☒ Forced Air ☐ Non Forced Air
☐ Electric Space Heat

HOUSE TYPE	9.32.1(2)
☒ I Type a) or b) appliance only, no solid fuel	
☐ II Type I except with solid fuel (including fireplaces)	
☐ III Any Type c) appliance	
☐ IV Type I, or II with electric space heat	
☐ Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS	O.N.H.W.P.
☐ 1 Exhaust only/Forced Air System	
☐ 2 HRV with Ducting/Forced Air System	
☒ 3 HRV Simplified/connected to forced air system	
☐ 4 HRV with Ducting/non forced air system	
☐ Part 6 Design	

TOTAL VENTILATION CAPACITY	9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm <u>42.4</u> cfm
Other Bedrooms	<u>3</u> @ 10.6 cfm <u>31.8</u> cfm
Kitchen & Bathrooms	<u>5</u> @ 10.6 cfm <u>53</u> cfm
Other Rooms	<u>5</u> @ 10.6 cfm <u>53.0</u> cfm
Table 9.32.3.A.	TOTAL <u>180.2</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED	9.32.3.4.(1)
1 Bedroom	31.8 cfm
2 Bedroom	47.7 cfm
3 Bedroom	63.6 cfm
4 Bedroom	79.5 cfm
5 Bedroom	95.4 cfm
TOTAL	79.5 cfm

SUPPLEMENTAL VENTILATION CAPACITY	9.32.3.5.
Total Ventilation Capacity	<u>180.2</u> cfm
Less Principal Ventil. Capacity	<u>79.5</u> cfm
Required Supplemental Capacity	<u>100.7</u> cfm

PRINCIPAL EXHAUST FAN CAPACITY
Model: VANEE V150H Location: BSMT
<u>79.5</u> cfm ☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION
CFM ΔT °F FACTOR % LOSS
79.5 CFM X 78 F X 1.08 X 0.25

SUPPLEMENTAL FANS	BY INSTALLING CONTRACTOR
Location Model cfm HVI Sones	
ENS BY INSTALLING CONTRACTOR 50 ☒ 3.5	
S-BATH BY INSTALLING CONTRACTOR 50 ☒ 3.5	
ENS-2 BY INSTALLING CONTRACTOR 50 ☒ 3.5	
PWD BY INSTALLING CONTRACTOR 50 ☒ 3.5	


HEAT RECOVERY VENTILATOR	9.32.3.11.
Model: VANEE V150H	
<u>150</u> cfm high <u>35</u> cfm low	
<u>75</u> % Sensible Efficiency ☒ HVI Approved	
@ 32 deg F (0 deg C)	

LOCATION OF INSTALLATION
Lot: Concession
Township Plan:
Address
Roll # Building Permit #

BUILDER:	GREENPARK HOMES
Name:	
Address:	
City:	
Telephone #: Fax #:	

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #: Fax #:	

DESIGNER CERTIFICATION
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.
Name: HVAC Designs Ltd.
Signature: 
HRAI # 001820
Date: February-24

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669  MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations

Formula Sheet (For Air Leakage / Ventilation Calculation)

LO#: 102623

Model: ROSE 2

Builder: GREENPARK HOMES

Date: 2/14/2024

Volume Calculation

Air Change & Delta T Data

House Volume

Level	Floor Area (ft ²)	Floor Height (ft)	Volume (ft ³)
Bsmt	1308	9	11118
First	1308	10	13210.8
Second	1687	9	15351.7
Third	0	9	0
Fourth	0	9	0
Total:			39,680.5 ft ³
Total:			1123.6 m ³

WINTER NATURAL AIR CHANGE RATE	0.377
SUMMER NATURAL AIR CHANGE RATE	0.118

Design Temperature Difference				
	Tin °C	Tout °C	ΔT °C	ΔT °F
Winter DTDh	22	-21	43	78
Summer DTDc	24	31	7	13

5.2.3.1 Heat Loss due to Air Leakage

6.2.6 Sensible Gain due to Air Leakage

$$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$$

$$0.377 \times 312.12 \times 43^\circ\text{C} \times 1.2 = 6105 \text{ W}$$

$$= 20831 \text{ Btu/h}$$

$$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$$

$$0.118 \times 312.12 \times 7^\circ\text{C} \times 1.2 = 313 \text{ W}$$

$$= 1068 \text{ Btu/h}$$

5.2.3.2 Heat Loss due to Mechanical Ventilation

6.2.7 Sensible heat Gain due to Ventilation

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 78^\circ\text{F} \times 1.08 \times 0.25 = 1670 \text{ Btu/h}$$

$$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$$

$$80 \text{ CFM} \times 13^\circ\text{F} \times 1.08 \times 0.25 = 275 \text{ Btu/h}$$

5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)

$$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$$

Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)
1	0.5	20,831	7,771	1.340
2	0.3		11,201	0.558
3	0.2		13,472	0.309
4	0		0	0.000
5	0		0	0.000

*HLairbv = Air leakage heat loss + ventilation heat loss

*For a balanced or supply only ventilation system HLairve = 0

Michael O'Rourke
BCIN# 19669CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024

RECEIVED
Per: joshua.nabua

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: ROSE 2	WOB	BUILDER: GREENPARK HOMES
SFQT: 3005	LO# 102623	SITE: TRINITGROUP

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-6	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.50

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	39680.5	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.27	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	5.5 ft
LENGTH: 53.0 ft	WIDTH: 34.0 ft	EXPOSED PERIMETER:	130.0 ft
WOB INSULATION CONFIGURATION	SCB_9	WOB EXPOSED PERIMETER	44.0 ft

2012 OBC - COMPLIANCE PACKAGE

Component

Compliance Package A1

	Nominal	Min. Eff.
Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV/ERV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV/ERV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE




CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024

RECEIVED
Per: joshua.nabua

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Richmond Hill	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	4.6	 Insulation Configuration
Floor Width (m):	10.4	
Exposed Perimeter (m):	39.6	
Wall Height (m):	2.6	
Depth Below Grade (m):	1.41	
Window Area (m ²):	0.0	
Door Area (m ²):	2.0	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		727

TYPE: ROSE 2
LO# 102623

WOB

Michael O'Rourke BCIN #19669


CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024


RECEIVED
Per: joshua.nabua

Residential Slab on Grade Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Richmond Hill	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Length (m):	1.5	
Width (m):	10.4	
Exposed Perimeter (m):	13.4	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Results		
Heating Load (Watts):		169

TYPE: ROSE 2
LO# 102623

WOB

Michael O'Rourke BCIN# 19669

CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024


RECEIVED
Per: joshua.nabua


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Richmond Hill			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	8.44			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1123.6			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1497.8 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.377			
Cooling Air Leakage Rate (ACH/H):	0.118			

TYPE: ROSE 2
LO# 102623

WOB



Michael O'Rourke BCIN# 19669



