

SITE NAME: TRINIGROUP
BUILDER: GREENPARK HOMESOPT 5 BED
TYPE: ROSE 6

DATE: Sep-23

GFA: 3175 LO# 102628

HEATING CFM 1142 COOLING CFM 1142
TOTAL HEAT LOSS 57,736 TOTAL HEAT GAIN 35,787
AIR FLOW RATE CFM 19.78 AIR FLOW RATE CFM 31.91

furnace pressure 0.7
furnace filter 0.14
a/c coil pressure 0.26
available pressure
for s/a & r/a 0.30

#GOODMAN
GMEC960803BNA 80

AFUE = 96 %
INPUT (BTU/H) = 80,000
OUTPUT (BTU/H) = **76,800**

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	16	10	6
R/A	0	0	6	2	1

plenium pressure s/a 0.16 r/a pressure 0.14
max s/a dif press. loss 0.01 r/a grille press. Loss 0.02
min adjusted pressure s/a 0.15 adjusted pressure r/a 0.12

MEDLOW
MEDIUM 885
MEDIUM HIGH 1005
HIGH 1142


DESIGN CFM = **1142**
CFM @ .7" E.S.P.

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	MBR	ENS	WIC	BED-3	BED-4	ENS-5	S-ENS	ENS-4	BED-5	MBR	BED-5	DN/LV	H-OFF	KT/BF	KT/BF	FAM	BED-2	PWD	FOY	MUD	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.48	1.18	0.35	1.77	1.67	0.63	0.34	1.11	0.70	1.48	0.70	2.23	2.24	2.33	2.33	1.46	1.41	0.94	3.53	0.85	3.25	3.25	3.25	3.25
CFM PER RUN HEAT	29	23	7	35	33	13	7	22	14	29	14	44	44	46	46	29	28	19	70	17	64	64	64	64
RM GAIN MBH.	1.67	0.81	0.09	2.15	2.20	0.31	0.09	0.84	0.91	1.67	0.91	2.13	1.72	2.28	2.28	1.39	2.10	0.31	1.47	0.13	0.32	0.32	0.32	0.32
CFM PER RUN COOLING	53	26	3	69	70	10	3	27	29	53	29	68	55	73	73	44	67	10	47	4	10	10	10	10
ADJUSTED PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	35	55	25	46	61	44	44	46	30	46	34	19	17	24	32	35	29	39	38	21	23	30	33	5
EQUIVALENT LENGTH	150	190	180	130	160	200	150	120	170	180	200	100	170	120	140	100	180	150	100	130	150	120	140	80
TOTAL EFFECTIVE LENGTH	185	245	205	176	221	244	194	166	200	226	234	119	187	144	172	135	209	189	138	151	173	150	173	85
ADJUSTED PRESSURE	0.08	0.06	0.07	0.08	0.07	0.06	0.08	0.09	0.07	0.06	0.06	0.12	0.08	0.1	0.08	0.11	0.07	0.08	0.11	0.1	0.08	0.1	0.08	0.17
ROUND DUCT SIZE	5	4	4	6	6	4	4	4	4	5	6	5	5	6	6	4	6	4	5	4	5	5	5	5
HEATING VELOCITY (ft/min)	213	264	80	178	168	149	80	252	161	213	71	323	323	235	235	333	143	218	514	195	470	470	470	470
COOLING VELOCITY (ft/min)	389	298	34	352	357	115	34	310	333	389	148	499	404	372	372	505	342	115	345	46	73	73	73	73
OUTLET GRILL SIZE	3X10	3X10	3X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	4X10	4X10	3X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10
TRUNK	A	B	C	E	D	B	E	E	E	A	B	C	C	A	A	B	C	D	D	E	A	B	B	C

RUN #	25	26	27	28	29	30	31	32
ROOM NAME	BAS	BED-3	BED-4	ENS	FAM	WIC-2	BAS	S-ENS
RM LOSS MBH.	3.25	1.77	1.67	1.18	1.46	1.25	3.25	0.34
CFM PER RUN HEAT	64	35	33	23	29	25	64	7
RM GAIN MBH.	0.32	2.15	2.20	0.81	1.39	0.87	0.32	0.09
CFM PER RUN COOLING	10	69	70	26	44	28	10	3
ADJUSTED PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	15	50	55	49	26	46	40	31
EQUIVALENT LENGTH	90	140	180	160	160	130	140	150
TOTAL EFFECTIVE LENGTH	105	190	235	209	186	176	180	181
ADJUSTED PRESSURE	0.14	0.08	0.06	0.07	0.08	0.08	0.08	0.08
ROUND DUCT SIZE	5	6	6	4	5	4	5	4
HEATING VELOCITY (ft/min)	470	178	168	264	213	287	470	80
COOLING VELOCITY (ft/min)	73	352	357	298	323	321	73	34
OUTLET GRILL SIZE	3X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10
TRUNK	C	E	D	B	A	D	D	E



SUPPLY AIR TRUNK SIZE

DUCT FET AIR TRUNK SIZE							DUCT FET AIR TRUNK SIZE								
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		
TRUNK A	243	0.06	8.9	12	x	8	365	TRUNK G	0	0.00	0	0	x	8	0
TRUNK B	473	0.06	11.4	16	x	8	532	TRUNK H	0	0.00	0	0	x	8	0
TRUNK C	724	0.06	13.4	20	x	8	652	TRUNK I	0	0.00	0	0	x	8	0
TRUNK D	244	0.06	8.9	10	x	8	439	TRUNK J	0	0.00	0	0	x	8	0
TRUNK E	381	0.06	10.5	14	x	8	490	TRUNK K	0	0.00	0	0	x	8	0
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0

RETURN AIR TRUNK SIZE

TYPE	TRUNK	STATIC	ROUND	RECT		VELOCITY	
(ft/min)	CFM	PRESS.	DUCT	DUCT		(ft/min)	
TRUNK O	0	0.05	0	0	x	8	0
TRUNK P	0	0.05	0	0	x	8	0
TRUNK Q	0	0.05	0	0	x	8	0
TRUNK R	0	0.05	0	0	x	8	0
TRUNK S	0	0.05	0	0	x	8	0
TRUNK T	0	0.05	0	0	x	8	0
TRUNK U	0	0.05	0	0	x	8	0
TRUNK V	0	0.05	0	0	x	8	0
TRUNK W	0	0.05	0	0	x	8	0
TRUNK X	1142	0.05	16.6	32	x	8	642
TRUNK Y	582	0.05	12.9	20	x	8	524
TRUNK Z	255	0.05	9.5	10	x	8	459
DROP	1142	0.05	16.6	24	x	10	685

RETURN AIR #	1	2	3	4	5	6	7	8								BR
AIR VOLUME	90	85	85	85	88	327	105	85	0	0	0	0	0	0	0	192
PLENUM PRESSURE	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12	0.12
ACTUAL DUCT LGH.	28	56	75	52	48	30	14	48	1	1	1	1	1	1	1	14
EQUIVALENT LENGTH	215	210	200	195	175	185	135	215	0	0	0	0	0	0	0	220
TOTAL EFFECTIVE LH	243	266	275	247	223	215	149	263	1	1	1	1	1	1	1	234
ADJUSTED PRESSURE	0.05	0.05	0.05	0.05	0.06	0.06	0.08	0.05	12.40	12.40	12.40	12.40	12.40	12.40	12.40	0.05
ROUND DUCT SIZE	6.4	6	6	6	6	9.9	6	6	0	0	0	0	0	0	0	8.5
INLET GRILL SIZE	8	8	8	8	8	8	8	8	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	30	14	14	0	0	0	0	0	0	0	24

CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024

RECEIVED
Per: joshua.nabua

TYPE: ROSE 6
SITE NAME: TRINIGROUPLO # 102628
OPT 5 BED

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES	9.32.3.1(1)
a) ☒ Direct vent (sealed combustion) only	
b) ☐ Positive venting induced draft (except fireplaces)	
c) ☐ Natural draft, B-vent or induced draft gas fireplace	
d) ☐ Solid Fuel (including fireplaces)	
e) ☐ No Combustion Appliances	

HEATING SYSTEM
☒ Forced Air ☐ Non Forced Air
☐ Electric Space Heat

HOUSE TYPE	9.32.1(2)
☒ I Type a) or b) appliance only, no solid fuel	
☐ II Type I except with solid fuel (including fireplaces)	
☐ III Any Type c) appliance	
☐ IV Type I, or II with electric space heat	
☐ Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS	O.N.H.W.P.
☐ 1 Exhaust only/Forced Air System	
☐ 2 HRV with Ducting/Forced Air System	
☒ 3 HRV Simplified/connected to forced air system	
☐ 4 HRV with Ducting/non forced air system	
☐ Part 6 Design	

TOTAL VENTILATION CAPACITY	9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm <u>42.4</u> cfm
Other Bedrooms	<u>3</u> @ 10.6 cfm <u>31.8</u> cfm
Kitchen & Bathrooms	<u>6</u> @ 10.6 cfm <u>63.6</u> cfm
Other Rooms	<u>6</u> @ 10.6 cfm <u>63.6</u> cfm
Table 9.32.3.A.	TOTAL <u>201.4</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED	9.32.3.4.(1)
1 Bedroom	31.8 cfm
2 Bedroom	47.7 cfm
3 Bedroom	63.6 cfm
4 Bedroom	79.5 cfm
5 Bedroom	95.4 cfm
TOTAL	79.5 cfm

SUPPLEMENTAL VENTILATION CAPACITY	9.32.3.5.
Total Ventilation Capacity	<u>201.4</u> cfm
Less Principal Ventil. Capacity	<u>79.5</u> cfm
Required Supplemental Capacity	<u>121.9</u> cfm

PRINCIPAL EXHAUST FAN CAPACITY
Model: VANEE V150H Location: BSMT
☒ HVI Approved
PRINCIPAL EXHAUST HEAT LOSS CALCULATION
CFM ΔT °F FACTOR % LOSS
79.5 CFM X 78 F X 1.08 X 0.25

SUPPLEMENTAL FANS	BY INSTALLING CONTRACTOR
Location Model cfm HVI Sones	
ENS BY INSTALLING CONTRACTOR 50 ✓ 3.5	
S-ENS BY INSTALLING CONTRACTOR 50 ✓ 3.5	
ENS-4 BY INSTALLING CONTRACTOR 50 ✓ 3.5	
PWD BY INSTALLING CONTRACTOR 50 ✓ 3.5	

HEAT RECOVERY VENTILATOR	9.32.3.11.
Model: VANEE V150H	
150 cfm high 35 cfm low	
75 % Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved

LOCATION OF INSTALLATION
Lot: Concession
Township Plan:
Address
Roll # Building Permit #

BUILDER:	GREENPARK HOMES
Name:	
Address:	
City:	
Telephone #: Fax #:	

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #: Fax #:	


DESIGNER CERTIFICATION
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.
Name: HVAC Designs Ltd.
Signature: <i>Michael O'Rourke</i>
HRAI # 001820
Date: September-23

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669 MICHAEL O'ROURKE*Michael O'Rourke*CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024

RECEIVED
Per: joshua.nabua

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 102628		Model: ROSE 6		Builder: GREENPARK HOMES																																																								
				Date: 9/25/2023																																																								
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>1399</td> <td>9</td> <td>11891.5</td> </tr> <tr> <td>First</td> <td>1399</td> <td>10</td> <td>14129.9</td> </tr> <tr> <td>Second</td> <td>1789</td> <td>9</td> <td>16279.9</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>42,301.3 ft³</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>1197.8 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	1399	9	11891.5	First	1399	10	14129.9	Second	1789	9	16279.9	Third	0	9	0	Fourth	0	9	0	Total:			42,301.3 ft³	Total:			1197.8 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 70%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 30%;">0.354</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.110</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-21</td> <td>43</td> <td>78</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>31</td> <td>7</td> <td>13</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.354	SUMMER NATURAL AIR CHANGE RATE	0.110	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-21	43	78	Summer DTDc	24	31	7	13
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	1399	9	11891.5																																																									
First	1399	10	14129.9																																																									
Second	1789	9	16279.9																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			42,301.3 ft³																																																									
Total:			1197.8 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.354																																																											
SUMMER NATURAL AIR CHANGE RATE	0.110																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-21	43	78																																																								
Summer DTDc	24	31	7	13																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.354 x 332.73 x 43 °C x 1.2 = 6105 W = 20831 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.110 x 332.73 x 7 °C x 1.2 = 313 W = 1069 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 78 °F x 1.08 x 0.25 = 1670 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 80 CFM x 13 °F x 1.08 x 0.25 = 275 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level\ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$ <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Level Factor (LF)</th> <th>HLairve Air Leakage + Ventilation Heat Loss (Btu/h)</th> <th>Level Conductive Heat Loss: (HL_{clevel})</th> <th>Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>0.5</td> <td rowspan="5" style="text-align: center; vertical-align: middle;">20,831</td> <td>9,095</td> <td>1.145</td> </tr> <tr> <td>2</td> <td>0.3</td> <td>12,389</td> <td>0.504</td> </tr> <tr> <td>3</td> <td>0.2</td> <td>14,342</td> <td>0.290</td> </tr> <tr> <td>4</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> <tr> <td>5</td> <td>0</td> <td>0</td> <td>0.000</td> </tr> </tbody> </table> *HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0					Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)	1	0.5	20,831	9,095	1.145	2	0.3	12,389	0.504	3	0.2	14,342	0.290	4	0	0	0.000	5	0	0	0.000																														
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	20,831	9,095	1.145																																																								
2	0.3		12,389	0.504																																																								
3	0.2		14,342	0.290																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								

Michael O'Rourke
BCIN# 19669


HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: ROSE 6	OPT 5 BED	BUILDER: GREENPARK HOMES
SFQT: 3175	LO# 102628	SITE: TRINIGROUP

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-6	OUTDOOR DESIGN TEMP.	88
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.60

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	3.57	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	AVERAGE	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft³):	42301.3	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	5
INTERIOR LIGHTING LOAD (Btu/h/ft²):	1.80	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	5.5 ft
LENGTH: 58.0 ft	WIDTH: 31.0 ft	EXPOSED PERIMETER:	178.0 ft

2012 OBC - COMPLIANCE PACKAGE

Component

Compliance Package A1

Nominal	Min. Eff.
---------	-----------

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22	17.03
Basement Walls Minimum RSI (R)-Value	20 ci	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	0.28	-
Skylights Maximum U-Value	0.49	-
Space Heating Equipment Minimum AFUE	96%	-
HRV/ERV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.8	-

INDIVIDUAL BCIN: 19669
MICHAEL O'ROURKE




CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024

RECEIVED
Per: joshua.nabua

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Richmond Hill	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	17.7	 Insulation Configuration
Floor Width (m):	9.4	
Exposed Perimeter (m):	0.0	
Wall Height (m):	2.6	
Depth Below Grade (m):	1.68	
Window Area (m ²):	0.6	
Door Area (m ²):	2.0	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		1791

TYPE: ROSE 6
LO# 102628

OPT 5 BED

Michael O'Rourke BCIN #19669

CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024


RECEIVED
Per: joshua.nabua

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Richmond Hill			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.68			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1197.8			
Air Leakage/Ventilation				
Air Tightness Type:	Present (1961-) (3.57 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1596.8 cm ²		
	3.57	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	37.5	37.5		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.354			
Cooling Air Leakage Rate (ACH/H):	0.110			

TYPE: ROSE 6
LO# 102628

OPT 5 BED

Michael O'Rourke BCIN# 19669



CITY OF RICHMOND HILL
BUILDING DIVISION

05/01/2024




RECEIVED
Per: joshua.nabua

SUPPLEMENTAL EXHAUST FAN (MINIMUM 100 CFM) DISCHARGING DIRECTLY TO THE EXTERIOR WILL BE PROVIDED IN THE KITCHEN. EXHAUST DUCTS SERVING THE KITCHEN SHALL NOT BE SMALLER THAN RECOMMENDED BY THE MANUFACTURER OF THE FANS AND MUST AT LEAST MEET O.B.C. STATED MINIMUMS.

1. Laundry dryer exhaust duct shall be provided as per OBC 2012 Div.B 6.2.3.8(7).
2. Kitchen hood exhaust duct shall be provided as per OBC 2012, Div.B 9.32.3.10, 9.32.3.5(2).
3. Minimum R-12 Insulation Value required for ducts installed at unheated or exposed condition (OBC 2012 Div.B 6.2.4.3(10) and seal the ducts as per 6.2.4.3(11) & HRAI Digest 2005, Clause 4.5.
4. Penetration of Air Barrier System by ducts, wires, conduits or building materials shall be sealed as per OBC 2012, Div.B 9.25.3.3.(9) & (10).
5. Volume control dampers to all branches to be installed per OBC 2012, Div.B, 6.2.4.5.
6. Space between studs and joists used as return ducts shall be separated from unused portion as per OBC 2012 Div.B 6.2.4.7(6)





10. Supply air grill at finished basement shall be at low level. Return air grill for finished or unfinished basement shall be at low level. HRAI digest 2005, clause 7.7(3).



13. Exterior insulation effective R-Value for wall, roof or exposed floor shall be maintained at the respective location where duct or sanitary pipes are routed inside exterior envelope.

14. Return air intake shall be provided as recommended in HRAI Digest 2005 Section 4.7 Return air inlet should be positioned so that short circuiting of supply air is avoided. A high and low wall return air combination shall be provided when a combined cooling & heating system is installed.

15. For simplified HRV/ERV installation, with stale air and fresh air connected to return air plenum, stale air intake and fresh air supply shall be separated minimum 3' or as recommended by HRV/ERV Manufacturer.



HEAT LOSS 59406 BTU/H UNIT DATA		# OF RUNS	S/A	R/A	FANS
MAKE	GOODMAN	3RD FLOOR			
MODEL	GMCE960803BNA	2ND FLOOR	16	6	5
INPUT	80.0 MBTU/H	1ST FLOOR	10	2	2
OUTPUT	76.8 MBTU/H	BASEMENT	6	1	0
COOLING	3.0 TONS	ALL S/A DIFFUSERS 4 "x10" UNLESS NOTED OTHERWISE ON LAYOUT. ALL S/A SENSORS 5'Ø UNLESS NOTED OTHERWISE ON LAYOUT. UNDERCUT DOORS 1" min. FOR R/A			
FAN SPEED	1142 cfm @ 0.6" w.c.				

 City of Richmond Hill
Building Division

REVIEWED

By: **PV** Date: **May/28/2024**

Building Permit #: RM#-24-00020

All construction shall comply with the Ontario Building Code and all other applicable statutory regulations. The reviewed documents must be kept on site at all times.

Building inspection line: 905-771-5465 (24 hr)
buildinginspectors@richmondhill.ca
Building inquiry line 905-771-8810
building@richmondhill.ca

Ensure that R-Values and U-Values used for heat loss and heat gain calculations are consistent with the values specified by SB-12 Prescriptive Package: [A1](#) and the values used for architectural design.

HVAC LEGEND	
	SUPPLY AIR GRILLE
	SUPPLY AIR GRILLE 6" BOOT
	LINEAR BAR or LINEAR SLOT GRILLE
	SUPPLY AIR BOOT ABOVE
	6" SUPPLY AIR BOOT ABOVE
	SUPPLY AIR STACK
	6" SUPPLY AIR STACK
	14X8 RETURN AIR GRILLE
	30X8 RETURN AIR GRILLE
	FLOOR RETURN AIR GRILLE
	RETURN STACK ABOVE
	RETURN AIR STACK
	REDUCER
	SUPPLY DUCTWORK
	RETURN DUCTWORK
	FLEX DUCT
	EXHAUST FAN
	LMT TRAP by REVERSOMATIC
DV	DIRECT VENT
LW	LOW WALL
HW	HIGH WALL
CLG.	CEILING
Z.D.	MOTORIZED ZONE DAMPER
M.D.	MOTORIZED DAMPER
	EXHAUST PIPE
	CONCENTRIC VENT KIT
	CONCENTRIC HRV or ERV VENT KIT
	SINGLE WALL BOX by REVERSOMATIC
	DOUBLE WALL BOX by REVERSOMATIC
	TRIPLE WALL BOX by REVERSOMATIC
	DRYER BOOSTER FAN

2			
1	ISSUED FOR PERMIT	SEPT/23	YV
No.	Revision	Date	By
SB-12 PACKAGE		A1	
I Michael O'Rourke have reviewed and take responsibility for the design work and am qualified under division C.3.2.5 of the building code.		 Michael O'Rourke BCIN # 19969 HVAC Designs Ltd.	

HVAC DESIGNS LTD.
375 Finley Ave - Unit 202 - Ajax, Ontario L1S 2E2
Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdsgns.ca
Web: www.hvacdsgns.ca
Specializing in Residential Mechanical Design Services

Client	GREENPARK HOMES		
Project Name	TRINIGROUP RICHMOND HILL, ONTARIO ROSE 6 - OPT 5 BED 3175 SQFT		
Copyright & Copy: © 2023 HVAC Designs Ltd.			
Sheet Title	HVAC	HEATING LAYOUT	
Drawn By	YV	Checked By	YV
Scale	3/16"=1'-0"		Sheet No.
Date	SEPTEMBER 2023		05/01/2023
LO #	102628		1