Enrollment:

Purchaser Name: Thanenthiran Loganathan

Andrea Thanenthiran

Phone: (647) 701-2589
Phone: (647) 720-0448

Closing Date: November 30, 2020
Inspector: Chris Bergman



Quality Control

Vendor/Builder No.: 39348

Vendor: Lormel Developments (Bradford) Ltd

Municipality: Town of Bradford West Gwillimbury

Lot/Phase: 112 / 2

51M-1087

Address: 231 Chelsea Crescent

Inspection Date: August 16, 2021

Page 1 of 2

Please list below any damaged, incomplete, or missing items and anything that is not in good operating condition. Also note any (substitutions) of items referred to in, or to be selected under, the Agreement of Purchase and Sales (APS). Please initial all changes and deletions. As a minimum, check the following:

DAMAGED, INCOMPLETE OR MISSING

- Windows, side lights and other glazing. Window and door screens
- Bathtub sinks and toilets
- · Bathroom accessories if provided
- Mirrors, counter tops and cabinetry
- Flooring (hardwood, vinyl, ceramic tiles, carpeting)
- Interior finished and trim carpentry
- Furnace
- Hot water heater, if provided (not rental)
- Exterior finished, driveways, walkways, decks and landscaping

OPERATING CONDITION

- Windows, interior and exterior doors. Door locks
- Faucets: Kitchen, bathroom, laundry room
- Exhaust fans (kitchen, bathrooms) if provided
- · Electrical outlets and fixtures
- Gas fireplaces, incl.circulation fans, if provided
- Heat Recovery Ventilation system, if provided
- Heating system
- Hot water heater, if provided (not rental)
- Air conditioning system, if provided and if conditions permit

EXTERIOR SEASONAL		
NOTE:	PAINT LINTELS.	
	SOFFIT INCOMPLETE AT COLUMNS ON FRONT PORCH, AND 2ND FLOOR BALCONY.	
	CAULK BACK PATIO DOORS	
	SEE GAP BETWEEN TOP OF BACK PATIO DOORS AND LINTELS.	
POWDER ROOM		
NOTE:	PAINT DOOR.	
FAMILY ROOM		
NOTE:	COLD AIR RETURN NOT SECURED TO WALL.	
FOYER/HALL		
NOTE:	DOOR STOPPER MISSING	

Enrollment:

Date (YYYY/MM/DD)

Purchaser Name: Thanenthiran Loganathan

Andrea Thanenthiran

2021/08/16

 Phone Res:
 (647) 701-2589

 Phone Bus:
 (647) 720-0448

 Closing Date:
 November 30, 2020

 Inspector:
 Chris Bergman



Quality Control

Vendor / Builder: 39348

Project: Lormel Developments (Bradford) Ltd

Lot / Phase: 112 / 2 Plan: 51M-1087

Address: 231 Chelsea Crescent

Municiaplity: Town of Bradford West Gwillimbury
Inspection Date: August 16, 2021

Page 2 of 2

LAUNDRY ROOM		
WALLS/DOORS	BASEBOARD MISSING	
FLOORING	GROUT AROUND GAS LINE.	
KITCHEN		
NOTE:	INSTALL ELECTRICAL COVER PLATES ON BACKSPLASH.	
GENERAL COMMENTS		
NOTE:	TOUCH UPS REQUIRED THROUGH OUT AS INDICATED	
	INSTALL AIR REGISTERS	
	CAULK BATHROOM ACCESSORIES WHERE REQUIRED.	
	CLEAN PAINT FROM FLOOR WHERE REQUIRED.	
LIVING ROOM		
WALLS/DOORS	PAINT COLUMNS AND CASINGS	
NOTE:	COLD AIR RETURN NOT SECURED TO WALL.	
BASEMENT		
COLD ROOM	INSTALL PASSAGE SET. SEE CUT OUT FOR DEADBOLT.	

THE COMPLETED PRE-DELIVERY INSPECTION IS A FORMAL RECORD OF THE HOME'S CONDITION BEFORE THE PURCHASER TAKES POSSESSION IT WILL BE USED AS A REFERENCE FOR FUTURE WARRANTY REQUESTS. * Purchasers or owners who intend to designate someone to conduct the PDI in their place should ensure they provide written authority to the vendor/builder authorizing the designate to sign this form on their behalf. I have inspected my new home and I agree that the description of the items listed on this form are accurate. Thanenthiran Loganathan Andrea Thanenthiran Purchaser's Name (print) Purchaser's Name (print) Purchaser's Signature Purchaser's Signature Chris Bergman Designate's Name (print) Designate's Signature Inspector's Name (print) Inspector's Signature

August 16, 2021