

☐ NEW SUBMISSION ☐ RE-SUBMISSION ☐ MODEL CHANGE ☐ MODEL CHANGE PERMIT #

LEGEND

Finish Floor
Top Of Foundation
U.S.F.
U.S.F.
Min. Underside Of Footing
Drainage/Swale Direction
Terracing 3H to 1V (max.)
Service Location
Proposed Grade
Existing Grade
Driveway & Slope Direction
Grade Percentage
Major Storm Flow Direction
Property Line

Catch Basin
Utility Drop Locations
PROPOSED ROGERS CABLE PEDESTAL
EXISTING ROGERS CABLE PEDESTAL
PROPOSED TRANSFORMER
EXISTING TRANSFORMER
PROPOSED BELL PEDESTAL
EXISTING BELL PEDESTAL
PROPOSED STREETLIGHT C/W
BRACKET AND NUMBER
PROPOSED STREETLIGHT DISCONNECT
SANITARY, STORM AND WATER
SERVICE LOCATIONS



F.P. bumpout within 1.2m
requires 3/4HR FRR.

Provide P.ENG soils
report to inspector
confirming assumed
design bearing capacity.

City of Ottawa
Building Services Branch

REVIEWED
By Thomas at 8:15 am, Jan 10, 2012

Signature
Building Code Reviewed

CARLINE THOMAS

City of Ottawa
Building Services Branch

REVIEWED
By Thomas at 3:51 pm, Jan 12, 2012

Zoning Reviewed

Signature
C. Thomas

Owner/Applicant

DCR/PHOENIX HOMES

Telephone # 723-9227

Plan # 4M-

Lot # 17 STRANDHERD MEADOWS

Block # Unit #

Conc. #

Civic Address: 344 BAMBURGH WAY

Bldg. Ht. m

Lot coverage 35.71 %

Scale 1:250

ELEVATIONS

Step footings N/A m

Underside footing SEE ABOVE m

Top of foundation SEE ABOVE m

CHECKED/APPROVED BY: T.L.MAK ENG.
MAY 2011
REV.1 SEP26-11
REV.2 OCT26-11

LOT 17 SITE/GRADING PLAN STRANDHERD MEADOWS PH5

PLEASE NOTE: THIS APPLICATION EXPIRES 6(SIX) MONTHS
AFTER DATE RECEIVED

Application No:

OFFICE USE ONLY: Civic Address:

Circ Date	Circ Date	Circ Date
Works Division Approval Date:	Zoning Approval Date:	UP0 Approval Date:

APPLICATION RECEIVED