

Customer Service Phone: (705) 721-9912 Fax: (705) 735-6991

Address: 2203 Batters Loop - Innisfil

Location: Maple Walk By the Brook - Phase: MWI - Lot: 179

Today's Date: 08Mar10

Contact Name(s): Joshua T. Bell and Kory A. Urquiza
Contact Phone No.: Res: (705) 431-9041 Bus: Bus2: Cell:

Company: D and S Electric Inc.

Attention:

Telephone: (705) 735-3443 **Fax:** (705) 735-0399

Please Complete the following items:

Deficiency Number	Issue	Appt. Date/Time	Notes
933	Basement- Water is leaking in through the hydro conduit into the basement behind the hydro panel. The water is not coming in through the foundation. It is leaking in through a loose coupling in the conduit. Call Josh at 416-358-4045 ASAP.		

Date Completed:	 Homeowner Signature:	
_ a.to _ op.o.to a		

Please schedule service to complete the work described above within two weeks of receipt of this Work Order. It is your responsibility to book your own appointment unless we have included appointment details on this form.

Your Service Person must ask the homeowner to sign this form when the work has been completed. If the owner is not available to sign this Work Order, the person who completes the work should sign and date the form. Fax the completed Work Order to us at 705-735-6991.

In the event that you do not complete this service work within 14 days, Pratt Homes reserves the right to carry out the repairs on your behalf and the labour and material costs may be billed back to you plus a 15% administrative fee.