

Lot 32 MW  
1521 Rankin Way



OCT 14 2008

## Pre-Delivery Inspection Form

Please list below any damaged, incomplete, or missing items and anything that is not in good operating condition. Also note any "substitutions" of items referred to in, or to be selected under, the Agreement of Purchase and Sale (APS). Please initial all changes and deletions. As a minimum check the following:

DAMAGED, INCOMPLETE OR MISSING	OPERATING CONDITION
<ul style="list-style-type: none"> <li>Windows, side lights and other glazing. Window and door screens</li> <li>Bathtubs, sinks and toilets</li> <li>Bathroom accessories, if provided</li> <li>Mirrors, countertops and cabinetry</li> <li>Flooring (hardwood, vinyl, ceramic tiles, carpeting)</li> <li>Interior finishes and trim carpentry</li> <li>Furnace</li> <li>Hot water heater, if provided (not a rental)</li> <li>Exterior finishes, driveways, walkways, decks and landscaping are complete</li> </ul>	<ul style="list-style-type: none"> <li>Windows, interior and exterior doors (including garage overhead door). Door locks</li> <li>Faucets: kitchen, bathroom, laundry room</li> <li>Exhaust fans (kitchen, bathrooms), if provided</li> <li>Electrical outlets and fixtures</li> <li>Gas fireplaces, incl. circulation fans, if provided</li> <li>Heat Recovery Ventilation system, if provided</li> <li>Heating system</li> <li>Hot water heater, if provided (not a rental)</li> <li>Air conditioning system, if provided and if conditions permit</li> </ul>

Comments - *DOORLESS DOORS TO BE PAINTED - DAUGLASS*

Item #	Room/Location	Description
1	EXTERIOR	BRICK & MORTAR TOUCH-UPS
2	EXTERIOR	ELECTRICAL CONDUIT @ FOUNDATION NEEDS TO BE PAINTED, #0SB NEEDS TO BE TERMIMATED.
3	EXTERIOR	CLEANING, PAVED DRIVEWAY, GRADING, SOD, ELECTRICAL, PAINTING, NOT INSPECTED
4	EXTERIOR	GAS LINE BRACKET NOT FASTENED (BRACKET LOOSE @ ELBOW)
5	INTERIOR / UTILITY ROOM	FILTER TO BE REPLACED
6	UTILITY Room	THOSE B1/B3 TURN OFF. (SPIDER / TOUGHUP REQUIREMENTS)
7	INTERIOR	ELECTRICAL NOT COMPLETE
8	INTERIOR	@ WALLS TO BE PAINTED.
9	INTERIOR	PAINTING, FLOORING, TRIM, DOORS, HARDWARE, PUNTING'S NOT COMPLETE.
10	INTERIOR	VENTS NOT INSPECTED
11	INTERIOR	CEILING TO BE STRAIGHT
12	M. BATH	COULD NOT INSPECT BATH TUB.
13	INTERIOR	CARPET NOT INSTALLED.
14	INTERIOR	NO MEDICINE CABINET.
15	BREAK ROOM.	WINDOW OFF TRACK
16	GREEN ROOM	WINDOW NEEDS ADJUSTMENT - WILL NOT LOCK
17	INTERIOR	HOUSE NOT CLEANED
18	EXTERIOR	CAULKING NOT COMPLETED
19	INTERIOR	VENTS NOT CLEANED
20	KITCHEN	VENT DOESN'T FIT FUSK TO FLOOR
21	INTERIOR	PHONE JACKS / TELEPHONE CABLE COVERS MISSING.
22	INTERIOR	SUMMERS, BLINDS & MIRRORS NOT INSTALLED
23	INTERIOR	COULD NOT TEST FIRE ALARM.