Page 1 of 1



**PDI** Page 1 of 1

83290

Vendor/Builder#

Purchaser Name: Phone Res:

Indra Jaipargas (416) 414-5620

Phone Bus : Closing Date: Inspector:

2013-06-27 Bruno Tidd

Legal Address: Project:

Plan #: Lot / Phase #: Municiaplity:

Enrollment#

DLS[19]

SWD-00063 / 1

H Hansen Development Inc.

Inspection Date: 22 Jun 2013

Please list below any damaged, incomplete, or missing items and anything that is not in good operating condition.

Also note any (substitutions) of items referred to in, or to be selected under, the Agreement of Purchase and Sales (APS). Please initial all changes and deletions. As a minimum, check the following:

DAMAGED, INCOMPLETE OR MISSING

• Windows, side lights and other glazing. Window and door screens

- · Bathtub sinks and toilets
- Bathroom accessories if provided

  Mirrors, counter tops and cabinetry
- Flooring (hardwood, vinyl, ceramic tiles, carpeting)
   Interior finished and trim carpentry
- · Furnace
- · Hot water heater, if provided (not rental)
- · Exterior finished, driveways, walkways, decks and landscaping

**OPERATING CONDITION** 

· Windows, interior and exterior doors including garage overhead doors, door locks

· Faucets: Kitchen, bathroom, laundry room


· Exhaust fans (kitchen, bathrooms) if provided · Electrical outlets and fixtures

Gas fireplaces, incl.circulation fans, if provided
 Heat Recovery Ventilation system, if provided

Heating system
 Hot water heater, if provided (not rental)
 Air conditioning system, if provided and if conditions permit

Also list here anything that can't be assessed because for example is dirty or inaccessible

GENERAL COMMENTS		
INSPECTION START TIME NOTE:	INSPECTION STARTED AT 9:35 A.M.  TOUCH UPS REQUIRED THROUGH OUT AS INDICATED. UNIT NEEDS A RECLEAN. TRADES IN AFTERINITIAL CLEANING. LAMINATE FLOOR AND COUNTERTOPS IN PARTICULAR.	 <del></del>
NEW TELEPHONE NUMBER	** PURCHASER HAS A NEW PHONE NUMBER -416-414-5620	 
LIVING ROOM		 —·
TRIM	NOTE COMPLETED IN CORNER BY CLOSET AND ALCOVE. DOOR TO BASEMENT DOES NOT CLOSE.	
KITCHEN		 
WALLS	CEILING NOT PAINTED PROPERLY.	
CABINETS	PURCHASER FEELS THAT THE HANDLES ARE THE WRONG COLOURS.	
POWDER ROOM		 
TRIM	BASEBOARD AND 1/4 ROUND. NOT COMPLETED.AND PATCHY	
BASEMENT		 
FURNACE	HEATING DUCT HAS FALLEN AND IS HANGING LOOSELEY OFF THE FURNACE.	 



THE COMPLETED PRE-DELIVERY INSPECTION IS A FORMAL RIPOSSESSION IT WILL BE USED AS A REFERENCE FOR FUTURE * Purchasers or owners who intend to designate someone to conduct the authorizing the designate to sign this form on their behalf.  Builder Representative	WARRANTY REQUESTS	
Designate's Name(please print)  I the homeowner, confirm that all repair work listed has been completed	Designate's Signature	
	Purchaser	Date

31001-PDIF-01.01