
FAX TRANSMISSION

To: Pratt Hansen Group Inc.
From: Pratt Homes
Subject: Work order Re: Sunnidale Vistas - SUN - Common Elements - Marnoch Electric Ltd.

Message: Please schedule repairs asap. Thankyou Ramona



Pratt Hansen Group
Customer Service
Phone: (705) 792-3883
Fax: (705) 792-3893

Work Order

Address: -
Location: Sunnidale Vistas - Phase: SUN - Lot: Common Elements
Today's Date: 22Dec10
Contact Name(s):
Contact Phone No.: Res: Bus: Bus2: Cell:
Company: Marnoch Electric Ltd.
Attention:
Telephone: (705) 431-7888
Fax: (705) 436-7691

Please Complete the following items:

Deficiency Number	Issue		Appt. Date/Time	Notes
4183	Attic- 39 Coulter south end attic - Junction box in attic is missing a cover.			
4184	Foyer- 41 Coulter - back entry - The automatic door opener at the top of the exterior door is mounted lower than the top of the door opening. There must be at least 75" clearance between the floor and the top of the opening. This opener must be relocated to provide the minimum opening size.			
4185	Other- 41 Coulter - Storage room S17 to S24 - Supply and install a cover on the smoke detector that is missing.			

Date Completed: _____

Homeowner Signature: _____

Please schedule service to complete the work described above within two weeks of receipt of this Work Order. It is your responsibility to book your own appointment unless we have included appointment details on this form.

Your Service Person must ask the homeowner to sign this form when the work has been completed. If the

owner is not available to sign this Work Order, the person who completes the work should sign and date the form. Fax the completed Work Order to us at 705-735-6991.

In the event that you do not complete this service work within 14 days, Pratt Homes reserves the right to carry out the repairs on your behalf and the labour and material costs may be billed back to you plus a 15% administrative fee.