



**UNITED ENGINEERING INC**  
Mechanical and Electrical Consulting Engineers

3645 Keele St. #105  
Toronto, ON, M3J 1M6  
Email: info@u-eng.ca  
T: (416) 398-1999  
F: (416) 398-1933

## SITE INSTRUCTION

PROJECT: HAMPTON MANOR  
25 BAKER HILL BLVD  
STOUFFVILLE, ONTARIO

PROJECT NO: 14-016

CONTRACT: Electrical

DATE October 04, 2016

SITE INSTRUCTION: E-2

---

THIS SITE INSTRUCTION IS NOT TO BE CONSTRUED AS A CHANGE IN THE CONTRACT PRICE, BUT IS ISSUED FOR CLARIFICATION ONLY. IF A CHANGE IN CONTRACT PRICE IS PERCEIVED, PROVIDE AN ITEMIZED BREAKDOWN OF ANY EXTRAS OR CREDITS WITHIN SEVEN (7) WORKING DAYS.

**Purpose:** Clarifications.

**1.0 Reference Drawing E-4A & E-4B (2nd Floor) Issued**

- 1.1 Clarify: Top of stair smoke detector and speaker c/w fire alarm zone to be on 2<sup>nd</sup> floor.

**2.0 Reference Drawing E-5A & E-5B (3<sup>rd</sup>-5<sup>th</sup> Floor) Issued**

- 2.1 Revise: Top of stair smoke detector and speaker c/w fire alarm zone to be on the 5<sup>th</sup> floor.

**3.0 Reference Drawing E-7A & E-7B (7<sup>th</sup> Floor) Issued**

- 3.1 Delete: Top of stair smoke detector and speaker c/w fire alarm zone.

**4.0 Reference Drawing E-10 (Riser Diagrams) Issued**

- 4.1 Revise: Location of top of stair smoke detectors and speakers c/w fire alarm zone.

Site Instruction #E-2  
25 Baker Hill Blvd.

---

PREPARED BY:   
Chula Meksavanh  
Electrical Department

ISSUED TO ROYAL PINE HOMES,  
FRANK CAROGIOIELLO, [frank@royalpinehomes.com](mailto:frank@royalpinehomes.com);  
LOUIE PANTALEO, [Louie@royalpinehomes.com](mailto:Louie@royalpinehomes.com);  
KELLY WATSON, [Kelly@royalpinehomes.com](mailto:Kelly@royalpinehomes.com)  
FOR DISTRIBUTION TO ALL AFFECTED PARTIES.

cc. GRAZIANI + CORAZZA ARCH. INC.,  
GINO COLANGELO, [GColangelo@gc-architects.com](mailto:GColangelo@gc-architects.com)  
DINEEN CONSTRUCTION CORP., RIC WIGHT, [rwight@dineen.com](mailto:rwight@dineen.com)