



**UNITED ENGINEERING INC**  
Mechanical and Electrical Consulting Engineers

3645 Keele St. #105  
Toronto, ON, M3J 1M6  
Email: info@u-eng.ca  
T: (416) 398-1999  
F: (416) 398-1933

## SITE INSTRUCTION

PROJECT: HAMPTON MANOR  
25 BAKER HILL BLVD  
STOUFFVILLE, ONTARIO

PROJECT NO: 14-016

CONTRACT: Electrical

DATE September 12, 2017

SITE INSTRUCTION: E-10

---

THIS SITE INSTRUCTION IS NOT TO BE CONSTRUED AS A CHANGE IN THE CONTRACT PRICE, BUT IS ISSUED FOR CLARIFICATION ONLY. IF A CHANGE IN CONTRACT PRICE IS PERCEIVED, PROVIDE AN ITEMIZED BREAKDOWN OF ANY EXTRAS OR CREDITS WITHIN SEVEN (7) WORKING DAYS.

**Purpose:** To coordinate with the Interior designer and architectural drawings, site conditions and for clarifications.

### 1.0 Reference Drawing E-2A (Parking P1 Level - A) Issued

- 1.1 Add: Seven (7) type FL1 lighting fixtures, one (1) fire alarm speaker, one (1) smoke detector and two (2) fire alarm strobe lights at exit corridor.
- 1.2 Relocate: One (1) fire alarm speaker and one (1) smoke detector at exit corridor.
- 1.3 Delete: Five (5) type F lighting fixtures at exit corridor.

### 2.0 Reference Drawing E-3A (Ground Floor Plan - A) Issued

- 2.1 Add: One (1) type V lighting fixture at south exit door.
- 2.2 Clarify: Exterior lighting to be type V lighting fixture outside amenity area.
- 2.3 Add: Exterior lighting type V lighting fixture outside amenity area.
- 2.4 Revise: Exterior lighting to be type V lighting fixture outside amenity area.
- 2.5 Add: LD-01 cove lighting at lobby corridor.
- 2.6 Add: Power connection for motorized blinds at front facade entry two storeys.

**Project #14-016  
Hampton Manor**

**3.0 Reference Drawing E-3B (Ground Floor Plan - B) Issued**

- 3.1 Revise: Two (2) exterior lighting to be type V ceiling mounted lighting fixtures outside dog spa and exit corridor areas.
- 3.2 Delete: Two (2) exterior lighting type T1 wall mounted lighting fixtures outside dog spa and exit corridor areas.

**4.0 Reference Drawing E-4B (2<sup>nd</sup> Floor Plan – B) Issued**

- 4.1 Relocate: Two (2) receptacles on balcony.

**5.0 Reference Drawing E-5B (3<sup>rd</sup>-5<sup>th</sup> Floor Plan – B) Issued**

- 5.1 Relocate: Two (2) receptacles on balcony.

**6.0 Reference Drawing E-6A (6<sup>th</sup> Floor Plan – A) Issued**

- 6.1 Relocate: One (1) receptacle on balcony.
- 6.2 Add: One (1) receptacle on balcony.

**7.0 Reference Drawing E-6B (6<sup>th</sup> Floor Plan – B) Issued**

- 7.1 Relocate: One (1) receptacle on balcony.

**8.0 Reference Drawing E-7A (7<sup>th</sup> Floor Plan – A) Issued**

- 8.1 Relocate: Two (2) exterior balcony receptacles and one (1) wall mounted type T6 lighting fixture.
- 8.2 Delete: Two (2) exterior balcony receptacles.

**9.0 Reference Drawing E-7B (7<sup>th</sup> Floor Plan – B) Issued**

- 9.1 Relocate: Three (3) exterior balcony receptacles.

**10.0 Reference Drawing E-9B (Details - B) Issued**

- 10.1 Clarify: Strip cove lighting to be type LD-01.

**11.0 Reference Drawing E-12 (Panel Schedules) Issued**

- 11.1 Revise: Panel C.

**Note: The site instruction & drawings will be uploaded to FTP SITE**

Project #14-016  
Hampton Manor

---

PREPARED BY: 

Chula Meksavanh  
Electrical Department

ISSUED TO ROYAL PINE HOMES,  
Cinzia Caruso, Cinzia@royalpinehomes.com;  
Vince Staffieri, vince@royalpinehomes.com  
FOR DISTRIBUTION TO ALL AFFECTED PARTIES.

cc. GRAZIANI + CORAZZA ARCH. INC.,  
Gino Colangelo, GColangelo@gc-architects.com  
REXCON CONSTRUCTION, Lenny Simonelli, rexcon.construxtion@gmail.com