

3645 Keele St. #105 Toronto, ON, M3J 1M6 Email:info@u-eng.ca T:(416)398-1999 F:(416)398-1933

#### SITE INSTRUCTION

PROJECT: HAMPTON MANOR

25 BAKER HILL BLVD

STOUFFVILLE, ONTARIO

CONTRACT: Electrical

PROJECT NO: 14-016

DATE November 17, 2017

SITE INSTRUCTION: E-14

THIS SITE INSTRUCTION IS NOT TO BE CONSTRUED AS A CHANGE IN THE CONTRACT PRICE, BUT IS ISSUED FOR CLARIFICATION ONLY. IF A CHANGE IN CONTRACT PRICE IS PERCEIVED, PROVIDE AN ITEMIZED BREAKDOWN OF ANY EXTRAS OR CREDITS WITHIN SEVEN (7) WORKING DAYS.

Purpose: As per mechanical SI M-9 and Building Inspector, and for clarifications

## 1.0 Reference Drawing E-2A (P1 Level - 2A) Issued

1.1 Relocate:

Power connection and control panel for sanitary sump pit 'P-8' and for

storm sump pump 'P-9'.

1.2 Relocate:

Insulate and electrically trace for 75Ø sanitary discharge and for 100Ø

storm discharge.

2.0 Reference Drawings E-3A (Ground Floor - A) Issued

E-4A (2nd Floor - A) Issued

E-5A (3<sup>rd</sup> to 5th Floor - A) Issued

E-6A (6<sup>th</sup> Floor - A) Issued E-7A (7th Floor - A) Issued

2.1 Add:

Power door operator c/w push buttons for barrier free in corridor

horizontal exits

2.2 Clarify:

Circuits for door hold open device

## 3.0 Reference Drawing E-3A (Ground Floor - A) Issued

3.1 Clarify:

Suites key note #16 to state:

120V smoke alarm/carbon monoxide combo detector in suites on ground,  $2^{nd}$ ,  $3^{rd}$ ,  $6^{th}$  and  $7^{th}$  floor and

120V smoke alarm detector in suites on 4<sup>th</sup> and 5<sup>th</sup> floor

# 4.0 Reference Drawings E-5A and E-5B (3<sup>rd</sup> to 5th Floor – A and B) Issued

- 4.1 Clarify:
- 120V smoke alarm/carbon monoxide combo detector in suites on 3<sup>rd</sup> floor
- 120V smoke alarm detector in suites on 4<sup>th</sup> and 5<sup>th</sup> floor
- 4.2 Add:
- One (1) fire alarm strobe light in suites 001/002 and 003/004
- 4.3 Add:

Key note #6

# 5.0 Reference Drawings E-6A and E-6B (6th Floor – A and B) Issued

- 5.1 Clarify:
- 120V smoke alarm/carbon monoxide combo detector in suites on 6<sup>th</sup> floor
- 5.2 Delete:
- One (1) fire alarm strobe light in suites 613 and 616

### 6.0 Reference Drawing E-10 (Riser Diagrams) Issued

- 6.1 Clarify:
- 3 units in suites' power SD-4 at west closet on the ground floor

## 7.0 Reference Drawing E-12 (Panel Schedules) Issued

7.1 Revise:

Panels EC and ECN

Note: The site instruction & drawings will be uploaded to FTP SITE

PREPARED BY: Chu lullek swal

Chula Meksavanh Electrical Department

ISSUED TO ROYAL PINE HOMES,

Cinzia Caruso, Cinzia@royalpinehomes.com;

Vince Staffieri, vince@royalpinehomes.com

FOR DISTRIBUTION TO ALL AFFECTED PARTIES.

cc. GRAZIANI + CORAZZA ARCH. INC., Gino Colangelo, GColangelo@gc-architects.com DINEEN CONSTRUCTION CORP., Chuck Clark, cclark@dineen.com; Jeffrey Ellis, jellis@dineen.com; Ric Wight, rwight@dineen.com