

PANEL IDENTIF:	B	SERVICE: 208V/120V, 3ø, 4W MAIN CCT. BRK: 225 AMPS MOUNTING: SURFACE				NOTES:	
						LOCATION:	
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
LIGHTING - LOCKERS (P1)		15A	1	2	15A		RECEPTABLES - LOBBY ELEVATORS
LIGHTING - LOCKERS (P1)		15A	3	4	15A		RECEPTABLES - STAR A (P1)
LIGHTING - MECH. RM. (P1)		15A	5	6	15A		RECEPTABLES - STAR B (P1)
LGT. - GARBAGE/REC/BUCK (P1)		15A	7	8	15A		RECEPTABLES - STAR C (P1)
REC - GARBAGE/REC/BUCK (P1)		15A	9	10	15A		RECEPTABLES - STAR D (P1)
TRISORT - GARBAGE (P1)		20A	11	12	15A		SPARE
RECEPT. - ELEVATOR LOBBY (P1)		15A	13	14	15A		RECEPT. - LOCKERS (P1)
SPARE		15A	15	16	15A		RECEPT. - LOCKERS (P1)
		15A	17	18	15A		RECEPTABLE - MAIN ELEC. (P3)
		15A	19	20	15A		RECEPTABLE - MECH. RM. #1 (P1)
		15A	21	22	15A		REC. - SUB-ELECT. 1/COMM. (P1)
		15A	23	24	15A		RECEPTABLE - SUB-ELECT. 2 (P1)
		15A	25	26	15A		SPARE
		15A	27	28	15A		SPARE
		15A	29	30	15A		SPARE
SPACE		31	32				SPACE
		33	34				
		35	36				
		37	38				
		39	40				
		41	42				

PANEL IDENTIFY:	EB	SERVICE: MAIN CCT. BRK: 208V/120V, 3ø, 4ø MANS: 225 AMPS MOUNTING: SURFACE	NOTES: ** LOCK ON BREAKER LOCATION:				
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
LIGHTING - LOBBY ELEVATORS		15A	1	2	15A		EXIT SIGNS - (P1) ***
LIGHTING - STAR A (P1)		15A	3	4	15A		EXIT SIGNS - (P1) ***
LIGHTING - STAR B (P1)		15A	5	6	15A		LOWER STAR PRESS FAN 'F-9' SA
LIGHTING - STAR C (P1)		15A	7	8	15A		LOWER STAR PRESS FAN 'F-9' SB
LIGHTING - STAR D (P1)		15A	9	10	15A		LOWER STAR PRESS FAN 'F-9' SC
SPARE		15A	11	12	15A		SPARE
LIGHTING - LOCKERS (P1)		15A	13	14	15A		
LIGHTING - LOCKERS (P1)		15A	15	16	15A		
LIGHTING - MAIN ELEC. (P1)		15A	17	18	15A		
LIGHTING - MECH. RM. (P1)		15A	19	20	15A		
LGT. - SUB-ELEC./COMM. (P1)		15A	21	22	15A		
LGT. - GARBAGE/REC/BUCK (P1)		15A	23	24	15A		
SPARE		15A	25	26	15A		
		15A	27	28			
		15A	29	30			
SPACE		31	32				SPACE
		33	34				
		35	36				
		37	38				
		39	40				
		41	42				

PANEL IDENTIF:	SUITE (TYPICAL)	SERVICE: MAIN CCT. BRK: 120/208V, 1ø, 3ø MANS: 125 AMPS MOUNTING: RECESSED	NOTES:				
		LOCATION:					
LOAD DESCRIPTION	WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION	
LTC, RECEPT. & SMOKE ALARM	1000	15A	1	2	15A**	1000	KITCHEN GFI SPLIT RECEPTACLE
LIGHTING & RECEPTABLES	1000	15A	3	4	2P		
LIGHTING & RECEPTABLES	1000	15A	5	6	15A	1000	SPLIT RECEPTACLE
LIGHTING & RECEPTABLES	1000	15A	7	8	2P		
LIGHTING & RECEPTABLES	1000	15A	9	10	50A	6000	RANGE (3 #0)
EXTERIOR REC. GFI AS REQUIRED	500	15A	11	12	2P		
GFI RECEPTACLE	1000	15A	13	14	15A	800	FRIDGE
FAN COIL UNIT *	1000	15A**	15	16	30A	3000	DRYER
FAN COIL UNIT **	**	1000	15A**	17	18	2P	
AUTO FLUSH TOILET *		15A	19	20	15A	1000	WASHER
SPARE	15A	21	22	15A	1000	DISHWASHER	
SEPARATE RECEPTACLE **	500	15A	23	24	15A**		BATHRM. HEATER (TOP FLOOR)**
COMBO MICROWAVE HOOD/FAN **	15A**	25	26	15A**	1000	MICROWAVE	
DRYER EXHAUST FAN	15A	27	28	15A**	1000	SPLIT RECEPTACLE	
WINDOW A/C UNIT	**	1000	29	30	2P		
SPARE	15A	31	32			SPACE	
	15A	33	34				
	15A	35	36				
	15A	37	38				
	15A	39	40				
	15A	41	42				

PANEL IDENTIFY:	SUITE (TYPICAL)	SERVICE: MAIN CCT. BRK: 120/208V, 1ø, 3ø MANS: 100 AMPS MOUNTING: SURFACE	NOTES:
		LOCATION:	
LOAD DESCRIPTION	WATTS	BRK	LOAD DESCRIPTION
LTC, RECEPT. & SMOKE ALARM	1000	15A 1	KITCHEN GFI SPLIT RECEPTACLE
LIGHTING & RECEPTABLES	1000	15A 3	
LIGHTING & RECEPTABLES	1000	15A 5	SPLIT RECEPTACLE
LIGHTING & RECEPTABLES	1000	15A 7	
LIGHTING & RECEPTABLES	1000	15A 9	
EXTERIOR REC. GFI AS REQUIRED	500	15A 11	RANGE (3 Ø)
GFI RECEPTACLE	1000	15A 13	FRIDGE
FAN COIL UNIT *	1000	15A* 15	30A 3000
FAN COIL UNIT **	1000	15A* 17	DRYER
AUTO FLUSH TOILET *		15A 19	1000
SPARE	15A 21	22	DISHWASHER
SEPARATE RECEPTACLE **	500	15A 23	24 15A**
COMBO MICROWAVE HOOD/FAN **	15A** 25	26	15A** 1000
DRYER EXHAUST FAN	15A 27	28	15A** 1000
WINDOW A/C UNIT	** 1000	29	30 2P
NOTES:			
* CONFIRM ELEC REQUIREMENTS WITH UNITS SHOP DWGS (FOR EACH DIFFERENT SUITE/UNIT)			
** WHERE APPLICABLE AND REQUIRED, REFER TO UNITS LAYOUTS, ELEC PROVIDE SPARES			
PANELS CAN TRULS-N-OR OR TRULS-N-OR			
PANELS SHALL BE SIZABLE FOR THE USE OF DOUBLE BREAKERS WHICH SHALL BE USED SHOULD THE			
ACTUAL PROPORTION OF REQUIRED WATTS/AMPS EXCEED CODE REQUIREMENTS			
PROVIDE FIRE STOPPING IN CONDUIT AT PANEL AND IN ELECTRICAL CLOSET IN ACCORDANCE TO CODE			

PANEL IDENTIF:	C	SERVICE: 208V/120V, 3ø, 4W MAIN CCT. BRK: MANS: MOUNTING: SURFACE	NOTES:			
		LOCATION:				
LOAD DESCRIPTION	WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
RECEPTABLES - AMENITY (1ST)	15A	1	2	15A		RECEPTABLES - STAR C (1ST)
RECEPTABLES - AMENITY (1ST)	15A	3	4	15A		RECEPTABLES - CORRIDOR (1ST)
RECEPTABLES - AMENITY (1ST)	15A	5	6	15A		RECEPTABLES - CORRIDOR (1ST)
RECEPTABLES - AMENITY (1ST)	15A	7	8	15A		RECEPTABLES - ENTRANCE (1ST)
TV RECEPTABLES-AMENITY (1ST)	15A	9	10	15A		RECEPTABLES - LOBBY (1ST)
FIREPLACE - AMENITY (1ST)	15A	11	12	15A		RECEPTABLES - LOBBY (1ST)
FLOOR REC. - AMENITY (1ST)	15A	13	14	15A		FIREPLACE REC. - LOBBY (1ST)
FL EQUIP REC - AMENITY (1ST)	15A	15	16	15A		RECEPTABLE - CACF ROOM (1ST)
FL EQUIP REC - AMENITY (1ST)	15A	17	18	15A		CONCRETE FL REC - (1ST)
SPARE	15A	19	20	15A		CONCRETE FL REC - (1ST)
ELECTRICAL RM - AMENITY (1ST)	15A	21	22	15A		REC. - M OFFICE/MAIL (1ST)
EXT. BBO REC - AMENITY (1ST)	15A	23	24	15A		RECEPTABLES - M OFFICE (1ST)
EXT. BBO REC - AMENITY (1ST)	15A	25	26	15A		GFI RECEPTABLES - WC (1ST)
EXTERIOR REC. - AMENITY (1ST)	15A	27	28	15A		GFI RECEPTABLES - WC (1ST)
EXTERIOR REC. - AMENITY (1ST)	15A	29	30	15A		SPARE
GFI RECEPTABLE-DOO SPA (1ST)	15A	31	32	15A		FRIDGE - AMENITY (1ST)
GFI RECEPTABLE-DOO SPA (1ST)	15A	33	34	15A		COUNTER REC - AMENITY (1ST)
LIGHTING - LOBBY (1ST)	15A	35	36	15A		
LIGHTING - LOBBY (1ST)	15A	37	38	15A		COUNTER REC - AMENITY (1ST)
LIGHTING - AMENITY (1ST)	15A	39	40	15A		
LIGHTING - AMENITY (1ST)	15A	41	42	15A		DISHWASHER - AMENITY (1ST)
LIGHTING - AMENITY (1ST)	15A	43	44	15A		COOKTOP - AMENITY (1ST)
MOTORIZED BLINDS-LOBBY (1ST)	15A	45	46	15A		MICRO/HOOD FAN - AMENITY
SPARE	15A	47	48	15A		STOVE - AMENITY (1ST)
	15A	49	50	15A		SPARE
	15A	51	52	15A		
	15A	53	54	15A		
	15A	55	56	15A		
	15A	57	58	15A		
	15A	59	60	15A		
SPACE	61	62				SPACE

		15A	46	50	15A		SPARE
		15A	51	52	15A		
		15A	53	54	15A		
		15A	55	56	15A		
		15A	57	58	15A		
		15A	59	60	15A		
SPACE		61	62			SPACE	
		63	64				
		65	66				
		67	68				
		69	70				
		71	72				

PANEL IDENTIF:	EC	SERVICE: MAIN CCT. BRK: 208V/120V, 3ø, 4W MANS: 225 AMPS MOUNTING: SURFACE	NOTES: ** LOCK ON BREAKER LOCATION:				
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
LIGHTING - STAR C (1ST FL)		15A	1	2	15A		EXIT SIGNS STAR C (1ST) **
LIGHTING - DOO SPA (1ST FL)		15A	3	4	15A		EXIT SIGNS - LOBBY (1ST) **
LIGHTING - LOBBY (1ST FL)		15A	5	6	15A		
LIGHTING - LOBBY (1ST FL)		15A	7	8	15A		DOOR HOLD OPEN DEVICE - GR
LIGHTING - LOBBY (1ST FL)		15A	9	10	15A		DOOR HOLD OPEN DEVICE - 2ND
LIGHTING - AMENITY (1ST FL)		15A	11	12	15A		DOOR HOLD OPEN DEVICE - 3RD

SPARE	15A	16	20	15A	DOOR HOLD OPEN DEVICE - 7TH
	15A	21			SPARE
	15A	23	24	15A	
	15A	25	26	15A	
	15A	27	28	15A	
	15A	29	30	15A	
	15A	31	32		
	33	34			
	35	36			
	37	38			
	39	40			
	41	42			

SPARE	31	32			SPACE
	33	34			
	35	36			
	37	38			
	39	40			
	41	42			

PANEL IDENTIF:	ECN	SERVICE: 208V/120V, 3ø, 4ø MAIN CCT. BRK: - MANS: 225 AMPS MOUNTING: SURFACE	NOTES:				
			LOCATION:				
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
DO CONTROL PANEL		15A	1	2	15A		DO NOT ENTER SIGN (P1)
ENTERPHONE CONTROL PANEL		15A	3	4	15A		AUTO DOOR OPENER ENTR.(1ST)
SECURITY REER CONTROL PANEL		15A	5	6	15A		
TEL./TV RECEPTABLES		15A	7	8	15A		AUTO DOOR OPENER (2ND)
TEL./TV RECEPTABLES		15A	9	10	15A		AUTO DOOR OPENER (2ND)
ENTERPHONE PANEL-MAN ENTR.		15A	11	12	15A		AUTO DOOR OPENER (3RD)

			15A	18		20	15A		AUTO DOOR OPENER (7TH)
			15A	21		22	15A		SPACE
			15A	23		24	15A		
			15A	25		26	15A		
			15A	27		28	15A		
			15A	29		30	15A		
				31		32			
				33		34			SPACE
				35		36			
				37		38			
				39		40			
				41		42			

PANEL IDENTIF:	D	SERVICE: 208V/120V, 3ø, 4W MAIN CCT. BRK: MANS: 225 AMPS MOUNTING: SURFACE			NOTES:		
					LOCATION:		
LOAD DESCRIPTION		WATTS	BRK	CIRCUITS	BRK	WATTS	LOAD DESCRIPTION
STAIR A RECEPTABLES (2ND-7TH)		15A	1	2	15A		CORRIDOR RECEPT. (2ND-7TH)
STAIR B RECEPTABLES (2ND-7TH)		15A	3	4	15A		CORRIDOR RECEPT. (2ND-7TH)
SPARE		15A	5	6	15A		CORRIDOR RECEPT. (2ND-7TH)
RECEPTABLES - GUESS RM (1ST)		15A	7	8	15A		CORRIDOR RECEPT. (2ND-7TH)
RECEPTABLES - GUESS RM (1ST)		15A	9	10	15A		CORRIDOR RECEPT. (2ND-7TH)
DISHWASHER - GUESS RM (1ST)		15A	11	12	15A		CORRIDOR RECEPT. (2ND-7TH)
COUNTER REC - GUESS RM (1ST)		15A	13	14	15A		CORRIDOR RECEPT. (2ND-7TH)
COUNTER REC - GUESS RM (1ST)		15A	15	16	15A		CORRIDOR RECEPT. (2ND-7TH)
WC GFI REC. - GUESS RM (1ST)		15A	17	18	15A		CORRIDOR RECEPT. (2ND-7TH)
WC EX FAN - GUESS RM (1ST)		15A	19	20	15A		CORRIDOR RECEPT. (2ND-7TH)
FAN COIL - GUESS RM (1ST)		15A	21	22	15A		CORRIDOR RECEPT. (2ND-7TH)
RECEPTABLE LOCKERS (2ND-7TH)		15A	23	24	15A		CORRIDOR RECEPT. (2ND-7TH)
CONDENSATE NEUTRALIZATION KIT		15A	25	26	15A		LIGHTING - LOCKER (2ND-7TH)
RECEPTABLE LOCKERS (2ND-7TH)		15A	27	28	15A		LIGHTING - LOCKER (2ND-7TH)
CONDENSATE NEUTRALIZATION KIT		15A	29	30	15A		SPARE
SPACE		31	32	32	15A		
		33	34	34	15A		
		35	36	36	15A		
		37	38	38	15A		
		39	40	40	15A		
		41	42	42	15A		