

1200W X 2-400 DEEP SAN SUMP
FT C/W PUMP P-8 (DUPLES)
1200W X 2-400 DEEP STORM SEDIMENT FT
FT C/W PUMP P-4 (DUPLES)


750 SANITARY DISCHARGE UP INSULATE &
ELECTRICALLY TRACE EXPOSED PIPE
THROUGH OUT
1200W STORM DISCHARGE UP INSULATE &
ELECTRICALLY TRACE EXPOSED PIPE
THROUGH OUT

ALL EXPOSED TRAPS IN UNHEATED AREAS TO
BE ELECTRICALLY TRACED & INSULATED

NOTE
UNDERFLOOR VEEPING TILE SUPPLIED AND INSTALLED
BY GENERAL DIVISION, REFER TO SOILS REPORT PREPARED
EXP SERVICES INC

NO.	BY	DESCRIPTION	DATE
6	LD	REVISED AS PER SITE INSTRUCTION H-4	OCT/14/2017
5	LD	REVISED AS PER SITE INSTRUCTION H-5	SEP/20/2017
4	LD	REVISED AS PER SITE INSTRUCTION H-5 ISSUED FOR CONSTRUCTION	AUG/04/2017
3	LD	PROGRESS FOR CONSTRUCTION	JUL/18/2017
2	LH	ISSUED FOR PERMIT	DEC/28/2016
1	LH	ISSUED FOR TENDER	MAR/21/2016

This drawing, is an instrument of service, is provided by and is the property of United Engineering Inc. The contractor must verify and accept responsibility for all dimensions and conditions on site and must notify United Engineering Inc. of any discrepancy before proceeding.
United Engineering Inc. is not responsible for the accuracy of Architectural, structural, interior design, etc. on this drawing.
Refer to the appropriate trade drawings before proceeding with any work. Installation must conform to all applicable codes and requirements of the authorities having jurisdiction.
This drawing is not to be scaled, all symbols are graphic representations only.



United Engineering Inc.
Mechanical Electrical Consulting Engineers
3645 Hurdle Street, Suite 105,
Toronto, Ontario, M3J 1M6
Tel: (416) 398 1999 Fax: (416) 398 1933

TITLE UNDERGROUND PARKING MECHANICAL	
PROJECT 25 BAKER HILL BLVD. ROYAL PINE HOMES	
STOUFFVILLE, ONTARIO PROPOSED RESIDENTIAL DEVELOPMENT	
DRAWN GC	CHECKED BT
DATE JUNE 2015	PROJECT 14-016
SCALE 1:100	
DRAWING M-3	
OF 42	