

Schedule 1: Designer Information

Use one form for each individual who reviews and takes responsibility for design activities with respect to the project.

A. Project Information			
Building number, street name Unit 4502 Cor Elev. A, B and C		Lot: 4502 Cor	
Municipality BRAMPTON		Postal code	Plan number/ other description
B. Individual who reviews and takes responsibility for design activities			
Name Doug McCallum		Firm McCallum HVAC Design Inc.	
Street address 2 Dewside Drive Unit 208		Unit no.	Lot/con.
Municipality Brampton	Postal code L6R 3Y5	Province Ontario	E-mail info@mccallumhvac.com
Telephone number (905) 840-8166	Fax number	Cell number (647) 229-0380	
C. Design activities undertaken by individual identified in Section B. [Building Code Table 3.5.2.1 of Division C]			
House ☒	HVAC – House	Building Structural	
Small Buildings	Building Services	Plumbing – House	
Large Buildings	Detection, Lighting and Power	Plumbing – All Buildings	
Complex Buildings	Fire Protection	On-site Sewage Systems	
Description of designer's work		Model Certification	
Heating and Cooling Load Calculations Air System Design Residential mechanical ventilation Design Summary Residential System Design per CAN/CSA-F280-12 Residential New Construction - Forced Air		Project #: P22161	
		Builder	ROYAL PINE HOMES
		Project	FORESTSIDE ESTATES INC
		Model	Unit 4502 Cor Elev. A, B and C
		SB-12	SB 12 Performance 28
D. Declaration of Designer			
I, <u>Doug McCallum</u> declare that (choose one as appropriate): (print name)			
☒ I review and take responsibility for the design work on behalf of a firm registered under subsection 3.2.4 Division C of the Building Code. I am qualified, and the firm is registered, in the appropriate classes/categories. Individual BCIN: <u>25896</u> Firm BCIN: <u>102614</u>			
I review and take responsibility for the design and am qualified in the appropriate category as an "other designer" under subsection 3.2.5 of Division C, of the Building Code. Individual BCIN: _____ Basis for exemption from registration: _____			
The design work is exempt from the registration and qualification requirements of the Building Code. Basis for exemption from registration and qualification: _____			
I certify that: 1. The information contained in this schedule is true to the best of my knowledge. 2. I have submitted this application with the knowledge and consent of the firm.			
<u>2022-06-28</u> Date		 Signature of Designer	

NOTE:

- For the purposes of this form, "individual" means the "person" referred to in Clause 3.2.4.7(1) d), of Division C, Article 3.2.5.1. of Division C and all other persons who are exempt from qualifications under Subsections 3.2.4 . and 3.2.5. of Division C.
- Schedule 1 does not require to be completed a holder of a license, temporary license, or a certificate of authorization, issued by the Ontario Association of Architects. Schedule 1 is also not required to be completed by a holder of a license to practise, a limited licence to practise, or a certificate of authorization, issued by the Association of Professional Engineers of Ontario.

2 Dewside Drive Unit 208, Brampton, Ontario L6R 3Y5 Tel: 905-840-8166

e-mail - info@mccallumhvac.com

Heat loss and gain calculation summary sheet		CSA-F280-M12 Standard Form No. 1
These documents issued for the use of ROYAL PINE HOMES		Project No. P22161
and may not be used by any other persons without authorization. Documents for permit and/or construction are signed in red.		
Building Location		
Address (Model): Unit 4502 Cor Elev. A, B and C	Site: FORESTSIDE ESTATES INC	
Model:	Lot: 4502 Cor	
City and Province: BRAMPTON	Postal code:	
Calculations based on		
Dimensional information based on:		
Attachment: Detached	Front facing: North	Assumed? Yes
No. of Levels: 3 Ventilated? Included	Air tightness: -1	Assumed? Yes
Weather location: Brampton	Wind exposure: Shelterd	
HRV? VanEE 65H	Internal shading: Light-translucent	Occupants: 5
Sensible Eff. at -25C 60.0 % Apparent Effect. at -0C 75.0 %	Units: Imperial	
Heating design conditions		Cooling design conditions
Outdoor temp: -2.2°F Indoor temp: 72.0°F Mean soil temp: 48.2°F		Outdoor temp: 86.0°F Indoor temp: 72.0°F Latitude: 43.68
Above grade walls		Below grade walls
Style A: As per Selected OBC SB12 SB 1 R 22+1.	Style A: As per Selected OBC SB12 SB 1 R 20ci	
Style B: Existing Walls (When Applicable) R 8.50	Style B:	
Style C:	Style C:	
Style D:	Style D:	
Floors on soil		Ceilings
Style A: As per Selected OBC SB12 SB 12 F	Style A: As per Selected OBC SB12 SB 12 P R 60.0	
Style B:	Style B: As per Selected OBC SB12 SB 12 P R 22.8	
Exposed floors		Style C:
Style A: As per Selected OBC SB12 SB 12 R 31	Doors	
Style B:	Style A: As per Selected OBC SB12 SB 12 R 3.01	
Windows		Style B:
Style A: As per Selected OBC SB12 SB 12 I R 3.57	Style C:	
Style B: Existing Windows (When Applicable) R	Skylights	
Style C:	Style A: As per Selected OBC SB12 SB 12 R 2.04	
Style D:	Style B:	
Attached documents: As per Shedule 1		
Notes: Residential New Construction - Forced Air		
Calculations performed by		
Name: Doug McCallum	Postal code: L6R 3Y5	
Company: McCallum HVAC Design Inc.	Telephone: (905) 840-8166	
Address: 2 Dewside Drive Unit 208	Mobile: (647) 229-0380	
City: Brampton	E-mail: info@mccallumhvac.com	

Project: FORESTSIDE ESTATES INC

Model: Unit 4502 Cor Elev. A, B and C

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

For systems serving one dwelling unit & conforming to the Ontario Building Code, O. reg 159/93

Location of Installation	
Lot #	Plan #
Township BRAMPTON	
Roll #	Permit #
Address	

Total Ventilation Capacity 9.32.3.3(1)					
Bsmt & Master Bdrm	2	@ 21.2	cfm	42.4	cfm
Other Bedrooms	3	@ 10.6	cfm	31.8	cfm
Bathrooms & Kitchen	6	@ 10.6	cfm	63.6	cfm
Other rooms	4	@ 10.6	cfm	42.4	cfm
Total				<u>180.2</u>	

Builder	
Name	ROYAL PINE HOMES
Address	
City	
Tel	Fax

Principal Ventilation Capacity 9.32.3.4(1)					
Master bedroom	1	@ 31.8	cfm	31.8	cfm
Other bedrooms	3	@ 15.9	cfm	47.7	cfm
Total				<u>79.5</u>	

Installing Contractor	
Name	
Address	
City	
Tel	Fax

Principal Exhaust Fan Capacity			
Make	Model	Location	
VanEE	65H	BASE	
129	cfm	64	Sones

Heat Recovery Ventilator			
Make	VanEE		
Model	65H		
	129	cfm high	64 cfm low
Sensible efficiency @ -25 deg C	60 %		
Sensible efficiency @ 0 deg C	75 %		


Combustion Appliances 9.32.3.1(1)	
a)	☒ Direct vent (sealed combustion) only
b)	☐ Positive venting induced draft (except fireplaces)
c)	☐ Natural draft, B-vent or induced draft fireplaces
d)	☐ Solid fuel (including fireplaces)
e)	☐ No combustion Appliances

Supplemental Ventilation Capacity	
Total ventilation capacity	180.2
Less principal exhaust capacity	79.5
REQUIRED supplemental vent. Capacity	<u>100.7</u> cfm

Heating System	
☒	Forced air
☐	Non forced air
☐	Electric space heat (if over 10% of heat load)

Supplemental Fans 9.32.3.5.			
Location	cfm	Model	Sones
ENSUITE	50	770	2.5
POWDER	50	770	2.5
		None	
		None	
all fans HVI listed Make Broan or Equiv.			

House Type 9.32.3.1(2)	
I	☒ Type a) or b) appliances only, no solid fuel
II	☐ Type I except with solid fuel (including fireplace)
III	☐ Any type c) appliance
IV	☐ Type I or II either electric space heat
Other	☐ Type I, II or IV no forced air

Designer Certification	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name	Doug McCallum
Signature	
HRAI #	BCIN # 25896
Date	2022-06-28

System Design Option	
1	☐ Exhaust only / forced air system
2	☐ HRV WITH DUCTING / forced air system
3	☒ HRV simplified connection to forced air system
4	☐ HRV full ducting/not coupled to forced air system
	☐ Part 6 design

Energy Efficiency Design Summary: Prescriptive Method

(Building Code Part 9, Residential)

This form is used by a designer to demonstrate that the energy efficiency design of a house complies with the building code using the prescriptive method described in Subsection 3.1.1. of SB-12. This form is applicable where the ratio of gross area of windows/sidelights/skylights/glazing in doors and sliding glass doors to the gross area of peripheral walls is not more than 22%.

For use by Principal Authority	
Application No:	Model/Certification Number

A. Project Information

Building number, street name Unit 4502 Cor Elev. A, B and C		Unit number	Lot/Con
Municipality BRAMPTON	Postal code	Reg. Plan number / other description	

B. Compliance Option

SB-12 Prescriptive (input design package)	Package: SB 12 Performance 2i	Table: [SB-12 - 3.1.1.]
---	-------------------------------	-------------------------

C. Project Design Conditions

Climatic Zone (SB-1):	Heating Equipment Efficiency	Space Heating Fuel Source
☒ Zone 1 (< 5000 degree days)	☒ ≥ 92% AFUE	☒ Gas ☐ Propane ☐ Solid Fuel
☐ Zone 2 (≥ 5000 degree days)	☐ ≥ 84% < 92% AFUE	☐ Oil ☐ Electric ☐ Earth Energy

Ratio of Windows, Skylights & Glass (W, S & G) to Wall Area				Other Building Conditions				
Area of Walls =	381.0	m ² or	4101.0	ft ²	W, S & G % = 18.87%	☐ Log/Post&Beam	☐ ICF Above Grade	☐ ICF Basement
					Utilize window averaging:	☐ Slab on ground	☐ Walkout Basement	
Area of W, S & G =	71.9	m ² or	774.0	ft ²	☐ Yes ☐ No	☐ Air conditioning	☐ Combo unit	
						☐ Air Sourced Heat Pump	☐ Ground Sourced Heat Pump (GSHP)	

D. Building Specifications [provide values and ratings of the energy efficiency components proposed]

Energy Efficiency Substitutions				
☐ ICF (3.1.1.2.(5) & (6) / 3.1.1.3.(5) & (6))				
☐ Combined space heating and domestic water heating systems (3.1.1.2.(7) / 3.1.1.3.(7))				
☐ Airtightness substitution(s)	☐ Table 3.1.1.4.B	Required:	Permitted substitution:	
	☐ Table 3.1.1.4.C	Required:	Permitted substitution:	
Airtightness test required (Refer to design guide attached)		Required:	Permitted substitution:	
Building Component	Minimum RSI / R values or maximum U-Value ⁽¹⁾	Effective	Building Component	Efficiency Ratings
Thermal Insulation	Nominal	Effective	Windows & Doors Provide U-Value¹ or ER rating	
Ceiling with Attic Space	60	59.22	Windows/Sliding Glass Doors	1.6
Ceiling without Attic Space	31	27.65	Skylights/Glazed roofs	2.8
Exposed Floor	31	29.8	Mechanicals	
Walls Above Grade	22+1.5ci	18.53	Heating Equip. (AFUE)	96%
Basement Walls	20ci	21.12	HRV Efficiency (SRE% at 0°C)	75%
Slab (all >600mm below grade)	X		DHW Heater (EF)	0.9
Slab (edge only ≤600mm below grade)	10		DWHR (CSA B55.1 (min. 42% efficiency))	42%
Slab (all ≤600mm below grade, or heated)	10		Combined heating system	#Showers: 2

(1) U-Value to be provided in either W/(m²*K) or Btu/(h*ft²*F) but not both

E. Designer(s) [name(s) & BCIN(s), if applicable, of person(s) providing information herein to substantiate that design meets the building code]

Qualified Designer Declaration of designer to have reviewed and take responsibility for the design work		
NAME Doug McCallum	BCIN 102614	Signature 

Envelope Air Leakage Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description

Province:	Brampton
Region:	ON
Weather Station Location:	Open flat terrain, grass
Anemometer height (m):	10

Local Shielding

Building Site:	Suburban, forest
Walls:	Heavv
Flue:	Heavv
Highest Ceiling Height (m):	6.71

Building Configuration

Type:	Detached
Number of Stories:	Two
Foundation:	Full
House Volume (m ³):	1230

Air Leakage/Ventilation

Air Tightness Type:	Custom - DBT values		
Custom BDT Data:	ELA @ 10 Pa.	1556.241	
	3	ACH @ 50 Pa	
Mechanical Ventilation (L/s):	Total Supply:	Total Exhaust:	
	0	0	

Flue Size

Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0


Envelope Air Leakage Rate

Heating Air Leakage Rate (ACH/H):

Cooling Air Leakage Rate (ACH/H):

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Brampton	
Region:	ON	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Deep (>10 m, >33 Ft)	
Foundation Dimensions		
Floor Length (m):	22.8	 Insulation Configuration BCIN_1
Floor Width (m):	5.48	
Exposed Perimeter (m):	56.6	
Wall Height (m):	3.05	
Depth Below Grade (m):	2.44	
Window Area (m ²):	1.39	
Door Area (m ²):	0	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	23	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	1528	

SYSTEM A

DESIGN LOAD SPECIFICATIONS				AIR DISTRIBUTION AND PRESSURE			
LEVEL 1 NET LOAD	15578 btu/h			EQUIPMENT EXTERNAL STATIC PRESSURE	0.500"W.C.		
LEVEL 2 NET LOAD	21878 btu/h			ADDITIONAL EQUIPMENT PRESSURE DROP	0.250"W.C.		
LEVEL 3 NET LOAD	20238 btu/h			AVAILABLE DESIGN PRESSURE	0.250"W.C.		
LEVEL 4 NET LOAD	0 btu/h			RETURN BRANCH LONGEST EFFECTIVE LENGTH	300ft		
SYSTEM HEATLOSS	57694 btu/h			R/A PLENUM PRESSURE	0.120"W.C.		
SYSTEM HEATGAIN	40366 btu/h			S/A PLENUM PRESSURE	0.130"W.C.		
BUILDING VOLUME Vb	43419.00 ft3			HEATING AIR FLOW PROPORTIONING FACTOR	0.0227 cfm/btuh		
VENTILATION LOAD	1591.00 btu/h			COOLING AIR FLOW PROPORTIONING FACTOR	0.0325 cfm/btuh		
VENTILATION PVC	79.50 cfm			R/A TEMP. 70°F	S/A TEMP. 129.37°F	DIFFUSER LOSS 0.01"W.C.	
FURNACE/AIR HANDLER DATA				BLOWER DATA			
MAKE	LENNOX			HEATING CHECK	1314.00 CFM		
MODEL	EL296UH090XE48C			SELECTED CFM	1310.00 CFM		
HIGH INPUT btu/h	88000	LOW INPUT btu/h	0	COOLING CHECK	1307.00 CFM		
HIGH OUTPUT btu/h	84000	LOW OUTPUT btu/h	0	COOLING AIR FLOW RATE	1310.00 CFM		
E.S.P.	0.50			BLOWER TYPE ECM (BRUSHLESS DC OBC 12.3.1.5.(2))			
WATER TEMP.				A/C UNIT DATA			
AFUE	95.45%			MAKER	3.5 TON		
AUX. HEAT	0			CONDENSER	3.5 TON		
SB-12 PACKAGE	SB 12 Performance 28			COIL	3.5 TON		
TEMP. RISE	59.37°F						

SUPPLY BRANCH AND GRILL SIZING

OUTLET #	ROOM USE	BTU/H OUTLET	HEATING AIR FLOW RATE CFM	COOLING AIR FLOW RATE CFM	DUCT DESIGN PRESSURE	ACTUAL DUCT LENGTH	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	DUCT SIZE ROUND	OUTLET SIZE	TRUNK
29	BASE	3116	71	29	0.13	38	125	163	0.07	6.0	4x10	B1
30	BASE	3116	71	29	0.13	30	145	175	0.07	6.0	4x10	B1
31	BASE	3116	71	29	0.13	60	185	245	0.05	6.0	4x10	C1
32	BASE	3116	71	29	0.13	34	125	159	0.08	6.0	4x10	E1
33	BASE	3116	71	29	0.13	44	165	209	0.06	6.0	4x10	E1
17	FAM RM	1960	45	66	0.13	41	135	176	0.07	6.0	4x10	B1
18	FAM RM	1960	45	66	0.13	41	165	206	0.06	6.0	4x10	A1
19	KIT/BREAK	1878	43	58	0.13	32	155	187	0.06	5.0	4x10	A1
20	KIT/BREAK	1878	43	58	0.13	39	115	154	0.08	5.0	4x10	B1
21	LAUND	645	15	39	0.13	11	150	161	0.07	5.0	4x10	F1
22	MUD RM	2123	48	13	0.13	21	140	161	0.07	5.0	4x10	F1
23	LIV RM	2417	55	66	0.13	64	155	219	0.05	6.0	4x10	C1
24	LIV RM	2417	55	66	0.13	60	175	235	0.05	6.0	4x10	C1
25	PWD RM	1363	31	53	0.13	47	165	212	0.06	5.0	4x10	D1
26	FOYER	3295	75	23	0.13	32	135	167	0.07	6.0	4x10	E1
27	DINING RM	972	22	47	0.13	33	145	178	0.07	5.0	4x10	E1
28	DINING RM	972	22	47	0.13	27	175	202	0.06	5.0	4x10	E1
4	PRI. ENS	947	22	28	0.13	13	130	143	0.08	5	4x10	F1
2	PRI MB	1436	33	39	0.13	31	145	176	0.07	5.0	4x10	A1
3	PRI MB	1436	33	39	0.13	39	165	204	0.06	5.0	4x10	A1
15	SHD BATH-2	431	10	4	0.13	20	185	205	0.06	5	4x10	B1
12	WIC-3	1122	25	50	0.13	52	205	257	0.05	5.0	4x10	D1
7	SHD BATH WC	853	19	12	0.13	63	165	228	0.05	5	4x10	D1
8	SHD BATH-1	193	4	2	0.13	61	155	216	0.06	5	4x10	D1
13	BD-4	1507	34	63	0.13	57	175	232	0.05	6.0	4x10	E1
14	BD-4	1507	34	63	0.13	29	205	234	0.05	6.0	4x10	E1
16	PRI WIC	97	2	2	0.13	12	130	142	0.08	5	4x10	F1

9	WIC-2	154	3	2	0.13	51	205	256	0.05	5	4x10	D1
1	BD-5	2423	55	76	0.13	38	185	223	0.05	6.0	4x10	B1
5	BDRM-2	2102	48	32	0.13	73	190	263	0.05	5.0	4x10	D1
6	BDRM-2	2102	48	32	0.13	70	185	255	0.05	5.0	4x10	D1
10	BD-3	1965	45	58	0.13	76	185	261	0.05	6.0	4x10	C1
11	BD-3	1965	45	58	0.13	71	165	236	0.05	6.0	4x10	C1

RETURN BRANCH AND GRILL SIZING

R/A INLET #	INLET AIR VOLUME CFM	DUCT DESIGN PRESSU RE	ACTUAL DUCT LENGTH	EQUIVA LENT LENGTH	TOTAL EFFECTIV E LENGTH	ADJUSTE D PRESSU RE	DUCT SIZE ROUND	INLET SIZE	TRUNK
1R	75	0.12	27	120	147	0.07	6	14x8	Y1
2R	140	0.12	63	120	183	0.05	8	14x8	X1
3R	60	0.12	70	130	200	0.05	6	14x8	W1
4R	140	0.12	66	140	206	0.05	8	14x8	V1
5R	345	0.12	63	160	223	0.04	11.5	30X8	X1
6R	300	0.12	29	160	189	0.05	10.5	30X8	Y1
7R	140	0.12	59	160	219	0.05	8	14x8	V1
8R	110	0.12	50	170	220	0.05	7	FLC	W1

RETURN TRUNK DUCT SIZING

TRUNK	CFM	PRESSU RE	ROUND	RECT. SIZE	SIZE ALTERNA TE
DROP	1310	0.04		0	
Z1	1310	0.04	18.5	32x10	32x10
Y1	375	0.05	11.5	14x8	20x6
X1	935	0.04	16.5	32x8	24x10
W1	450	0.05	12	16x8	22x6
V1	280	0.05	10	12x8	16x6

SUPPLY TRUNK DUCT SIZING

TRUNK	CFM	PRESSU RE	ROUND	RECT. SIZE	SIZE ALTERNA TE
A1	154	0.06	8	10x8	
B1	449	0.05	12	16x8	22x6
C1	271	0.05	10	12x8	16x6
D1	449	0.05	12	16x8	22x6
E1	778	0.05	15	26x8	20x10
F1	1314	0.05	18	30x10	30x10

**HEATLOSS/GAIN
CALCULATIONS
CSA-F280-12**

ADDRESS/MODEL: Unit 4502 Cor Elev. A, B CLIENT: ROYAL PINE HOMES
and C
PROJECT #: P22161
COMPLIANCE PACKAGE: SB 12
GTA: 3355
LOT: 4502 Cor
SITE: FORESTSIDE ESTATES INC



WEATHER DATA [Brampton] [43.68] [-2.20] [86.00] [51.80] [48.20] [74.20] [14.00]

LEVEL 1																												
BASE		TOTALS H.L.: 15578 btuh						H.G.: 4502 btuh				AREA: 1349 ft2		Above Grade: 2		GROSS EXP. WALL NEW 372 ft EXIST 0 ft												
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT											
	NEW: 186 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2									
Eff. R-V	21.12		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03									
LOSS	3.5	0 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh								
GAIN	0.7	237 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh								
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS											
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 9.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 6.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2									
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99									
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	164 btuh	37.3	0 btuh	0	0	0	0	18.3	110 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh								
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	249 btuh	14.9	0 btuh	0	0	0	0	21.2	127 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh								
FUND. CONDUCTIVE HEATLOSS				5214 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.				
TOTAL CONDUCTIVE				LOSS	5488 btuh				LOSS	1.7942	9847 btuh				LOSS	0.0000	0 btuh	LOSS	0.0	243.3 btuh		239		5558		LOSS	0%	0 btuh
TOTAL CONDUCTIVE				GAIN	613 btuh				GAIN	0.0599	37 btuh				GAIN	0.0000	0 btuh	GAIN	0.06	34 btuh		0 0 btuh		50% 2779 btuh		GAIN	0%	0 btuh

LEVEL 2																												
FAM RM		TOTALS H.L.: 3920 btuh						H.G.: 4061 btuh				AREA: 236 ft2		C.Height: 11		GROSS EXP. WALL NEW 385 ft EXIST 0 ft												
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT											
	NEW: 35 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2									
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03									
LOSS	4.0	1205 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh								
GAIN	0.8	227 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh								
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS											
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 45.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 39.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2									
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99									
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	822 btuh	37.3	0 btuh	0	0	0	0	18.3	713 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh								
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1247 btuh	14.9	0 btuh	0	0	0	0	21.2	828 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh								
FUND. CONDUCTIVE HEATLOSS				0 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.				
TOTAL CONDUCTIVE				LOSS	2740 btuh				LOSS	0.3863	1059 btuh				LOSS	0.0000	0 btuh	LOSS	0.0	121.4 btuh		239		5558		LOSS	0%	0 btuh
TOTAL CONDUCTIVE				GAIN	2302 btuh				GAIN	0.0599	138 btuh				GAIN	0.0000	0 btuh	GAIN	0.06	128 btuh		0 0 btuh		10% 556 btuh		GAIN	0%	0 btuh

KIT/BREAK																												
		TOTALS H.L.: 3755 btuh						H.G.: 3591 btuh				AREA: 320 ft2		C.Height: 11		GROSS EXP. WALL NEW 374 ft EXIST 0 ft												
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT											
	NEW: 34 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2									
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03									
LOSS	4.0	1181 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh								
GAIN	0.8	223 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh								
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS											
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 12.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 67.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2									
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99									
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	219 btuh	37.3	0 btuh	0	0	0	0	18.3	1224 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh								
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	332 btuh	14.9	0 btuh	0	0	0	0	21.2	1423 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh								
FUND. CONDUCTIVE HEATLOSS				0 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.				
TOTAL CONDUCTIVE				LOSS	2625 btuh				LOSS	0.3863	1014 btuh				LOSS	0.0000	0 btuh	LOSS	0.0	116.4 btuh		239		5558		LOSS	0%	0 btuh
TOTAL CONDUCTIVE				GAIN	1978 btuh				GAIN	0.0599	118 btuh				GAIN	0.0000	0 btuh	GAIN	0.06	110 btuh		0 0 btuh		10% 556 btuh		GAIN	0%	0 btuh

LAUND																												
		TOTALS H.L.: 645 btuh						H.G.: 1199 btuh				AREA: 55 ft2		C.Height: 11		GROSS EXP. WALL NEW 77 ft EXIST 0 ft												
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT											
	NEW: 7 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2									
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03									
LOSS	4.0	268 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh								
GAIN	0.8	51 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh								
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS											
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 10.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2									
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99									
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	183 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh								
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	277 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh								
FUND. CONDUCTIVE HEATLOSS				0 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.				
TOTAL CONDUCTIVE				LOSS	451 btuh				LOSS	0.3863	174 btuh				LOSS	0.0000	0 btuh	LOSS	0.0	20.0 btuh		239		5558		LOSS	0%	0 btuh
TOTAL CONDUCTIVE				GAIN	328 btuh				GAIN	0.0599	20 btuh				GAIN	0.0000	0 btuh	GAIN	0.06	18 btuh		0 0 btuh		10% 556 btuh		GAIN	0%	0 btuh

MUD RM																				
		TOTALS H.L.: 2123 btuh						H.G.: 407 btuh				AREA: 50 ft2		C.Height: 11		GROSS EXP. WALL NEW 154 ft EXIST 0 ft				
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT			
	NEW: 14 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2	
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03	

**HEATLOSS/GAIN
CALCULATIONS
CSA-F280-12**

ADDRESS/MODEL: Unit 4502 Cor Elev. A, B CLIENT: ROYAL PINE HOMES
and C
PROJECT #: P22161
COMPLIANCE PACKAGE: SB 12
GTA: 3355
LOT: 4502 Cor
SITE: FORESTSIDE ESTATES INC



LOSS	4.0	448 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	85 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
	NEW: 42.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	1035 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	195 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE			LOSS	1484 btuh	LOSS	0.3863	573 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	65.8 btuh	239	5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE			GAIN	280 btuh	GAIN	0.0599	17 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	16 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh	
LIV RM				TOTALS H.L.: 4833 btuh				H.G.: 4065 btuh				AREA: 177 ft2		C.Height: 11		GROSS EXP. WALL		NEW 473 ft		EXIST 0 ft	
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
	NEW: 43 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	1478 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	279 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 52.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 52 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	950 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	950 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1441 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	586 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE			LOSS	3378 btuh	LOSS	0.3863	1305 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	149.7 btuh	239	5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE			GAIN	2305 btuh	GAIN	0.0599	138 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	128 btuh	0	0 btuh	10%	556 btuh	GAIN	0%	0 btuh	
PWD RM				TOTALS H.L.: 1363 btuh				H.G.: 1633 btuh				AREA: 59 ft2		C.Height: 11		GROSS EXP. WALL		NEW 99 ft		EXIST 0 ft	
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
	NEW: 9 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	240 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	45 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 39.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	713 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1080 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE			LOSS	953 btuh	LOSS	0.3863	368 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	42.2 btuh	239	5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE			GAIN	1126 btuh	GAIN	0.0599	67 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	63 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh	
FOYER				TOTALS H.L.: 3295 btuh				H.G.: 722 btuh				AREA: 229 ft2		C.Height: 11		GROSS EXP. WALL		NEW 330 ft		EXIST 0 ft	
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
	NEW: 30 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	1121 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	212 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
	NEW: 42.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 8 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	1035 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	146 btuh	37.3	0 btuh	
GAIN	4.7	195 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	90 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE			LOSS	2303 btuh	LOSS	0.3863	890 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	102.1 btuh	239	5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE			GAIN	497 btuh	GAIN	0.0599	30 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	28 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh	
DINING RM				TOTALS H.L.: 1944 btuh				H.G.: 2924 btuh				AREA: 217 ft2		C.Height: 11		GROSS EXP. WALL		NEW 154 ft		EXIST 0 ft	
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
	NEW: 14 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	408 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	77 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 52.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	950 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1441 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	

**HEATLOSS/GAIN
CALCULATIONS
CSA-F280-12**

ADDRESS/MODEL: Unit 4502 Cor Elev. A, B CLIENT: ROYAL PINE HOMES
and C GTA: 3355
PROJECT #: P22161 LOT: 4502 Cor
COMPLIANCE PACKAGE: SB 12 SITE: FORESTSIDE ESTATES INC



FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.			
TOTAL CONDUCTIVE				LOSS	1359 btuh	LOSS	0.3863	525 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	60.2 btuh	239		5558		LOSS	0%	0 btuh	
TOTAL CONDUCTIVE				GAIN	1518 btuh	GAIN	0.0599	91 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	84 btuh	0	0 btuh	10%	556 btuh	GAIN	0%	0 btuh	
LEVEL 3																						
PRI. ENS		TOTALS H.L.: 947 btuh						H.G.: 862 btuh			AREA: 98 ft2		C.Height: 9		GROSS EXP. WALL				NEW 90 ft		EXIST 0 ft	
		EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
		NEW: 10 ft		EXIST: 0 ft		NEW: 98 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V		18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS		4.0	292 btuh	8.7	0 btuh	1.3	123 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN		0.8	55 btuh	1.6	0 btuh	0.7	68 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
		DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 17.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V		3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS		24.7	0 btuh	24.7	0 btuh	18.3	311 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN		4.7	0 btuh	4.7	0 btuh	27.7	471 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.			
TOTAL CONDUCTIVE				LOSS	726 btuh	LOSS	0.2599	189 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	32.2 btuh	239		5558		LOSS	0%	0 btuh	
TOTAL CONDUCTIVE				GAIN	594 btuh	GAIN	0.0599	36 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	33 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh	
PRI MB		TOTALS H.L.: 2871 btuh						H.G.: 2432 btuh			AREA: 306 ft2		C.Height: 9		GROSS EXP. WALL				NEW 315 ft		EXIST 0 ft	
		EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
		NEW: 35 ft		EXIST: 0 ft		NEW: 306 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V		18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS		4.0	1105 btuh	8.7	0 btuh	1.3	383 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN		0.8	209 btuh	1.6	0 btuh	0.7	212 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
		DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 39.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V		3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS		24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	713 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN		4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	828 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.			
TOTAL CONDUCTIVE				LOSS	2201 btuh	LOSS	0.2599	572 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	97.6 btuh	239		5558		LOSS	0%	0 btuh	
TOTAL CONDUCTIVE				GAIN	1249 btuh	GAIN	0.0599	75 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	69 btuh	2	478 btuh	0%	0 btuh	GAIN	0%	0 btuh	
SHD BATH-2		TOTALS H.L.: 431 btuh						H.G.: 131 btuh			AREA: 62 ft2		C.Height: 9		GROSS EXP. WALL				NEW 63 ft		EXIST 0 ft	
		EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
		NEW: 7 ft		EXIST: 0 ft		NEW: 62 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V		18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS		4.0	252 btuh	8.7	0 btuh	1.3	78 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN		0.8	48 btuh	1.6	0 btuh	0.7	43 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
		DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V		3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS		24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN		4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.			
TOTAL CONDUCTIVE				LOSS	330 btuh	LOSS	0.2599	86 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	14.6 btuh	239		5558		LOSS	0%	0 btuh	
TOTAL CONDUCTIVE				GAIN	91 btuh	GAIN	0.0599	5 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	5 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh	
WIC-3		TOTALS H.L.: 1122 btuh						H.G.: 1531 btuh			AREA: 46 ft2		C.Height: 9		GROSS EXP. WALL				NEW 72 ft		EXIST 0 ft	
		EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
		NEW: 8 ft		EXIST: 0 ft		NEW: 46 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V		18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS		4.0	144 btuh	8.7	0 btuh	1.3	58 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN		0.8	27 btuh	1.6	0 btuh	0.7	32 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
		DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 36.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V		3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS		24.7	0 btuh	24.7	0 btuh	18.3	658 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN		4.7	0 btuh	4.7	0 btuh	27.7	997 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.			
TOTAL CONDUCTIVE				LOSS	860 btuh	LOSS	0.2599	224 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	38.1 btuh	239		5558		LOSS	0%	0 btuh	
TOTAL CONDUCTIVE				GAIN	1056 btuh	GAIN	0.0599	63 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	59 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh	
SHD BATH WC		TOTALS H.L.: 853 btuh						H.G.: 368 btuh			AREA: 40 ft2		C.Height: 9		GROSS EXP. WALL				NEW 63 ft		EXIST 0 ft	
		EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				

**HEATLOSS/GAIN
CALCULATIONS
CSA-F280-12**

ADDRESS/MODEL: Unit 4502 Cor Elev. A, B CLIENT: ROYAL PINE HOMES
and C
PROJECT #: P22161
COMPLIANCE PACKAGE: SB 12
GTA: 3355
LOT: 4502 Cor
SITE: FORESTSIDE ESTATES INC



NEW: 7 ft		EXIST: 0 ft		NEW: 40 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 38 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2			
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	196 btuh	8.7	0 btuh	1.3	50 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	95 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	37 btuh	1.6	0 btuh	0.7	28 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	10 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
DOORS		EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS							
NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 14 ft2		EXIST: 0 ft2			
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	256 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	158 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW		AIR LEAKAGE EXIST		VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.			
TOTAL CONDUCTIVE		LOSS	597 btuh		LOSS	0.2599	155 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	26.5 btuh	239		5558		LOSS	10%	75 btuh	
TOTAL CONDUCTIVE		GAIN	233 btuh		GAIN	0.0599	14 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	13 btuh	0	0 btuh	0%	0 btuh	GAIN	10%	23 btuh	

SHD BATH-1		TOTALS H.L.: 193 btuh						H.G.: 57 btuh				AREA: 38 ft2		C.Height: 9		GROSS EXP. WALL				NEW 0 ft		EXIST 0 ft	
EXPPOSED WALLS		EXPPOSED CEILING W/ATTIC				EXPPOSED CEILING NO ATTIC				EXPPOSED FLOORS				SKYLIGHT									
NEW: 0 ft		EXIST: 0 ft		NEW: 38 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 35 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2					
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03				
LOSS	4.0	0 btuh	8.7	0 btuh	1.3	48 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	87 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh			
GAIN	0.8	0 btuh	1.6	0 btuh	0.7	26 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	9 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh			
DOORS		EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS									
NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2					
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99				
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh			
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh			
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW		AIR LEAKAGE EXIST		VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.					
TOTAL CONDUCTIVE		LOSS	135 btuh		LOSS	0.2599	35 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	6.0 btuh	239		5558		LOSS	10%	17 btuh			
TOTAL CONDUCTIVE		GAIN	36 btuh		GAIN	0.0599	2 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	2 btuh	0	0 btuh	0%	0 btuh	GAIN	10%	4 btuh			

BD-4		TOTALS H.L.: 3014 btuh						H.G.: 3866 btuh				AREA: 209 ft2		C.Height: 9		GROSS EXP. WALL				NEW 198 ft		EXIST 0 ft	
EXPPOSED WALLS		EXPPOSED CEILING W/ATTIC				EXPPOSED CEILING NO ATTIC				EXPPOSED FLOORS				SKYLIGHT									
NEW: 22 ft		EXIST: 0 ft		NEW: 209 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2					
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03				
LOSS	4.0	440 btuh	8.7	0 btuh	1.3	262 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh			
GAIN	0.8	83 btuh	1.6	0 btuh	0.7	145 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh			
DOORS		EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS									
NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 88.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2					
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99				
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	1608 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh			
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	2438 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh			
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW		AIR LEAKAGE EXIST		VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.					
TOTAL CONDUCTIVE		LOSS	2311 btuh	LOSS	0.2599	601 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	102.4 btuh	239		5558		LOSS	0%	0 btuh				
TOTAL CONDUCTIVE		GAIN	2666 btuh	GAIN	0.0599	160 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	148 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh				

PRI WIC		TOTALS H.L.: 97 btuh						H.G.: 61 btuh				AREA: 60 ft2		C.Height: 9		GROSS EXP. WALL				NEW 0 ft		EXIST 0 ft	
EXPPOSED WALLS		EXPPOSED CEILING W/ATTIC				EXPPOSED CEILING NO ATTIC				EXPPOSED FLOORS				SKYLIGHT									
NEW: 0 ft		EXIST: 0 ft		NEW: 60 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2					
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03				
LOSS	4.0	0 btuh	8.7	0 btuh	1.3	75 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh			
GAIN	0.8	0 btuh	1.6	0 btuh	0.7	42 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh			
DOORS		EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS									
NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2					
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99				
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh			
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh			
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW		AIR LEAKAGE EXIST		VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.					
TOTAL CONDUCTIVE		LOSS	75 btuh	LOSS	0.2599	19 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	3.3 btuh	239		5558		LOSS	0%	0 btuh				
TOTAL CONDUCTIVE		GAIN	42 btuh	GAIN	0.0599	3 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	2 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh				

WIC-2		TOTALS H.L.: 154 btuh						H.G.: 53 btuh				AREA: 40 ft2		C.Height: 9		GROSS EXP. WALL				NEW 0 ft		EXIST 0 ft	
EXPPOSED WALLS		EXPPOSED CEILING W/ATTIC				EXPPOSED CEILING NO ATTIC				EXPPOSED FLOORS				SKYLIGHT									
NEW: 0 ft		EXIST: 0 ft		NEW: 40 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 23 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2					
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03				
LOSS	4.0	0 btuh	8.7	0 btuh	1.3	50 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	57 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh			
GAIN	0.8	0 btuh	1.6	0 btuh	0.7	28 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	6 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh			
DOORS		EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS									
NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2					
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99				

**HEATLOSS/GAIN
CALCULATIONS
CSA-F280-12**

ADDRESS/MODEL: Unit 4502 Cor Elev. A, B CLIENT: ROYAL PINE HOMES
and C GTA: 3355
PROJECT #: P22161 LOT: 4502 Cor
COMPLIANCE PACKAGE: SB 12 SITE: FORESTSIDE ESTATES INC



LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh					
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh					
FUND. CONDUCTIVE HEATLOSS				0 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	107 btuh	LOSS	0.2599	28 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	4.7 btuh	239		5558		LOSS	10%	14 btuh					
TOTAL CONDUCTIVE			GAIN	34 btuh	GAIN	0.0599	2 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	2 btuh	0	0 btuh	0%	0 btuh	GAIN	10%	3 btuh					
BD-5																									
		TOTALS H.L.: 2423 btuh				H.G.: 2345 btuh				AREA: 233 ft2			C.Height: 9		GROSS EXP. WALL NEW 252 ft				EXIST 0 ft						
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT								
	NEW: 28 ft		EXIST: 0 ft		NEW: 233 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2						
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03						
LOSS	4.0	853 btuh	8.7	0 btuh	1.3	292 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh					
GAIN	0.8	161 btuh	1.6	0 btuh	0.7	161 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh					
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS								
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 39.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2						
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99						
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	713 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh					
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1080 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh					
FUND. CONDUCTIVE HEATLOSS				0 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	1858 btuh	LOSS	0.2599	483 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	82.4 btuh	239		5558		LOSS	0%	0 btuh					
TOTAL CONDUCTIVE			GAIN	1403 btuh	GAIN	0.0599	84 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	78 btuh	1	239 btuh	0%	0 btuh	GAIN	0%	0 btuh					
BDRM-2																									
		TOTALS H.L.: 4204 btuh				H.G.: 1997 btuh				AREA: 311 ft2			C.Height: 9		GROSS EXP. WALL NEW 306 ft				EXIST 0 ft						
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT								
	NEW: 34 ft		EXIST: 0 ft		NEW: 311 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 240 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2						
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03						
LOSS	4.0	1021 btuh	8.7	0 btuh	1.3	390 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	598 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh					
GAIN	0.8	193 btuh	1.6	0 btuh	0.7	215 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	64 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh					
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS								
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 51 ft2		EXIST: 0 ft2						
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99						
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	932 btuh	37.3	0 btuh					
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	574 btuh	14.9	0 btuh					
FUND. CONDUCTIVE HEATLOSS				0 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	2940 btuh	LOSS	0.2599	764 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	130.3 btuh	239		5558		LOSS	10%	370 btuh					
TOTAL CONDUCTIVE			GAIN	1047 btuh	GAIN	0.0599	63 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	58 btuh	1	239 btuh	0%	0 btuh	GAIN	10%	129 btuh					
BD-3																									
		TOTALS H.L.: 3929 btuh				H.G.: 3559 btuh				AREA: 241 ft2			C.Height: 9		GROSS EXP. WALL NEW 324 ft				EXIST 0 ft						
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT								
	NEW: 36 ft		EXIST: 0 ft		NEW: 241 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2						
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03						
LOSS	4.0	901 btuh	8.7	0 btuh	1.3	302 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh					
GAIN	0.8	170 btuh	1.6	0 btuh	0.7	167 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh					
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS								
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 48.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 51 ft2		EXIST: 0 ft2						
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99						
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	877 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	932 btuh	37.3	0 btuh					
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1330 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	574 btuh	14.9	0 btuh					
FUND. CONDUCTIVE HEATLOSS				0 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	3012 btuh	LOSS	0.2599	783 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	133.5 btuh	239		5558		LOSS	0%	0 btuh					
TOTAL CONDUCTIVE			GAIN	2241 btuh	GAIN	0.0599	134 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	125 btuh	1	239 btuh	0%	0 btuh	GAIN	0%	0 btuh					
LEVEL 4																									

Schedule 1: Designer Information

Use one form for each individual who reviews and takes responsibility for design activities with respect to the project.

A. Project Information			
Building number, street name Unit 4502 Cor Elev. A, B and C		Lot: 4502 Cor	
Municipality BRAMPTON		Postal code	Plan number/ other description
B. Individual who reviews and takes responsibility for design activities			
Name Doug McCallum		Firm McCallum HVAC Design Inc.	
Street address 2 Dewside Drive Unit 208		Unit no.	Lot/con.
Municipality Brampton	Postal code L6R 3Y5	Province Ontario	E-mail info@mccallumhvac.com
Telephone number (905) 840-8166	Fax number	Cell number (647) 229-0380	
C. Design activities undertaken by individual identified in Section B. [Building Code Table 3.5.2.1 of Division C]			
House ☒	HVAC – House	Building Structural	
Small Buildings	Building Services	Plumbing – House	
Large Buildings	Detection, Lighting and Power	Plumbing – All Buildings	
Complex Buildings	Fire Protection	On-site Sewage Systems	
Description of designer's work		Model Certification	
Heating and Cooling Load Calculations Air System Design Residential mechanical ventilation Design Summary Residential System Design per CAN/CSA-F280-12 Residential New Construction - Forced Air		Project #: P22161	
		Builder	ROYAL PINE HOMES
		Project	FORESTSIDE ESTATES INC
		Model	Unit 4502 Cor Elev. A, B and C
		SB-12	SB 12 Performance 28
D. Declaration of Designer			
I, <u>Doug McCallum</u> declare that (choose one as appropriate): (print name)			
☒ I review and take responsibility for the design work on behalf of a firm registered under subsection 3.2.4 Division C of the Building Code. I am qualified, and the firm is registered, in the appropriate classes/categories. Individual BCIN: <u>25896</u> Firm BCIN: <u>102614</u>			
I review and take responsibility for the design and am qualified in the appropriate category as an "other designer" under subsection 3.2.5 of Division C, of the Building Code. Individual BCIN: _____ Basis for exemption from registration: _____ The design work is exempt from the registration and qualification requirements of the Building Code. Basis for exemption from registration and qualification: _____			
I certify that: 1. The information contained in this schedule is true to the best of my knowledge. 2. I have submitted this application with the knowledge and consent of the firm.			
<u>2022-06-28</u> Date		 Signature of Designer	

NOTE:

- For the purposes of this form, "individual" means the "person" referred to in Clause 3.2.4.7(1) d), of Division C, Article 3.2.5.1. of Division C and all other persons who are exempt from qualifications under Subsections 3.2.4 . and 3.2.5. of Division C.
- Schedule 1 does not require to be completed a holder of a license, temporary license, or a certificate of authorization, issued by the Ontario Association of Architects. Schedule 1 is also not required to be completed by a holder of a license to practise, a limited licence to practise, or a certificate of authorization, issued by the Association of Professional Engineers of Ontario.

2 Dewside Drive Unit 208, Brampton, Ontario L6R 3Y5 Tel: 905-840-8166

e-mail - info@mccallumhvac.com

Heat loss and gain calculation summary sheet		CSA-F280-M12 Standard Form No. 1
These documents issued for the use of ROYAL PINE HOMES		Project No. P22161
and may not be used by any other persons without authorization. Documents for permit and/or construction are signed in red.		
Building Location		
Address (Model): Unit 4502 Cor Elev. A, B and C	Site: FORESTSIDE ESTATES INC	
Model:	Lot: 4502 Cor	
City and Province: BRAMPTON	Postal code:	
Calculations based on		
Dimensional information based on:		
Attachment: Detached	Front facing: North	Assumed? Yes
No. of Levels: 3 Ventilated? Included	Air tightness: -1	Assumed? Yes
Weather location: Brampton	Wind exposure: Shelterd	
HRV? VanEE 65H	Internal shading: Light-translucent	Occupants: 5
Sensible Eff. at -25C 60.0 % Apparent Effect. at -0C 75.0 %	Units: Imperial	
Heating design conditions		Cooling design conditions
Outdoor temp: -2.2°F Indoor temp: 72.0°F Mean soil temp: 48.2°F		Outdoor temp: 86.0°F Indoor temp: 72.0°F Latitude: 43.68
Above grade walls		Below grade walls
Style A: As per Selected OBC SB12 SB 1 R 22+1.	Style A: As per Selected OBC SB12 SB 1 R 20ci	
Style B: Existing Walls (When Applicable) R 8.50	Style B:	
Style C:	Style C:	
Style D:	Style D:	
Floors on soil		Ceilings
Style A: As per Selected OBC SB12 SB 12 F	Style A: As per Selected OBC SB12 SB 12 P R 60.0	
Style B:	Style B: As per Selected OBC SB12 SB 12 P R 22.8	
Exposed floors		Style C:
Style A: As per Selected OBC SB12 SB 12 R 31	Doors	
Style B:	Style A: As per Selected OBC SB12 SB 12 R 3.01	
Windows		Style B:
Style A: As per Selected OBC SB12 SB 12 I R 3.57	Style C:	
Style B: Existing Windows (When Applicable) R	Skylights	
Style C:	Style A: As per Selected OBC SB12 SB 12 R 2.04	
Style D:	Style B:	
Attached documents: As per Shedule 1		
Notes: Residential New Construction - Forced Air		
Calculations performed by		
Name: Doug McCallum	Postal code: L6R 3Y5	
Company: McCallum HVAC Design Inc.	Telephone: (905) 840-8166	
Address: 2 Dewside Drive Unit 208	Mobile: (647) 229-0380	
City: Brampton	E-mail: info@mccallumhvac.com	

Project: FORESTSIDE ESTATES INC

Model: Unit 4502 Cor Elev. A, B and C

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

For systems serving one dwelling unit & conforming to the Ontario Building Code, O. reg 159/93

Location of Installation	
Lot #	Plan #
Township BRAMPTON	
Roll #	Permit #
Address	

Total Ventilation Capacity 9.32.3.3(1)					
Bsmt & Master Bdrm	2	@ 21.2	cfm	42.4	cfm
Other Bedrooms	3	@ 10.6	cfm	31.8	cfm
Bathrooms & Kitchen	6	@ 10.6	cfm	63.6	cfm
Other rooms	4	@ 10.6	cfm	42.4	cfm
Total				<u>180.2</u>	

Builder	
Name	ROYAL PINE HOMES
Address	
City	
Tel	Fax

Principal Ventilation Capacity 9.32.3.4(1)					
Master bedroom	1	@ 31.8	cfm	31.8	cfm
Other bedrooms	3	@ 15.9	cfm	47.7	cfm
Total				<u>79.5</u>	

Installing Contractor	
Name	
Address	
City	
Tel	Fax

Principal Exhaust Fan Capacity			
Make	Model	Location	
VanEE	65H	BASE	
129	cfm	64	Sones

Heat Recovery Ventilator			
Make	VanEE		
Model	65H		
129	cfm high	64	cfm low
Sensible efficiency @ -25 deg C		60	%
Sensible efficiency @ 0 deg C		75	%


Combustion Appliances 9.32.3.1(1)	
a)	☒ Direct vent (sealed combustion) only
b)	☐ Positive venting induced draft (except fireplaces)
c)	☐ Natural draft, B-vent or induced draft fireplaces
d)	☐ Solid fuel (including fireplaces)
e)	☐ No combustion Appliances

Supplemental Ventilation Capacity	
Total ventilation capacity	180.2
Less principal exhaust capacity	79.5
REQUIRED supplemental vent. Capacity	<u>100.7</u> cfm

Heating System	
☒	Forced air
☐	Non forced air
☐	Electric space heat (if over 10% of heat load)

Supplemental Fans 9.32.3.5.			
Location	cfm	Model	Sones
ENSUITE	50	770	2.5
POWDER	50	770	2.5
		None	
		None	
all fans HVI listed		Make	Broan or Equiv.

House Type 9.32.3.1(2)	
I	☒ Type a) or b) appliances only, no solid fuel
II	☐ Type I except with solid fuel (including fireplace)
III	☐ Any type c) appliance
IV	☐ Type I or II either electric space heat
Other	☐ Type I, II or IV no forced air

Designer Certification	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name	Doug McCallum
Signature	
HRAI #	BCIN # 25896
Date	2022-06-28

System Design Option	
1	☐ Exhaust only / forced air system
2	☐ HRV WITH DUCTING / forced air system
3	☒ HRV simplified connection to forced air system
4	☐ HRV full ducting/not coupled to forced air system
	☐ Part 6 design

Envelope Air Leakage Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description

Province:	Brampton
Region:	ON
Weather Station Location:	Open flat terrain, grass
Anemometer height (m):	10

Local Shielding

Building Site:	Suburban, forest
Walls:	Heavv
Flue:	Heavv
Highest Ceiling Height (m):	6.71

Building Configuration

Type:	Detached
Number of Stories:	Two
Foundation:	Full
House Volume (m ³):	1230

Air Leakage/Ventilation

Air Tightness Type:	Custom - DBT values		
Custom BDT Data:	ELA @ 10 Pa.	1556.241	
	3	ACH @ 50 Pa	
Mechanical Ventilation (L/s):	Total Supply:	Total Exhaust:	
	0	0	

Flue Size

Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0


Envelope Air Leakage Rate

Heating Air Leakage Rate (ACH/H):

Cooling Air Leakage Rate (ACH/H):

Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Brampton	
Region:	ON	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Deep (>10 m, >33 Ft)	
Foundation Dimensions		
Floor Length (m):	22.8	 Insulation Configuration BCIN_1
Floor Width (m):	5.48	
Exposed Perimeter (m):	56.6	
Wall Height (m):	3.05	
Depth Below Grade (m):	2.44	
Window Area (m ²):	1.39	
Door Area (m ²):	0	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	23	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):	1528	

SYSTEM A

DESIGN LOAD SPECIFICATIONS				AIR DISTRIBUTION AND PRESSURE			
LEVEL 1 NET LOAD	15578 btu/h			EQUIPMENT EXTERNAL STATIC PRESSURE	0.500"W.C.		
LEVEL 2 NET LOAD	21878 btu/h			ADDITIONAL EQUIPMENT PRESSURE DROP	0.250"W.C.		
LEVEL 3 NET LOAD	20238 btu/h			AVAILABLE DESIGN PRESSURE	0.250"W.C.		
LEVEL 4 NET LOAD	0 btu/h			RETURN BRANCH LONGEST EFFECTIVE LENGTH	300ft		
SYSTEM HEATLOSS	57694 btu/h			R/A PLENUM PRESSURE	0.120"W.C.		
SYSTEM HEATGAIN	40366 btu/h			S/A PLENUM PRESSURE	0.130"W.C.		
BUILDING VOLUME Vb	43419.00 ft3			HEATING AIR FLOW PROPORTIONING FACTOR	0.0227 cfm/btuh		
VENTILATION LOAD	1591.00 btu/h			COOLING AIR FLOW PROPORTIONING FACTOR	0.0325 cfm/btuh		
VENTILATION PVC	79.50 cfm			R/A TEMP. 70°F	S/A TEMP. 129.37°F	DIFFUSER LOSS 0.01"W.C.	
FURNACE/AIR HANDLER DATA				BLOWER DATA			
MAKE	LENNOX			HEATING CHECK	1314.00 CFM		
MODEL	EL296UH090XE48C			SELECTED CFM	1310.00 CFM		
HIGH INPUT btu/h	88000	LOW INPUT btu/h	0	COOLING CHECK	1307.00 CFM		
HIGH OUTPUT btu/h	84000	LOW OUTPUT btu/h	0	COOLING AIR FLOW RATE	1310.00 CFM		
E.S.P.	0.50			BLOWER TYPE ECM (BRUSHLESS DC OBC 12.3.1.5.(2))			
WATER TEMP.				A/C UNIT DATA			
AFUE	95.45%			MAKER	3.5 TON		
AUX. HEAT	0			CONDENSER	3.5 TON		
SB-12 PACKAGE	SB 12 Performance 28			COIL	3.5 TON		
TEMP. RISE	59.37°F						

SUPPLY BRANCH AND GRILL SIZING

OUTLET #	ROOM USE	BTU/H OUTLET	HEATING AIR FLOW RATE CFM	COOLING AIR FLOW RATE CFM	DUCT DESIGN PRESSURE	ACTUAL DUCT LENGTH	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	DUCT SIZE ROUND	OUTLET SIZE	TRUNK
29	BASE	3116	71	29	0.13	38	125	163	0.07	6.0	4x10	B1
30	BASE	3116	71	29	0.13	30	145	175	0.07	6.0	4x10	B1
31	BASE	3116	71	29	0.13	60	185	245	0.05	6.0	4x10	C1
32	BASE	3116	71	29	0.13	34	125	159	0.08	6.0	4x10	E1
33	BASE	3116	71	29	0.13	44	165	209	0.06	6.0	4x10	E1
17	FAM RM	1960	45	66	0.13	41	135	176	0.07	6.0	4x10	B1
18	FAM RM	1960	45	66	0.13	41	165	206	0.06	6.0	4x10	A1
19	KIT/BREAK	1878	43	58	0.13	32	155	187	0.06	5.0	4x10	A1
20	KIT/BREAK	1878	43	58	0.13	39	115	154	0.08	5.0	4x10	B1
21	LAUND	645	15	39	0.13	11	150	161	0.07	5.0	4x10	F1
22	MUD RM	2123	48	13	0.13	21	140	161	0.07	5.0	4x10	F1
23	LIV RM	2417	55	66	0.13	64	155	219	0.05	6.0	4x10	C1
24	LIV RM	2417	55	66	0.13	60	175	235	0.05	6.0	4x10	C1
25	PWD RM	1363	31	53	0.13	47	165	212	0.06	5.0	4x10	D1
26	FOYER	3295	75	23	0.13	32	135	167	0.07	6.0	4x10	E1
27	DINING RM	972	22	47	0.13	33	145	178	0.07	5.0	4x10	E1
28	DINING RM	972	22	47	0.13	27	175	202	0.06	5.0	4x10	E1
4	PRI. ENS	947	22	28	0.13	13	130	143	0.08	5	4x10	F1
2	PRI MB	1436	33	39	0.13	31	145	176	0.07	5.0	4x10	A1
3	PRI MB	1436	33	39	0.13	39	165	204	0.06	5.0	4x10	A1
15	SHD BATH-2	431	10	4	0.13	20	185	205	0.06	5	4x10	B1
12	WIC-3	1122	25	50	0.13	52	205	257	0.05	5.0	4x10	D1
7	SHD BATH WC	853	19	12	0.13	63	165	228	0.05	5	4x10	D1
8	SHD BATH-1	193	4	2	0.13	61	155	216	0.06	5	4x10	D1
13	BD-4	1507	34	63	0.13	57	175	232	0.05	6.0	4x10	E1
14	BD-4	1507	34	63	0.13	29	205	234	0.05	6.0	4x10	E1
16	PRI WIC	97	2	2	0.13	12	130	142	0.08	5	4x10	F1

9	WIC-2	154	3	2	0.13	51	205	256	0.05	5	4x10	D1
1	BD-5	2423	55	76	0.13	38	185	223	0.05	6.0	4x10	B1
5	BDRM-2	2102	48	32	0.13	73	190	263	0.05	5.0	4x10	D1
6	BDRM-2	2102	48	32	0.13	70	185	255	0.05	5.0	4x10	D1
10	BD-3	1965	45	58	0.13	76	185	261	0.05	6.0	4x10	C1
11	BD-3	1965	45	58	0.13	71	165	236	0.05	6.0	4x10	C1

RETURN BRANCH AND GRILL SIZING

R/A INLET #	INLET AIR VOLUME CFM	DUCT DESIGN PRESSU RE	ACTUAL DUCT LENGTH	EQUIVA LENT LENGTH	TOTAL EFFECTIV E LENGTH	ADJUSTE D PRESSU RE	DUCT SIZE ROUND	INLET SIZE	TRUNK
1R	75	0.12	27	120	147	0.07	6	14x8	Y1
2R	140	0.12	63	120	183	0.05	8	14x8	X1
3R	60	0.12	70	130	200	0.05	6	14x8	W1
4R	140	0.12	66	140	206	0.05	8	14x8	V1
5R	345	0.12	63	160	223	0.04	11.5	30X8	X1
6R	300	0.12	29	160	189	0.05	10.5	30X8	Y1
7R	140	0.12	59	160	219	0.05	8	14x8	V1
8R	110	0.12	50	170	220	0.05	7	FLC	W1

RETURN TRUNK DUCT SIZING

TRUNK	CFM	PRESSU RE	ROUND	RECT. SIZE	SIZE ALTERNA TE
DROP	1310	0.04		0	
Z1	1310	0.04	18.5	32x10	32x10
Y1	375	0.05	11.5	14x8	20x6
X1	935	0.04	16.5	32x8	24x10
W1	450	0.05	12	16x8	22x6
V1	280	0.05	10	12x8	16x6

SUPPLY TRUNK DUCT SIZING

TRUNK	CFM	PRESSU RE	ROUND	RECT. SIZE	SIZE ALTERNA TE
A1	154	0.06	8	10x8	
B1	449	0.05	12	16x8	22x6
C1	271	0.05	10	12x8	16x6
D1	449	0.05	12	16x8	22x6
E1	778	0.05	15	26x8	20x10
F1	1314	0.05	18	30x10	30x10

**HEATLOSS/GAIN
CALCULATIONS
CSA-F280-12**

ADDRESS/MODEL: Unit 4502 Cor Elev. A, B CLIENT: ROYAL PINE HOMES
and C
PROJECT #: P22161
COMPLIANCE PACKAGE: SB 12
GTA: 3355
LOT: 4502 Cor
SITE: FORESTSIDE ESTATES INC



WEATHER DATA [Brampton] [43.68] [-2.20] [86.00] [51.80] [48.20] [74.20] [14.00]

LEVEL 1																									
BASE		TOTALS H.L.: 15578 btuh						H.G.: 4502 btuh				AREA: 1349 ft2		Above Grade: 2		GROSS EXP. WALL NEW 372 ft EXIST 0 ft									
	EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT									
	NEW: 186 ft		EXIST: 0 ft	NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2							
Eff. R-V	21.12		8.50	59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03							
LOSS	3.5	0 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh					
GAIN	0.7	237 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh					
	DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS									
	NEW: 0.0 ft2		EXIST: 0.0 ft2	NEW: 9.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 6.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2							
Eff. R-V	3.01		3.01	4.06		1.99		0		0		4.06		1.99		4.06		1.99							
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	164 btuh	37.3	0 btuh	0	0	0	0	18.3	110 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh					
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	249 btuh	14.9	0 btuh	0	0	0	0	21.2	127 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh					
FUND. CONDUCTIVE HEATLOSS				5214 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	5488 btuh	LOSS	1.7942	9847 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	243.3 btuh	239		5558		LOSS	0%	0 btuh					
TOTAL CONDUCTIVE			GAIN	613 btuh	GAIN	0.0599	37 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	34 btuh	0	0 btuh	50%	2779 btuh	GAIN	0%	0 btuh					
LEVEL 2																									
FAM RM		TOTALS H.L.: 3920 btuh						H.G.: 4061 btuh				AREA: 236 ft2		C.Height: 11		GROSS EXP. WALL NEW 385 ft EXIST 0 ft									
	EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT									
	NEW: 35 ft		EXIST: 0 ft	NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2							
Eff. R-V	18.53		8.50	59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03							
LOSS	4.0	1205 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh					
GAIN	0.8	227 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh					
	DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS									
	NEW: 0.0 ft2		EXIST: 0.0 ft2	NEW: 45.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 39.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2							
Eff. R-V	3.01		3.01	4.06		1.99		0		0		4.06		1.99		4.06		1.99							
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	822 btuh	37.3	0 btuh	0	0	0	0	18.3	713 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh					
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1247 btuh	14.9	0 btuh	0	0	0	0	21.2	828 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh					
FUND. CONDUCTIVE HEATLOSS				0 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	2740 btuh	LOSS	0.3863	1059 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	121.4 btuh	239		5558		LOSS	0%	0 btuh					
TOTAL CONDUCTIVE			GAIN	2302 btuh	GAIN	0.0599	138 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	128 btuh	0	0 btuh	10%	556 btuh	GAIN	0%	0 btuh					
KIT/BREAK		TOTALS H.L.: 3755 btuh						H.G.: 3591 btuh				AREA: 320 ft2		C.Height: 11		GROSS EXP. WALL NEW 374 ft EXIST 0 ft									
	EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT									
	NEW: 34 ft		EXIST: 0 ft	NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2							
Eff. R-V	18.53		8.50	59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03							
LOSS	4.0	1181 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh					
GAIN	0.8	223 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh					
	DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS									
	NEW: 0.0 ft2		EXIST: 0.0 ft2	NEW: 12.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 67.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2							
Eff. R-V	3.01		3.01	4.06		1.99		0		0		4.06		1.99		4.06		1.99							
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	219 btuh	37.3	0 btuh	0	0	0	0	18.3	1224 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh					
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	332 btuh	14.9	0 btuh	0	0	0	0	21.2	1423 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh					
FUND. CONDUCTIVE HEATLOSS				0 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	2625 btuh	LOSS	0.3863	1014 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	116.4 btuh	239		5558		LOSS	0%	0 btuh					
TOTAL CONDUCTIVE			GAIN	1978 btuh	GAIN	0.0599	118 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	110 btuh	0	0 btuh	10%	556 btuh	GAIN	0%	0 btuh					
LAUND		TOTALS H.L.: 645 btuh						H.G.: 1199 btuh				AREA: 55 ft2		C.Height: 11		GROSS EXP. WALL NEW 77 ft EXIST 0 ft									
	EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT									
	NEW: 7 ft		EXIST: 0 ft	NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2							
Eff. R-V	18.53		8.50	59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03							
LOSS	4.0	268 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh					
GAIN	0.8	51 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh					
	DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS									
	NEW: 0.0 ft2		EXIST: 0.0 ft2	NEW: 10.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2							
Eff. R-V	3.01		3.01	4.06		1.99		0		0		4.06		1.99		4.06		1.99							
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	183 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh					
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	277 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh					
FUND. CONDUCTIVE HEATLOSS				0 btuh				AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	451 btuh	LOSS	0.3863	174 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	20.0 btuh	239		5558		LOSS	0%	0 btuh					
TOTAL CONDUCTIVE			GAIN	328 btuh	GAIN	0.0599	20 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	18 btuh	0	0 btuh	10%	556 btuh	GAIN	0%	0 btuh					
MUD RM		TOTALS H.L.: 2123 btuh						H.G.: 407 btuh				AREA: 50 ft2		C.Height: 11		GROSS EXP. WALL NEW 154 ft EXIST 0 ft									
	EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT									
	NEW: 14 ft		EXIST: 0 ft	NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2							
Eff. R-V	18.53		8.50	59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03							

**HEATLOSS/GAIN
CALCULATIONS
CSA-F280-12**

ADDRESS/MODEL: Unit 4502 Cor Elev. A, B CLIENT: ROYAL PINE HOMES
and C
PROJECT #: P22161
COMPLIANCE PACKAGE: SB 12
GTA: 3355
LOT: 4502 Cor
SITE: FORESTSIDE ESTATES INC



LOSS	4.0	448 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	85 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
	NEW: 42.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	1035 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	195 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE			LOSS	1484 btuh	LOSS	0.3863	573 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	65.8 btuh	239	5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE			GAIN	280 btuh	GAIN	0.0599	17 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	16 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh	
LIV RM				TOTALS H.L.: 4833 btuh				H.G.: 4065 btuh				AREA: 177 ft2		C.Height: 11		GROSS EXP. WALL		NEW 473 ft		EXIST 0 ft	
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
	NEW: 43 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	1478 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	279 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 52.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 52 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	950 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	950 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1441 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	586 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE			LOSS	3378 btuh	LOSS	0.3863	1305 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	149.7 btuh	239	5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE			GAIN	2305 btuh	GAIN	0.0599	138 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	128 btuh	0	0 btuh	10%	556 btuh	GAIN	0%	0 btuh	
PWD RM				TOTALS H.L.: 1363 btuh				H.G.: 1633 btuh				AREA: 59 ft2		C.Height: 11		GROSS EXP. WALL		NEW 99 ft		EXIST 0 ft	
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
	NEW: 9 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	240 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	45 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 39.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	713 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1080 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE			LOSS	953 btuh	LOSS	0.3863	368 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	42.2 btuh	239	5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE			GAIN	1126 btuh	GAIN	0.0599	67 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	63 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh	
FOYER				TOTALS H.L.: 3295 btuh				H.G.: 722 btuh				AREA: 229 ft2		C.Height: 11		GROSS EXP. WALL		NEW 330 ft		EXIST 0 ft	
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
	NEW: 30 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	1121 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	212 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
	NEW: 42.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 8 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	1035 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	146 btuh	37.3	0 btuh	
GAIN	4.7	195 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	90 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE			LOSS	2303 btuh	LOSS	0.3863	890 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	102.1 btuh	239	5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE			GAIN	497 btuh	GAIN	0.0599	30 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	28 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh	
DINING RM				TOTALS H.L.: 1944 btuh				H.G.: 2924 btuh				AREA: 217 ft2		C.Height: 11		GROSS EXP. WALL		NEW 154 ft		EXIST 0 ft	
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
	NEW: 14 ft		EXIST: 0 ft		NEW: 0		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	408 btuh	8.7	0 btuh	1.3	0 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	77 btuh	1.6	0 btuh	0.7	0 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 52.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	950 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1441 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	

**HEATLOSS/GAIN
CALCULATIONS
CSA-F280-12**

ADDRESS/MODEL: Unit 4502 Cor Elev. A, B CLIENT: ROYAL PINE HOMES
and C GTA: 3355
PROJECT #: P22161 LOT: 4502 Cor
COMPLIANCE PACKAGE: SB 12 SITE: FORESTSIDE ESTATES INC



FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE		LOSS	1359 btuh	LOSS	0.3863	525 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	60.2 btuh	239		5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE		GAIN	1518 btuh	GAIN	0.0599	91 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	84 btuh	0	0 btuh	10%	556 btuh	GAIN	0%	0 btuh		

LEVEL 3																					
PRI. ENS		TOTALS H.L.: 947 btuh					H.G.: 862 btuh			AREA: 98 ft2		C.Height: 9		GROSS EXP. WALL				NEW 90 ft		EXIST 0 ft	
		EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
		NEW: 10 ft		EXIST: 0 ft		NEW: 98 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2	
Eff. R-V	18.53	8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03			
LOSS	4.0	292 btuh	8.7	0 btuh	1.3	123 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	55 btuh	1.6	0 btuh	0.7	68 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
		DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 17.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2	
Eff. R-V	3.01	3.01		4.06		1.99		0		0		0		4.06		1.99		4.06		1.99	
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	311 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	471 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	

FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE		LOSS	726 btuh	LOSS	0.2599	189 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	32.2 btuh	239		5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE		GAIN	594 btuh	GAIN	0.0599	36 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	33 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh		

PRI MB		TOTALS H.L.: 2871 btuh					H.G.: 2432 btuh			AREA: 306 ft2		C.Height: 9		GROSS EXP. WALL				NEW 315 ft		EXIST 0 ft	
		EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
		NEW: 35 ft		EXIST: 0 ft		NEW: 306 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2	
Eff. R-V	18.53	8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03			
LOSS	4.0	1105 btuh	8.7	0 btuh	1.3	383 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	209 btuh	1.6	0 btuh	0.7	212 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
		DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 39.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2	
Eff. R-V	3.01	3.01		4.06		1.99		0		0		0		4.06		1.99		4.06		1.99	
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	713 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	828 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	

FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE		LOSS	2201 btuh	LOSS	0.2599	572 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	97.6 btuh	239		5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE		GAIN	1249 btuh	GAIN	0.0599	75 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	69 btuh	2	478 btuh	0%	0 btuh	GAIN	0%	0 btuh		

SHD BATH-2		TOTALS H.L.: 431 btuh					H.G.: 131 btuh			AREA: 62 ft2		C.Height: 9		GROSS EXP. WALL				NEW 63 ft		EXIST 0 ft	
		EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
		NEW: 7 ft		EXIST: 0 ft		NEW: 62 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2	
Eff. R-V	18.53	8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03			
LOSS	4.0	252 btuh	8.7	0 btuh	1.3	78 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	48 btuh	1.6	0 btuh	0.7	43 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
		DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2	
Eff. R-V	3.01	3.01		4.06		1.99		0		0		0		4.06		1.99		4.06		1.99	
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	

FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE		LOSS	330 btuh	LOSS	0.2599	86 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	14.6 btuh	239		5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE		GAIN	91 btuh	GAIN	0.0599	5 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	5 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh		

WIC-3		TOTALS H.L.: 1122 btuh					H.G.: 1531 btuh			AREA: 46 ft2		C.Height: 9		GROSS EXP. WALL				NEW 72 ft		EXIST 0 ft	
		EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				
		NEW: 8 ft		EXIST: 0 ft		NEW: 46 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2	
Eff. R-V	18.53	8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03			
LOSS	4.0	144 btuh	8.7	0 btuh	1.3	58 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	27 btuh	1.6	0 btuh	0.7	32 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
		DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS				
		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 36.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2	
Eff. R-V	3.01	3.01		4.06		1.99		0		0		0		4.06		1.99		4.06		1.99	
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	658 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	997 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	

FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW			AIR LEAKAGE EXIST			VENTILATION CASE 3			H.G. PEOPLE		APP. LOAD		DUCT PIPE L.		
TOTAL CONDUCTIVE		LOSS	860 btuh	LOSS	0.2599	224 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	38.1 btuh	239		5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE		GAIN	1056 btuh	GAIN	0.0599	63 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	59 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh		

SHD BATH WC		TOTALS H.L.: 853 btuh					H.G.: 368 btuh			AREA: 40 ft2		C.Height: 9		GROSS EXP. WALL				NEW 63 ft		EXIST 0 ft	
		EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT				

**HEATLOSS/GAIN
CALCULATIONS
CSA-F280-12**

ADDRESS/MODEL: Unit 4502 Cor Elev. A, B CLIENT: ROYAL PINE HOMES
and C
PROJECT #: P22161
COMPLIANCE PACKAGE: SB 12
GTA: 3355
LOT: 4502 Cor
SITE: FORESTSIDE ESTATES INC



NEW: 7 ft			EXIST: 0 ft		NEW: 40 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 38 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	196 btuh	8.7	0 btuh	1.3	50 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	95 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	37 btuh	1.6	0 btuh	0.7	28 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	10 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS						
NEW: 0.0 ft2			EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 14 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	256 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	158 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW		AIR LEAKAGE EXIST		VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.			
TOTAL CONDUCTIVE			LOSS	597 btuh	LOSS	0.2599	155 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	26.5 btuh	239		5558		LOSS	10%	75 btuh	
TOTAL CONDUCTIVE			GAIN	233 btuh	GAIN	0.0599	14 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	13 btuh	0	0 btuh	0%	0 btuh	GAIN	10%	23 btuh	

SHD BATH-1		TOTALS H.L.: 193 btuh						H.G.: 57 btuh		AREA: 38 ft2		C.Height: 9		GROSS EXP. WALL				NEW 0 ft		EXIST 0 ft	
EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT						
NEW: 0 ft			EXIST: 0 ft		NEW: 38 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 35 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	0 btuh	8.7	0 btuh	1.3	48 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	87 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	0 btuh	1.6	0 btuh	0.7	26 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	9 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS						
NEW: 0.0 ft2			EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW		AIR LEAKAGE EXIST		VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.			
TOTAL CONDUCTIVE			LOSS	135 btuh	LOSS	0.2599	35 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	6.0 btuh	239		5558		LOSS	10%	17 btuh	
TOTAL CONDUCTIVE			GAIN	36 btuh	GAIN	0.0599	2 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	2 btuh	0	0 btuh	0%	0 btuh	GAIN	10%	4 btuh	

BD-4		TOTALS H.L.: 3014 btuh						H.G.: 3866 btuh		AREA: 209 ft2		C.Height: 9		GROSS EXP. WALL				NEW 198 ft		EXIST 0 ft	
EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT						
NEW: 22 ft			EXIST: 0 ft		NEW: 209 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	440 btuh	8.7	0 btuh	1.3	262 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	83 btuh	1.6	0 btuh	0.7	145 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS						
NEW: 0.0 ft2			EXIST: 0.0 ft2		NEW: 88.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	1608 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	2438 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW		AIR LEAKAGE EXIST		VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.			
TOTAL CONDUCTIVE			LOSS	2311 btuh	LOSS	0.2599	601 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	102.4 btuh	239		5558		LOSS	0%	0 btuh	
TOTAL CONDUCTIVE			GAIN	2666 btuh	GAIN	0.0599	160 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	148 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh	

PRI WIC		TOTALS H.L.: 97 btuh						H.G.: 61 btuh		AREA: 60 ft2		C.Height: 9		GROSS EXP. WALL				NEW 0 ft		EXIST 0 ft	
EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT						
NEW: 0 ft			EXIST: 0 ft		NEW: 60 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	0 btuh	8.7	0 btuh	1.3	75 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	0 btuh	1.6	0 btuh	0.7	42 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS						
NEW: 0.0 ft2			EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh	
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh	
FUND. CONDUCTIVE HEATLOSS				0 btuh		AIR LEAKAGE NEW		AIR LEAKAGE EXIST		VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.			
TOTAL CONDUCTIVE			LOSS	75 btuh	LOSS	0.2599	19 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	3.3 btuh	239		5558		LOSS	0%	0 btuh	
TOTAL CONDUCTIVE			GAIN	42 btuh	GAIN	0.0599	3 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	2 btuh	0	0 btuh	0%	0 btuh	GAIN	0%	0 btuh	

WIC-2		TOTALS H.L.: 154 btuh						H.G.: 53 btuh		AREA: 40 ft2		C.Height: 9		GROSS EXP. WALL				NEW 0 ft		EXIST 0 ft	
EXPOSED WALLS			EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT						
NEW: 0 ft			EXIST: 0 ft		NEW: 40 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 23 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03		
LOSS	4.0	0 btuh	8.7	0 btuh	1.3	50 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	57 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh	
GAIN	0.8	0 btuh	1.6	0 btuh	0.7	28 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	6 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh	
DOORS			EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS						
NEW: 0.0 ft2			EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2		
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99		

**HEATLOSS/GAIN
CALCULATIONS
CSA-F280-12**

ADDRESS/MODEL: Unit 4502 Cor Elev. A, B CLIENT: ROYAL PINE HOMES
and C GTA: 3355
PROJECT #: P22161 LOT: 4502 Cor
COMPLIANCE PACKAGE: SB 12 SITE: FORESTSIDE ESTATES INC



LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh		
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh		
FUND. CONDUCTIVE HEATLOSS				0 btuh	AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	107 btuh	LOSS	0.2599	28 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	4.7 btuh	239		5558		LOSS	10%	14 btuh		
TOTAL CONDUCTIVE			GAIN	34 btuh	GAIN	0.0599	2 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	2 btuh	0	0 btuh	0%	0 btuh	GAIN	10%	3 btuh		
BD-5																						
TOTALS H.L.: 2423 btuh				H.G.: 2345 btuh				AREA: 233 ft2				C.Height: 9		GROSS EXP. WALL NEW 252 ft				EXIST 0 ft				
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT					
	NEW: 28 ft		EXIST: 0 ft		NEW: 233 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2			
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03			
LOSS	4.0	853 btuh	8.7	0 btuh	1.3	292 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh		
GAIN	0.8	161 btuh	1.6	0 btuh	0.7	161 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh		
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS					
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 39.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0 ft2		EXIST: 0 ft2			
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99			
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	713 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	0 btuh	37.3	0 btuh		
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1080 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	0 btuh	14.9	0 btuh		
FUND. CONDUCTIVE HEATLOSS				0 btuh	AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	1858 btuh	LOSS	0.2599	483 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	82.4 btuh	239		5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE			GAIN	1403 btuh	GAIN	0.0599	84 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	78 btuh	1	239 btuh	0%	0 btuh	GAIN	0%	0 btuh		
BDRM-2																						
TOTALS H.L.: 4204 btuh				H.G.: 1997 btuh				AREA: 311 ft2				C.Height: 9		GROSS EXP. WALL NEW 306 ft				EXIST 0 ft				
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT					
	NEW: 34 ft		EXIST: 0 ft		NEW: 311 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 240 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2			
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03			
LOSS	4.0	1021 btuh	8.7	0 btuh	1.3	390 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	598 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh		
GAIN	0.8	193 btuh	1.6	0 btuh	0.7	215 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	64 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh		
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS					
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 51 ft2		EXIST: 0 ft2			
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99			
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	0 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	932 btuh	37.3	0 btuh		
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	0 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	574 btuh	14.9	0 btuh		
FUND. CONDUCTIVE HEATLOSS				0 btuh	AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	2940 btuh	LOSS	0.2599	764 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	130.3 btuh	239		5558		LOSS	10%	370 btuh		
TOTAL CONDUCTIVE			GAIN	1047 btuh	GAIN	0.0599	63 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	58 btuh	1	239 btuh	0%	0 btuh	GAIN	10%	129 btuh		
BD-3																						
TOTALS H.L.: 3929 btuh				H.G.: 3559 btuh				AREA: 241 ft2				C.Height: 9		GROSS EXP. WALL NEW 324 ft				EXIST 0 ft				
	EXPOSED WALLS				EXPOSED CEILING W/ATTIC				EXPOSED CEILING NO ATTIC				EXPOSED FLOORS				SKYLIGHT					
	NEW: 36 ft		EXIST: 0 ft		NEW: 241 ft2		EXIST: 0		NEW: 0		EXIST: 0		NEW: 0 ft2		EXIST: 0 ft2		NEW: 0.0 ft2		EXIST: 0.0 ft2			
Eff. R-V	18.53		8.50		59.22		22.86		27.65		22.05		29.80		22.05		2.04		2.03			
LOSS	4.0	901 btuh	8.7	0 btuh	1.3	302 btuh	3.2	0 btuh	2.7	0 btuh	3.4	0 btuh	2.5	0 btuh	3.4	0 btuh	36.4	0 btuh	37	0 btuh		
GAIN	0.8	170 btuh	1.6	0 btuh	0.7	167 btuh	1.8	0 btuh	1.5	0 btuh	1.9	0 btuh	0.3	0 btuh	0.4	0 btuh	89.7	0 btuh	14.7	0 btuh		
	DOORS				EAST/WEST WINDOWS				SE/SW WINDOWS				SOUTH WINDOWS				NORTH WINDOWS					
	NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 48.0 ft2		EXIST: 0.0 ft2		NEW:		EXIST:		NEW: 0.0 ft2		EXIST: 0.0 ft2		NEW: 51 ft2		EXIST: 0 ft2			
Eff. R-V	3.01		3.01		4.06		1.99		0		0		4.06		1.99		4.06		1.99			
LOSS	24.7	0 btuh	24.7	0 btuh	18.3	877 btuh	37.3	0 btuh	0	0	0	0	18.3	0 btuh	37.3	0 btuh	18.3	932 btuh	37.3	0 btuh		
GAIN	4.7	0 btuh	4.7	0 btuh	27.7	1330 btuh	14.9	0 btuh	0	0	0	0	21.2	0 btuh	14.9	0 btuh	11.3	574 btuh	14.9	0 btuh		
FUND. CONDUCTIVE HEATLOSS				0 btuh	AIR LEAKAGE NEW				AIR LEAKAGE EXIST				VENTILATION CASE 3				H.G. PEOPLE		APP. LOAD		DUCT PIPE L.	
TOTAL CONDUCTIVE			LOSS	3012 btuh	LOSS	0.2599	783 btuh	LOSS	0.0000	0 btuh	LOSS	0.0	133.5 btuh	239		5558		LOSS	0%	0 btuh		
TOTAL CONDUCTIVE			GAIN	2241 btuh	GAIN	0.0599	134 btuh	GAIN	0.0000	0 btuh	GAIN	0.06	125 btuh	1	239 btuh	0%	0 btuh	GAIN	0%	0 btuh		
LEVEL 4																						