

Schedule 1: Designer Information

Use one form for each individual who reviews and takes responsibility for design activities with respect to the project.

A. Project Information			
Building number, street name		Unit no.	Lot/con.
Municipality BRAMPTON	Postal code	Plan number/ other description	
B. Individual who reviews and takes responsibility for design activities			
Name MICHAEL O'ROURKE		Firm HVAC DESIGNS LTD.	
Street address 375 FINLEY AVE		Unit no. 202	Lot/con. N/A
Municipality AJAX	Postal code L1S 2E2	Province ONTARIO	E-mail info@hvacdesigns.ca
Telephone number (905) 619-2300	Fax number (905) 619-2375	Cell number ()	
C. Design activities undertaken by individual identified in Section B. [Building Code Table 3.5.2.1 OF Division C]			
☐ House ☐ Small Buildings ☐ Large Buildings ☐ Complex Buildings ☒ HVAC – House ☐ Building Services ☐ Detection, Lighting and Power ☐ Fire Protection ☐ Building Structural ☐ Plumbing – House ☐ Plumbing – All Buildings ☐ On-site Sewage Systems			
Description of designer's work HEAT LOSS / GAIN CALCULATIONS DUCT SIZING RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY RESIDENTIAL SYSTEM DESIGN per CSA-F280-12		Model: 5008 - ELEV B OPT 2ND Project: VALES OF HUMBER SOUTH	
D. Declaration of Designer			
I, <u>MICHAEL O'ROURKE</u> (print name) declare that (choose one as appropriate):			
☐ I review and take responsibility for the design work on behalf of a firm registered under subsection 3.2.4. of Division C, of the Building Code. I am qualified, and the firm is registered, in the appropriate classes/categories. Individual BCIN: _____ Firm BCIN: _____			
☒ I review and take responsibility for the design and am qualified in the appropriate category as an "other designer" under subsection 3.2.5. of Division C, of the Building Code. Individual BCIN: <u>19669</u> Basis for exemption from registration and qualification: <u>O.B.C SENTENCE 3.2.4.1 (4)</u>			
☐ The design work is exempt from the registration and qualification requirements of the Building Code. Basis for exemption from registration and qualification: _____			
I certify that:			
1. The information contained in this schedule is true to the best of my knowledge. 2. I have submitted this application with the knowledge and consent of the firm.			
April 6, 2022			
Date		Signature of Designer	

NOTE:

- For the purposes of this form, "individual" means the "person" referred to in Clause 3.2.4.7(1) d) of Division C, Article 3.2.5.1. of Division C, and all other persons who are exempt from qualification under Subsections 3.2.4. and 3.2.5. of Division C.
- Schedule 1 is not required to be completed by a holder of a license, temporary license, or a certificate of authorization, issued by the Ontario Association of Architects. Schedule 1 is also not required to be completed by a holder of a license to practise, a limited license to practise, or a certificate of authorization, issued by the Association of Professional Engineers of Ontario.

Application for a Permit Construct or Demolish – Effective January 1, 2015

SITE NAME: VALES OF HUMBER SOUTH										OPT 2ND					DATE Apr-22					WINTER NATURAL AIR CHANGE RATE 0.234					HEAT LOSS AT °F. 74		CSA-F280-12						
BUILDER: ROYAL PINE HOMES										TYPE: 5008 - ELEV B					GFA: 4398					LO# 95291					SUMMER NATURAL AIR CHANGE RATE 0.076					HEAT GAIN AT °F. 11		SB-12 PERFORMANCE	
ROOM USE			STUDY			GREAT			KIT			DIN			LIV			FOY			LAUN												
EXP. WALL			30			27			44			16			40			19			41												
CLG. HT.			11			11			11			11			11			21			13												
FACTORS																																	
GRS.WALL AREA			330			297			484			176			440			399			533												
GLAZING			LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN			LOSS GAIN												
NORTH			20.8	15.5	0	0	0	12	249	186	0	0	0	0	0	0	0	0	0	0	21	436	325										
EAST			20.8	41.0	0	0	0	0	0	0	0	0	0	0	0	48	997	1970	56	1163	2299	0	0	0									
SOUTH			20.8	24.4	0	0	0	12	249	293	42	873	1025	26	540	634	0	0	0	0	0	0	0										
WEST			20.8	41.0	36	748	1478	36	748	1478	71	1475	2914	0	0	0	0	0	0	0	0	0	0										
SKYLT.			34.1	100.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0											
DOORS			24.7	3.7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	20	493	73	20	493	73									
NET EXPOSED WALL			3.5	0.5	294	1019	151	237	822	122	371	1286	191	150	520	77	392	1359	201	323	1120	166	492	1706	253								
NET EXPOSED BSMT WALL ABOVE GR			3.5	0.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0											
EXPOSED CLG			1.3	0.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0											
NO ATTIC EXPOSED CLG			2.7	1.2	0	0	0	10	27	12	0	0	0	0	0	0	20	54	24	56	150	67	0	0	0								
EXPOSED FLOOR			2.5	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0											
BASEMENT/CRAWL HEAT LOSS			0			0			0			0			0			0			0												
SLAB ON GRADE HEAT LOSS			0			0			0			0			0			0			0												
SUBTOTAL HT LOSS			1767			2095			3634			1060			2410			2927			2635												
SUB TOTAL HT GAIN			1629			2090			4130			711			2196			2605			651												
LEVEL FACTOR / MULTIPLIER			0.30	0.37				0.30	0.37				0.30	0.37				0.30	0.37				0.30	0.37									
AIR CHANGE HEAT LOSS			650			771			1337			390			887			1077			969												
AIR CHANGE HEAT GAIN			90			115			228			39			121			144			36												
DUCT LOSS			0			0			0			0			0			0			0												
DUCT GAIN			0			0			0			0			0			0			0												
HEAT GAIN PEOPLE			240	0	0			0	0	0	0	0	0	0	0	0	0	0	0	0	0	0											
HEAT GAIN APPLIANCES/LIGHTS			1637			1637			1637			1637			1637			1637			1637												
TOTAL HT LOSS BTU/H			2417			2866			4971			1450			3297			4003			3605												
TOTAL HT GAIN x 1.3 BTU/H			4362			4994			7793			3103			5139			3573			3020												

ROOM USE																											BAS
EXP. WALL																											222
CLG. HT.																											10
	FACTORS																										
GRS.WALL AREA	LOSS	GAIN																									1554
GLAZING																											LOSS GAIN
NORTH	20.8	15.5																									4 83 62
EAST	20.8	41.0																									0 0 0
SOUTH	20.8	24.4																									8 166 195
WEST	20.8	41.0																									12 249 493
SKYLT.	34.1	100.3																									0 0 0
DOORS	24.7	3.7																									20 493 73
NET EXPOSED WALL	3.5	0.5																									0 0 0
NET EXPOSED BSMT WALL ABOVE GR	3.5	0.5																									666 2340 347
EXPOSED CLG	1.3	0.6																									0 0 0
NO ATTIC EXPOSED CLG	2.7	1.2																									0 0 0
EXPOSED FLOOR	2.5	0.4																									0 0 0
BASEMENT/CRAWL HEAT LOSS																											8044
SLAB ON GRADE HEAT LOSS																											11375
SUBTOTAL HT LOSS																											1170
SUB TOTAL HT GAIN																											
LEVEL FACTOR / MULTIPLIER																											0.50 0.89
AIR CHANGE HEAT LOSS																											10134
AIR CHANGE HEAT GAIN																											65
DUCT LOSS																											0
DUCT GAIN																											0
HEAT GAIN PEOPLE	240																										0
HEAT GAIN APPLIANCES/LIGHTS																											0
TOTAL HT LOSS BTU/H																											21509
TOTAL HT GAIN x 1.3 BTU/H																											1604

SITE NAME: VALES OF HUMBER SOUTH
BUILDER: ROYAL PINE HOMES

OPT 2ND
TYPE: 5008 - ELEV B

GFA: 4398

DATE Apr-22
LO# 95291

WINTER NATURAL AIR CHANGE RATE 0.234
SUMMER NATURAL AIR CHANGE RATE 0.076

HEAT LOSS AT °F. 74
HEAT GAIN AT °F. 11

CSA-F280-12
SB-12 PERFORMANCE

ROOM USE	EXP. WALL	CLG. HT.	PRI	ENS	BED-5	MEDIA	BED-2	BED-3	BATH-1	BED-4	BATH-2		
			28	24	14	21	39	40	7	16	10		
			9	9	9	9	10	10	9	9	9		
FACTORS													
GRS.WALL AREA	LOSS	GAIN	252	216	126	189	390	400	63	144	90		
GLAZING	LOSS	GAIN							LOSS	GAIN	LOSS	GAIN	
NORTH	20.8	15.5	9	187	139	9	187	139	0	0	0	0	0
EAST	20.8	41.0	0	0	0	0	0	0	0	0	0	0	0
SOUTH	20.8	24.4	9	187	220	0	0	0	0	0	0	0	0
WEST	20.8	41.0	26	540	1067	18	374	739	0	0	0	0	0
SKYLT.	34.1	100.3	0	0	0	0	0	0	0	0	0	0	0
DOORS	24.7	3.7	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	3.5	0.5	208	721	107	189	655	97	108	374	56	165	572
NET EXPOSED BSMT WALL ABOVE GR	3.5	0.5	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.3	0.6	404	506	225	143	179	80	210	263	117	441	553
NO ATTIC EXPOSED CLG	2.7	1.2	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.5	0.4	0	0	0	0	0	0	0	0	0	0	0
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2142		1395	1012	1623	3605	2641	689	1212	500	
SUB TOTAL HT GAIN				1758	1055	612	702	2760	2142	245	682	130	
LEVEL FACTOR / MULTIPLIER	0.20	0.26				0.20	0.26		0.20	0.26		0.20	0.26
AIR CHANGE HEAT LOSS			557		363	263	422	937	687	179	315	130	
AIR CHANGE HEAT GAIN				97	58	34	39	152	118	14	38	7	
DUCT LOSS			0		0	0	0	454	0	87	0	0	
DUCT GAIN			0		0	0	0	479	0	26	0	0	
HEAT GAIN PEOPLE	240	2	480	0	1	240	0	1	240	0	1	240	0
HEAT GAIN APPLIANCES/LIGHTS			1637	0	1637	1637	1637	1637	1637	0	1637	0	
TOTAL HT LOSS BTU/H			2698		1758	1275	2045	4996	3327	954	1527	630	
TOTAL HT GAIN x 1.3 BTU/H			5163		1447	3279	3090	6848	5378	369	3375	178	

ROOM USE	EXP. WALL	CLG. HT.	ENS-5										
			17										
			9										
FACTORS													
GRS.WALL AREA	LOSS	GAIN	153										
GLAZING	LOSS	GAIN											
NORTH	20.8	15.5	0	0	0								
EAST	20.8	41.0	0	0	0								
SOUTH	20.8	24.4	0	0	0								
WEST	20.8	41.0	9	187	369								
SKYLT.	34.1	100.3	0	0	0								
DOORS	24.7	3.7	0	0	0								
NET EXPOSED WALL	3.5	0.5	144	499	74								
NET EXPOSED BSMT WALL ABOVE GR	3.5	0.5	0	0	0								
EXPOSED CLG	1.3	0.6	70	88	39								
NO ATTIC EXPOSED CLG	2.7	1.2	0	0	0								
EXPOSED FLOOR	2.5	0.4	0	0	0								
BASEMENT/CRAWL HEAT LOSS			0										
SLAB ON GRADE HEAT LOSS			0										
SUBTOTAL HT LOSS			774										
SUB TOTAL HT GAIN				482									
LEVEL FACTOR / MULTIPLIER	0.20	0.26											
AIR CHANGE HEAT LOSS			201										
AIR CHANGE HEAT GAIN				27									
DUCT LOSS			0										
DUCT GAIN			0										
HEAT GAIN PEOPLE	240	0	0										
HEAT GAIN APPLIANCES/LIGHTS			0										
TOTAL HT LOSS BTU/H			975										
TOTAL HT GAIN x 1.3 BTU/H			662										

TOTAL HEAT GAIN BTU/H:

63826

TONS: 5.32

LOSS DUE TO VENTILATION LOAD BTU/H: 6010

STRUCTURAL HEAT LOSS: 64304

TOTAL COMBINED HEAT LOSS BTU/H: 70314

SITE NAME: VALES OF HUMBER SOUTH
BUILDER: ROYAL PINE HOMES

OPT 2ND
TYPE: 5008 - ELEV B

DATE: Apr-22

GFA: 4398 LO# 95291

FURNACE 1

HEATING CFM 1145 COOLING CFM 1145
TOTAL HEAT LOSS 44,118 TOTAL HEAT GAIN 33,589
AIR FLOW RATE CFM 25.95 AIR FLOW RATE CFM 34.09

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 47123 BTUH

#*CARRIER
59SP5A-60-14
FAN SPEED 60
LOW 0
MEDLOW 785
MEDIUM 960
MEDIUM HIGH 1145
HIGH 1440

AFUE = 97 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 58,000

DESIGN CFM = 1145
CFM @ .6" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	0	14	7
R/A	0	0	0	3	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	21	22	23	24
ROOM NAME	STUDY	STUDY	GREAT	GREAT	KIT	KIT	KIT	DIN	LIV	LIV	LIV	FOY	FOY	LAUN	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.21	1.21	1.43	1.43	1.66	1.66	1.66	1.45	1.10	1.10	1.10	2.00	2.00	3.60	3.07	3.07	3.07	3.07
CFM PER RUN HEAT	31	31	37	37	43	43	43	38	29	29	29	52	52	94	80	80	80	80
RM GAIN MBH.	2.18	2.18	2.50	2.50	2.60	2.60	2.60	3.10	1.71	1.71	1.71	1.79	1.79	3.02	0.23	0.23	0.23	0.23
CFM PER RUN COOLING	74	74	85	85	89	89	89	106	58	58	58	61	61	103	8	8	8	8
ADJUSTED PRESSURE	0.17	0.17	0.16	0.16	0.16	0.16	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	47	41	39	25	24	30	20	31	48	43	38	44	39	42	23	31	37	26
EQUIVALENT LENGTH	160	150	160	140	110	110	100	100	120	110	100	130	100	160	100	140	100	110
TOTAL EFFECTIVE LENGTH	207	191	199	165	134	140	120	131	168	153	138	174	139	202	123	171	137	136
ADJUSTED PRESSURE	0.08	0.09	0.08	0.1	0.12	0.12	0.14	0.12	0.1	0.11	0.12	0.1	0.12	0.08	0.14	0.1	0.13	0.13
ROUND DUCT SIZE	5	5	6	6	6	6	6	6	5	5	4	5	5	6	5	5	5	5
HEATING VELOCITY (ft/min)	228	228	189	189	219	219	219	194	213	213	333	382	382	479	587	587	587	587
COOLING VELOCITY (ft/min)	543	543	433	433	454	454	454	540	426	426	665	448	448	525	59	59	59	59
OUTLET GRILL SIZE	3X10	3X10	4X10	4X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10
TRUNK	A	A	A	A	A	A	B	D	C	C	C	C	D	B	B	A	B	B

RUN #	25	26	27
ROOM NAME	BAS	BAS	BAS
RM LOSS MBH.	3.07	3.07	3.07
CFM PER RUN HEAT	80	80	80
RM GAIN MBH.	0.23	0.23	0.23
CFM PER RUN COOLING	8	8	8
ADJUSTED PRESSURE	0.17	0.17	0.17
ACTUAL DUCT LGH.	27	26	39
EQUIVALENT LENGTH	140	100	120
TOTAL EFFECTIVE LENGTH	167	126	159
ADJUSTED PRESSURE	0.1	0.14	0.11
ROUND DUCT SIZE	5	5	5
HEATING VELOCITY (ft/min)	587	587	587
COOLING VELOCITY (ft/min)	59	59	59
OUTLET GRILL SIZE	3X10	3X10	3X10
TRUNK	D	D	C

SUPPLY AIR TRUNK SIZE													RETURN AIR TRUNK SIZE												
	TRUNK	STATIC	ROUND	RECT			VELOCITY		TRUNK	STATIC	ROUND	RECT			VELOCITY		TRUNK	STATIC	ROUND	RECT			VELOCITY		
	CFM	PRESS.	DUCT	DUCT			(ft/min)		CFM	PRESS.	DUCT	DUCT			(ft/min)		CFM	PRESS.	DUCT	DUCT			(ft/min)		
TRUNK A	302	0.08	9	12	x	8	453	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.07	0	0	x	8	0		
TRUNK B	679	0.08	12.1	18	x	8	679	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.07	0	0	x	8	0		
TRUNK C	219	0.10	7.5	8	x	8	493	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.07	0	0	x	8	0		
TRUNK D	469	0.10	10	12	x	8	704	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.07	0	0	x	8	0		
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.07	0	0	x	8	0		
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.07	0	0	x	8	0		

RETURN AIR #	1	2	3												BR
AIR VOLUME	205	360	360	0	0	0	0	0	0	0	0	0	0	0	220
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	43	23	23	1	1	1	1	1	1	1	1	1	1	1	18
EQUIVALENT LENGTH	130	145	150	0	0	0	0	0	0	0	0	0	0	0	190
TOTAL EFFECTIVE LH	173	168	173	1	1	1	1	1	1	1	1	1	1	1	208
ADJUSTED PRESSURE	0.09	0.09	0.09	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.07
ROUND DUCT SIZE	7.5	9.3	9.3	0	0	0	0	0	0	0	0	0	0	0	8.2
INLET GRILL SIZE	8	8	8	0	0	0	0	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	30	30	0	0	0	0	0	0	0	0	0	0	0	24

SITE NAME: VALES OF HUMBER SOUTH
BUILDER: ROYAL PINE HOMES

OPT 2ND
TYPE: 5008 - ELEV B

DATE: Apr-22

GFA: 4398 LO# 95291

FURNACE 2

HEATING CFM 875 COOLING CFM 875
TOTAL HEAT LOSS 20,186 TOTAL HEAT GAIN 29,791
AIR FLOW RATE CFM 43.35 AIR FLOW RATE CFM 29.37

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

**FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 23191 BTUH**
#CARRIER
59SP5A-40-10 40
FAN SPEED
LOW 0
MEDLOW 0
MEDIUM 0
MEDIUM HIGH 710
HIGH 875

AFUE = 97 %
INPUT (BTU/H) = 40,000
OUTPUT (BTU/H) = **39,000**

DESIGN CFM = **875**
CFM @ .6" E.S.P.

TEMPERATURE RISE 41 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	18	0	0
R/A	0	0	7	0	0

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
ROOM NAME	ENS-5	PRI	PRI	ENS	MEDIA	MEDIA	BATH-1	BED-2	BED-2	BED-2	BED-3	BED-3	BATH-2	BED-4	BED-4	BATH-1	BED-5	BED-5
RM LOSS MBH.	0.98	1.35	1.35	1.76	1.02	1.02	0.48	1.67	1.67	1.67	1.66	1.66	0.63	0.76	0.76	0.48	0.64	0.64
CFM PER RUN HEAT	42	58	58	76	44	44	21	72	72	72	72	72	27	33	33	21	28	28
RM GAIN MBH.	0.66	2.58	2.58	1.45	1.55	1.55	0.18	2.28	2.28	2.28	2.69	2.69	0.18	1.69	1.69	0.18	1.64	1.64
CFM PER RUN COOLING	19	76	76	43	45	45	5	67	67	67	79	79	5	50	50	5	48	48
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	41	69	53	58	56	54	59	58	62	68	62	59	57	67	31	60	49	44
EQUIVALENT LENGTH	160	150	140	160	170	190	140	140	140	110	170	150	110	150	160	140	170	170
TOTAL EFFECTIVE LENGTH	201	219	193	218	226	244	199	198	202	178	232	209	167	217	191	200	219	214
ADJUSTED PRESSURE	0.09	0.08	0.09	0.08	0.08	0.07	0.09	0.09	0.09	0.1	0.07	0.08	0.1	0.08	0.09	0.09	0.08	0.08
ROUND DUCT SIZE	4	6	6	6	5	5	4	5	5	5	6	6	4	5	6	4	5	5
HEATING VELOCITY (ft/min)	482	296	296	388	323	323	241	529	529	529	367	367	310	242	168	241	206	206
COOLING VELOCITY (ft/min)	218	388	388	219	330	330	57	492	492	492	403	403	57	367	255	57	352	352
OUTLET GRILL SIZE	3X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	4X10	3X10	3X10	3X10
TRUNK	C	C	C	C	C	C	B	A	A	B	A	A	B	B	B	B	C	C

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
ROOM NAME	ENS-5	PRI	PRI	ENS	MEDIA	MEDIA	BATH-1	BED-2	BED-2	BED-2	BED-3	BED-3	BATH-2	BED-4	BED-4	BATH-1	BED-5	BED-5
RM LOSS MBH.	0.98	1.35	1.35	1.76	1.02	1.02	0.48	1.67	1.67	1.67	1.66	1.66	0.63	0.76	0.76	0.48	0.64	0.64
CFM PER RUN HEAT	42	58	58	76	44	44	21	72	72	72	72	72	27	33	33	21	28	28
RM GAIN MBH.	0.66	2.58	2.58	1.45	1.55	1.55	0.18	2.28	2.28	2.28	2.69	2.69	0.18	1.69	1.69	0.18	1.64	1.64
CFM PER RUN COOLING	19	76	76	43	45	45	5	67	67	67	79	79	5	50	50	5	48	48
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	41	69	53	58	56	54	59	58	62	68	62	59	57	67	31	60	49	44
EQUIVALENT LENGTH	160	150	140	160	170	190	140	140	140	110	170	150	110	150	160	140	170	170
TOTAL EFFECTIVE LENGTH	201	219	193	218	226	244	199	198	202	178	232	209	167	217	191	200	219	214
ADJUSTED PRESSURE	0.09	0.08	0.09	0.08	0.08	0.07	0.09	0.09	0.09	0.1	0.07	0.08	0.1	0.08	0.09	0.09	0.08	0.08
ROUND DUCT SIZE	4	6	6	6	5	5	4	5	5	5	6	6	4	5	6	4	5	5
HEATING VELOCITY (ft/min)	482	296	296	388	323	323	241	529	529	529	367	367	310	242	168	241	206	206
COOLING VELOCITY (ft/min)	218	388	388	219	330	330	57	492	492	492	403	403	57	367	255	57	352	352
OUTLET GRILL SIZE	3X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	3X10	3X10	4X10	3X10	3X10	3X10
TRUNK	C	C	C	C	C	C	B	A	A	B	A	A	B	B	B	B	C	C

SUPPLY AIR TRUNK SIZE	TRUNK	STATIC	ROUND	RECT	VELOCITY	TRUNK	STATIC	ROUND	RECT	VELOCITY	RETURN AIR TRUNK SIZE	TRUNK	STATIC	ROUND	RECT	VELOCITY
	CFM	PRESS.	DUCT	DUCT	(ft/min)	CFM	PRESS.	DUCT	DUCT	(ft/min)		CFM	PRESS.	DUCT	DUCT	(ft/min)
TRUNK A	288	0.07	9.1	10	x 8	518	0	0.00	0	0	x 8	0	0.05	0	0	x 8
TRUNK B	495	0.07	11.1	14	x 8	636	0	0.00	0	0	x 8	0	0.05	0	0	x 8
TRUNK C	378	0.07	10.1	12	x 8	567	0	0.00	0	0	x 8	0	0.05	0	0	x 8
TRUNK D	0	0.00	0	0	x 8	0	0	0.00	0	0	x 8	0	0.05	0	0	x 8
TRUNK E	0	0.00	0	0	x 8	0	0	0.00	0	0	x 8	0	0.05	0	0	x 8
TRUNK F	0	0.00	0	0	x 8	0	0	0.00	0	0	x 8	0	0.05	0	0	x 8

RETURN AIR #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
AIR VOLUME	130	130	130	115	75	210	85	0	0	0	0	0	0	0	0	0	0	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	62	57	61	82	66	64	58	1	1	1	1	1	1	1	1	1	1	1
EQUIVALENT LENGTH	180	175	175	220	215	215	165	0	0	0	0	0	0	0	0	0	0	0
TOTAL EFFECTIVE LH	242	232	236	302	281	279	223	1	1	1	1	1	1	1	1	1	1	1
ADJUSTED PRESSURE	0.06	0.06	0.06	0.05	0.05	0.05	0.07	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80
ROUND DUCT SIZE	7	7	7	7	6	8.8	5.8	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0
INLET GRILL SIZE	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	14	14	14	14	14	30	14	0	0	0	0	0	0	0	0	0	0	0

TYPE: 5008 - ELEV B
SITE NAME: VALES OF HUMBER SOUTH

LO # 95291
OPT 2ND

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm	<u>42.4</u> cfm
Other Bedrooms	<u>4</u> @ 10.6 cfm	<u>42.4</u> cfm
Kitchen & Bathrooms	<u>6</u> @ 10.6 cfm	<u>63.6</u> cfm
Other Rooms	<u>7</u> @ 10.6 cfm	<u>74.2</u> cfm
Table 9.32.3.A.	TOTAL	<u>222.6</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		<u>95.4</u> cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>222.6</u>	cfm
Less Principal Ventil. Capacity	<u>150</u>	cfm
Required Supplemental Capacity	<u>72.6</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model: VANEE V150H	Location: BSMT
<u>150.0</u> cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
150.0 CFM	X 74 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		BY INSTALLING CONTRACTOR		
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	☒	3.5
BATH-1	BY INSTALLING CONTRACTOR	50	☒	3.5
BATH-2	BY INSTALLING CONTRACTOR	50	☒	3.5
BATH-3	BY INSTALLING CONTRACTOR	50	☒	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model: VANEE V150H	INSTALL 2 HRV / ERV's	
<u>150</u> cfm high	<u>35</u> cfm low	
<u>75</u> % Sensible Efficiency	☒ HVI Approved	
@ 32 deg F (0 deg C)		

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER: ROYAL PINE HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-22

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 95291	Model: 5008 - ELEV B	Builder: ROYAL PINE HOMES	Date: 2022-04-06																																																									
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>2073</td> <td>10</td> <td>20730</td> </tr> <tr> <td>First</td> <td>2073</td> <td>11</td> <td>22803</td> </tr> <tr> <td>Second</td> <td>2400</td> <td>9</td> <td>21600</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>65,133.0 ft³</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>1844.4 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	2073	10	20730	First	2073	11	22803	Second	2400	9	21600	Third	0	9	0	Fourth	0	9	0	Total:			65,133.0 ft³	Total:			1844.4 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%;">0.234</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.076</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-19</td> <td>41</td> <td>74</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>30</td> <td>6</td> <td>11</td> </tr> </table>		WINTER NATURAL AIR CHANGE RATE	0.234	SUMMER NATURAL AIR CHANGE RATE	0.076	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-19	41	74	Summer DTDc	24	30	6	11
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	2073	10	20730																																																									
First	2073	11	22803																																																									
Second	2400	9	21600																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			65,133.0 ft³																																																									
Total:			1844.4 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.234																																																											
SUMMER NATURAL AIR CHANGE RATE	0.076																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-19	41	74																																																								
Summer DTDc	24	30	6	11																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.234 x 512.32 x 41 °C x 1.2 = 5940 W = 20268 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.076 x 512.32 x 6 °C x 1.2 = 286 W = 977 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E) \times 2 \text{ HRV / ERV's}$ 300 CFM x 74 °F x 1.08 x 0.25 = 6010 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 300 CFM x 11 °F x 1.08 x 0.25 = 891 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = \text{Level Factor} \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$																																																												
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HLlevel)																																																								
1	0.5	20,268	11,375	0.891																																																								
2	0.3		16,529	0.368																																																								
3	0.2		15,592	0.260																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																												
				Michael O'Rourke BCIN# 19669 																																																								

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: 5008 - ELEV B	OPT 2ND	BUILDER: ROYAL PINE HOMES
SFQT: 4398	LO# 95291	SITE: VALES OF HUMBER SOUTH

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-2	OUTDOOR DESIGN TEMP.	86
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.60

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	2.50	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	TIGHT	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft ³):	65133.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	6
INTERIOR LIGHTING LOAD (Btu/h/ft ²):	3.00	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	7.0 ft
LENGTH: 69.0 ft	WIDTH: 42.0 ft	EXPOSED PERIMETER:	222.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package
SB-12 PERFORMANCE****Nominal** **Min. Eff.**

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22+1.5	21.40
Basement Walls Minimum RSI (R)-Value	20	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	1.6	-
Skylights Maximum U-Value	2.6	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.9	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Brampton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	21.0	
Floor Width (m):	12.8	
Exposed Perimeter (m):	0.0	
Wall Height (m):	3.0	
Depth Below Grade (m):	2.13	
Window Area (m ²):	2.2	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		2357

TYPE: 5008 - ELEV B
LO# 95291

OPT 2ND


Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Brampton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.01			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	1844.4			
Air Leakage/Ventilation				
Air Tightness Type:	Energy Star Detached (2.5 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1721.7 cm ²		
	2.50	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	70.8	70.8		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.234			
Cooling Air Leakage Rate (ACH/H):	0.076			

TYPE: 5008 - ELEV B
LO# 95291

OPT 2ND



FURNACE 1 (F-1)
CARRIER 59SP5A-60-14
58000 BTU/H OUTPUT
3.0 TONS A/C @ 1145 cfm

FURNACE 2 (F-2)
CARRIER 59SP5A-40-10
39000 BTU/H OUTPUT
2.5 TONS A/C @ 875 cfm

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

CSA-F280-12


SB-12 PERFORMANCE

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	REVISED TO PERFORMANCE PATH	APR/2022
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title			
ROYAL PINE HOMES			BASEMENT HEATING LAYOUT			
Project Name			Date			
VALES OF HUMBER SOUTH BRAMPTON, ONTARIO			Scale			
OPT 2ND			BCIN# 19669			
5008 - ELEV B			LO#			
4398 sqft			95291			

	S/A	R/A	FANS
2ND	18	7	4
1ST	14	3	2
BAS	7	1	0



I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.


CSA-F280-12

SB-12 PERFORMANCE

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	REVISED TO PERFORMANCE PATH	APR/2022
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.					Sheet Title	
ROYAL PINE HOMES							FIRST FLOOR HEATING LAYOUT	
Project Name							Date	MAR/2022
VALES OF HUMBER SOUTH BRAMPTON, ONTARIO							Scale	3/16" = 1'-0"
OPT 2ND							BCIN# 19669	
5008 - ELEV B	4398 sqft					LO#	95291	



I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

CSA-F280-12

SB-12 PERFORMANCE

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	REVISED TO PERFORMANCE PATH	APR/2022
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

Client

ROYAL PINE HOMES

Project Name

VALES OF HUMBER SOUTH
BRAMPTON, ONTARIO

OPT 2ND
5008 - ELEV B

4398 sqft

HVACDESIGNS LTD.

375 Finley Ave. Suite 202 - Ajax, Ontario
L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375
Email: info@hvacdesigns.ca
Web: www.hvacdesigns.ca
Specializing in Residential Mechanical Design Services

Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.

	S/A	R/A	FANS
2ND	18	7	4
1ST	14	3	2
BAS	7	1	0

Sheet Title

SECOND FLOOR
HEATING
LAYOUT

Date

MAR/2022

Scale

3/16" = 1'-0"

BCIN# 19669

LO#

95291