

Schedule 1: Designer Information

Use one form for each individual who reviews and takes responsibility for design activities with respect to the project.

A. Project Information			
Building number, street name		Unit no.	Lot/con.
Municipality BRAMPTON	Postal code	Plan number/ other description	
B. Individual who reviews and takes responsibility for design activities			
Name MICHAEL O'ROURKE		Firm HVAC DESIGNS LTD.	
Street address 375 FINLEY AVE		Unit no. 202	Lot/con. N/A
Municipality AJAX	Postal code L1S 2E2	Province ONTARIO	E-mail info@hvacdesigns.ca
Telephone number (905) 619-2300	Fax number (905) 619-2375	Cell number ()	
C. Design activities undertaken by individual identified in Section B. [Building Code Table 3.5.2.1 OF Division C]			
☐ House ☐ Small Buildings ☐ Large Buildings ☐ Complex Buildings ☒ HVAC – House ☐ Building Services ☐ Detection, Lighting and Power ☐ Fire Protection ☐ Building Structural ☐ Plumbing – House ☐ Plumbing – All Buildings ☐ On-site Sewage Systems			
Description of designer's work HEAT LOSS / GAIN CALCULATIONS DUCT SIZING RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY RESIDENTIAL SYSTEM DESIGN per CSA-F280-12		Model: 6003 Project: VALES OF HUMBER SOUTH	
D. Declaration of Designer			
I, <u>MICHAEL O'ROURKE</u> (print name) declare that (choose one as appropriate):			
☐ I review and take responsibility for the design work on behalf of a firm registered under subsection 3.2.4. of Division C, of the Building Code. I am qualified, and the firm is registered, in the appropriate classes/categories. Individual BCIN: _____ Firm BCIN: _____			
☒ I review and take responsibility for the design and am qualified in the appropriate category as an "other designer" under subsection 3.2.5. of Division C, of the Building Code. Individual BCIN: <u>19669</u> Basis for exemption from registration and qualification: <u>O.B.C SENTENCE 3.2.4.1 (4)</u>			
☐ The design work is exempt from the registration and qualification requirements of the Building Code. Basis for exemption from registration and qualification: _____			
I certify that:			
1. The information contained in this schedule is true to the best of my knowledge. 2. I have submitted this application with the knowledge and consent of the firm.			
April 6, 2022			
Date		Signature of Designer	

NOTE:

- For the purposes of this form, "individual" means the "person" referred to in Clause 3.2.4.7(1) d) of Division C, Article 3.2.5.1. of Division C, and all other persons who are exempt from qualification under Subsections 3.2.4. and 3.2.5. of Division C.
- Schedule 1 is not required to be completed by a holder of a license, temporary license, or a certificate of authorization, issued by the Ontario Association of Architects. Schedule 1 is also not required to be completed by a holder of a license to practise, a limited license to practise, or a certificate of authorization, issued by the Association of Professional Engineers of Ontario.

Application for a Permit Construct or Demolish – Effective January 1, 2015

[illegible]

TOTAL HEAT GAIN BTU/H:	70412	TONS: 5.87	LOSS DUE TO VENTILATION LOAD BTU/H: 6010	STRUCTURAL HEAT LOSS: 73079	TOTAL COMBINED HEAT LOSS BTU/H: 79089
------------------------	-------	------------	--	-----------------------------	---------------------------------------

Michael Kounhe

SITE NAME: VALES OF HUMBER SOUTH

BUILDER: ROYAL PINE HOMES

TYPE: 6003

GFA: 5041

DATE Apr-22

LO# 95293

WINTER NATURAL AIR CHANGE RATE 0.234

SUMMER NATURAL AIR CHANGE RATE 0.076

HEAT LOSS AT °F. 74

HEAT GAIN AT °F. 11

CSA-F280-12

SB-12 PERFORMANCE

ROOM USE	EXP. WALL	CLG. HT.	PRI	ENS	DRESS	BED-2	BED-3	BED-4	BED-5	ENS-2	ENS-3	ENS-4		
			37	11	14	43	39	41	33	10	10	7		
			10	9	9	9	10	10	10	9	9	9		
GRS.WALL AREA	LOSS	GAIN	370	99	126	387	390	410	330	90	90	63		
GLAZING	LOSS	GAIN		LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	LOSS	GAIN	
NORTH	20.8	15.5	0	0	0	0	0	0	0	0	0	0	0	0
EAST	20.8	41.0	0	0	0	0	0	0	0	0	0	0	0	0
SOUTH	20.8	24.4	0	0	0	18	374	439	0	0	0	0	0	0
WEST	20.8	41.0	36	748	1478	18	374	739	0	0	0	0	0	0
SKYLT.	34.1	100.3	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	24.7	3.7	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	3.5	0.5	334	1158	172	81	281	42	108	374	56	351	1217	180
NET EXPOSED BSMT WALL ABOVE GR	3.5	0.5	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.3	0.6	570	714	318	209	262	116	196	246	109	380	476	212
NO ATTIC EXPOSED CLG	2.7	1.2	0	0	0	0	0	0	0	0	0	50	134	60
EXPOSED FLOOR	2.5	0.4	0	0	0	0	0	0	0	0	0	300	747	111
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2620		917	994	2441	3301	3236	2332	875	875	645	
SUB TOTAL HT GAIN				1967	897	604	1870	2126	3481	2209	281	281	428	
LEVEL FACTOR / MULTIPLIER	0.20	0.25				0.20	0.25		0.20	0.25		0.20	0.25	
AIR CHANGE HEAT LOSS			645		226	245	601	812	796	574	215	215	159	
AIR CHANGE HEAT GAIN				103	47	32	98	112	183	116	15	15	23	
DUCT LOSS			0		0	0	0	411	0	0	109	109	80	
DUCT GAIN			0		0	0	0	435	0	0	30	30	45	
HEAT GAIN PEOPLE	240	2	480	0	0	0	1	240	1	240	0	0	0	
HEAT GAIN APPLIANCES/LIGHTS			1872	0	0	0	1872	1872	1872	1872	0	0	0	
TOTAL HT LOSS BTU/H			3265		1142	1239	3042	4524	4033	2906	1199	1199	884	
TOTAL HT GAIN x 1.3 BTU/H			5749		1227	826	5304	6220	7508	5767	423	423	644	

ROOM USE	EXP. WALL	CLG. HT.	ENS-5											
			9											
			9											
GRS.WALL AREA	LOSS	GAIN	81											
GLAZING	LOSS	GAIN												
NORTH	20.8	15.5	0	0	0									
EAST	20.8	41.0	0	0	0									
SOUTH	20.8	24.4	9	187	220									
WEST	20.8	41.0	0	0	0									
SKYLT.	34.1	100.3	0	0	0									
DOORS	24.7	3.7	0	0	0									
NET EXPOSED WALL	3.5	0.5	72	250	37									
NET EXPOSED BSMT WALL ABOVE GR	3.5	0.5	0	0	0									
EXPOSED CLG	1.3	0.6	117	147	65									
NO ATTIC EXPOSED CLG	2.7	1.2	0	0	0									
EXPOSED FLOOR	2.5	0.4	0	0	0									
BASEMENT/CRAWL HEAT LOSS			0											
SLAB ON GRADE HEAT LOSS			0											
SUBTOTAL HT LOSS			583											
SUB TOTAL HT GAIN				322										
LEVEL FACTOR / MULTIPLIER	0.20	0.25												
AIR CHANGE HEAT LOSS			144											
AIR CHANGE HEAT GAIN				17										
DUCT LOSS			0											
DUCT GAIN			0											
HEAT GAIN PEOPLE	240	0	0											
HEAT GAIN APPLIANCES/LIGHTS			0											
TOTAL HT LOSS BTU/H			727											
TOTAL HT GAIN x 1.3 BTU/H			440											

TOTAL HEAT GAIN BTU/H:

70412

TONS: 5.87

LOSS DUE TO VENTILATION LOAD BTU/H: 6010

STRUCTURAL HEAT LOSS: 73079

TOTAL COMBINED HEAT LOSS BTU/H: 79089

SITE NAME: VALES OF HUMBER SOUTH
BUILDER: ROYAL PINE HOMES

TYPE: 6003

DATE: Apr-22

GFA: 5041

LO# 95293

FURNACE 1

HEATING CFM 1145
TOTAL HEAT LOSS 48,919
AIR FLOW RATE CFM 23.41

COOLING CFM 1145
TOTAL HEAT GAIN 35,435
AIR FLOW RATE CFM 32.31

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure for s/a & r/a 0.35

FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 51924 BTUH

#*CARRIER

59SP5A-60-14

FAN SPEED LOW

MEDLOW 0

MEDIUM 785

MEDIUM HIGH 960

HIGH 1145

1440

AFUE = 97 %
INPUT (BTU/H) = 60,000
OUTPUT (BTU/H) = 58,000

DESIGN CFM = 1145
CFM @ .6" E.S.P.

TEMPERATURE RISE 47 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	0	17	8
R/A	0	0	0	4	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	21	22	23	24
ROOM NAME	GREAT	GREAT	GREAT	KIT	KIT	KIT	PANT	DIN	DIN	LIV	LIV	FOY	LIBR	LIBR	LIBR	PWD	LAUN	BAS	BAS	BAS	BAS
RM LOSS MBH.	1.94	1.94	1.94	1.23	1.23	1.23	1.05	1.10	1.10	1.53	1.53	3.28	1.19	1.19	1.19	0.37	2.02	2.98	2.98	2.98	2.98
CFM PER RUN HEAT	45	45	45	29	29	29	25	26	26	36	36	77	28	28	28	9	47	70	70	70	70
RM GAIN MBH.	2.23	2.23	2.23	2.26	2.26	2.26	0.15	1.92	1.92	2.70	2.70	1.59	2.20	2.20	2.20	0.05	2.73	0.20	0.20	0.20	0.20
CFM PER RUN COOLING	72	72	72	73	73	73	5	62	62	87	87	51	71	71	71	2	88	7	7	7	7
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	55	69	52	43	37	38	36	16	16	34	29	27	39	47	48	32	46	43	33	64	54
EQUIVALENT LENGTH	150	120	120	120	120	130	150	100	100	110	110	110	130	170	170	90	190	140	150	130	140
TOTAL EFFECTIVE LENGTH	205	189	172	163	157	168	186	116	116	144	139	137	169	217	218	122	236	183	183	194	194
ADJUSTED PRESSURE	0.08	0.09	0.1	0.11	0.11	0.1	0.09	0.15	0.15	0.11	0.12	0.13	0.1	0.08	0.08	0.14	0.07	0.09	0.09	0.09	0.09
ROUND DUCT SIZE	6	6	6	5	5	5	4	5	5	5	5	5	5	5	5	4	6	5	5	5	5
HEATING VELOCITY (ft/min)	229	229	229	213	213	213	287	191	191	264	264	565	206	206	206	103	240	514	514	514	514
COOLING VELOCITY (ft/min)	367	367	367	536	536	536	57	455	455	639	639	374	521	521	521	23	449	51	51	51	51
OUTLET GRILL SIZE	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10
TRUNK	A	A	A	B	B	B	B	C	E	D	D	D	D	D	D	E	A	B	B	A	A

RUN #	25	26	27	28
ROOM NAME	BAS	BAS	BAS	BAS
RM LOSS MBH.	2.98	2.98	2.98	2.98
CFM PER RUN HEAT	70	70	70	70
RM GAIN MBH.	0.20	0.20	0.20	0.20
CFM PER RUN COOLING	7	7	7	7
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	17	19	28	40
EQUIVALENT LENGTH	100	120	160	150
TOTAL EFFECTIVE LENGTH	117	139	188	190
ADJUSTED PRESSURE	0.15	0.12	0.09	0.09
ROUND DUCT SIZE	5	5	5	5
HEATING VELOCITY (ft/min)	514	514	514	514
COOLING VELOCITY (ft/min)	51	51	51	51
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10
TRUNK	E	E	D	D

SUPPLY AIR TRUNK SIZE														RETURN AIR TRUNK SIZE													
	TRUNK	STATIC	ROUND	RECT			VELOCITY		TRUNK	STATIC	ROUND	RECT			VELOCITY		TRUNK	STATIC	ROUND	RECT			VELOCITY				
	CFM	PRESS.	DUCT	DUCT			(ft/min)		CFM	PRESS.	DUCT	DUCT			(ft/min)		CFM	PRESS.	DUCT	DUCT			(ft/min)				
TRUNK A	322	0.07	9.5	10	x	8	580	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.07	0	0	x	8	0				
TRUNK B	252	0.09	8.1	8	x	8	567	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.07	0	0	x	8	0				
TRUNK C	600	0.07	12	16	x	8	675	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.07	0	0	x	8	0				
TRUNK D	373	0.08	9.7	12	x	8	560	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.07	0	0	x	8	0				
TRUNK E	548	0.08	11.2	16	x	8	617	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.07	0	0	x	8	0				
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.07	0	0	x	8	0				

RETURN AIR #	1	2	3	4												BR								
AIR VOLUME	290	340	135	135	0	0	0	0	0	0	0	0	0	0	0	245	TRUNK W	0	0.07	0	0	x	8	0
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	TRUNK X	875	0.07	13.8	24	x	8	656
ACTUAL DUCT LGH.	60	27	32	48	1	1	1	1	1	1	1	1	1	1	1	21	TRUNK Y	270	0.07	8.9	10	x	8	486
EQUIVALENT LENGTH	160	145	155	160	0	0	0	0	0	0	0	0	0	0	0	150	TRUNK Z	290	0.07	9.1	10	x	8	522
TOTAL EFFECTIVE LH	220	172	187	208	1	1	1	1	1	1	1	1	1	1	1	171	DROP	1145	0.07	15.3	24	x	12	573
ADJUSTED PRESSURE	0.07	0.09	0.08	0.07	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.09								
ROUND DUCT SIZE	9.1	9.1	6.6	6.8	0	0	0	0	0	0	0	0	0	0	0	8								
INLET GRILL SIZE	6	8	8	8	0	0	0	0	0	0	0	0	0	0	0	8								
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X								
INLET GRILL SIZE	30	30	14	14	0	0	0	0	0	0	0	0	0	0	0	24								

SITE NAME: VALES OF HUMBER SOUTH
BUILDER: ROYAL PINE HOMES

TYPE: 6003

DATE: Apr-22

GFA: 5041

LO# 95293

FURNACE 2

HEATING CFM 1040 COOLING CFM 1040
TOTAL HEAT LOSS 24,160 TOTAL HEAT GAIN 34,532
AIR FLOW RATE CFM 43.05 AIR FLOW RATE CFM 30.12

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

**FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 27165 BTUH**
#*CARRIER
59SP5A-40-12 40
FAN SPEED
LOW 0
MEDLOW 0
MEDIUM 0
MEDIUM HIGH 770
HIGH 1040

AFUE = 97 %
INPUT (BTU/H) = 40,000
OUTPUT (BTU/H) = **39,000**

DESIGN CFM = **1040**
CFM @ .6" E.S.P.

TEMPERATURE RISE 35 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	21	0	0
R/A	0	0	6	0	0

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
ROOM NAME	PRI	PRI	PRI	ENS	ENS	DRESS	BED-2	BED-2	BED-2	ENS-2	BED-3	BED-3	BED-3	ENS-3	BED-4	BED-4	BED-4	ENS-4	BED-5	BED-5	ENS-5
RM LOSS MBH.	1.09	1.09	1.09	0.57	0.57	1.24	1.01	1.01	1.01	1.20	1.51	1.51	1.51	1.20	1.34	1.34	1.34	0.88	1.45	1.45	0.73
CFM PER RUN HEAT	47	47	47	25	25	53	44	44	44	52	65	65	65	52	58	58	58	38	63	63	31
RM GAIN MBH.	1.92	1.92	1.92	0.61	0.61	0.83	1.77	1.77	1.77	0.42	2.07	2.07	2.07	0.42	2.50	2.50	2.50	0.64	2.88	2.88	0.44
CFM PER RUN COOLING	58	58	58	18	18	25	53	53	53	13	62	62	62	13	75	75	75	19	87	87	13
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.16	0.17
ACTUAL DUCT LGH.	63	70	76	65	47	39	74	80	86	66	64	68	69	68	54	61	64	54	43	45	41
EQUIVALENT LENGTH	200	200	200	180	160	160	180	180	190	150	130	140	150	150	160	150	180	120	130	150	130
TOTAL EFFECTIVE LENGTH	263	270	276	245	207	199	254	260	276	216	194	208	219	218	214	211	244	174	173	195	171
ADJUSTED PRESSURE	0.07	0.06	0.06	0.07	0.08	0.09	0.07	0.07	0.06	0.08	0.09	0.08	0.08	0.08	0.08	0.08	0.07	0.1	0.09	0.08	0.1
ROUND DUCT SIZE	5	5	5	4	4	5	5	5	5	5	5	5	5	5	6	6	6	4	6	6	4
HEATING VELOCITY (ft/min)	345	345	345	287	287	389	323	323	323	382	477	477	477	382	296	296	296	436	321	321	356
COOLING VELOCITY (ft/min)	426	426	426	207	207	184	389	389	389	95	455	455	455	95	382	382	382	218	444	444	149
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	4X10	3X10	4X10	4X10	3X10
TRUNK	C	C	C	D	D	D	C	C	C	D	B	B	B	D	A	A	A	B	A	A	B

RUN #	ROOM NAME	RM LOSS MBH.	CFM PER RUN HEAT	RM GAIN MBH.	CFM PER RUN COOLING	ADJUSTED PRESSURE	ACTUAL DUCT LGH.	EQUIVALENT LENGTH	TOTAL EFFECTIVE LENGTH	ADJUSTED PRESSURE	ROUND DUCT SIZE	HEATING VELOCITY (ft/min)	COOLING VELOCITY (ft/min)	OUTLET GRILL SIZE	TRUNK
1	PRI	1.09	47	1.92	58	0.17	63	200	263	0.07	5	345	426	3X10	C
2	PRI	1.09	47	1.92	58	0.17	70	200	270	0.06	5	345	426	3X10	C
3	PRI	1.09	47	1.92	58	0.17	76	200	276	0.06	5	345	426	3X10	C
4	ENS	0.57	25	0.61	18	0.17	65	180	245	0.07	4	287	207	3X10	D
5	ENS	0.57	25	0.61	18	0.17	47	160	207	0.08	4	287	207	3X10	D
6	DRESS	1.24	53	0.83	25	0.17	39	160	199	0.09	5	389	184	3X10	D
7	BED-2	1.01	44	1.77	53	0.17	74	180	254	0.07	5	323	389	3X10	C
8	BED-2	1.01	44	1.77	53	0.17	80	180	260	0.07	5	323	389	3X10	C
9	BED-2	1.01	44	1.77	53	0.17	86	190	276	0.06	5	323	389	3X10	C
10	ENS-2	1.20	52	0.42	13	0.17	66	150	216	0.08	5	382	95	3X10	D
11	BED-3	1.51	65	2.07	62	0.17	64	130	194	0.09	5	477	455	3X10	B
12	BED-3	1.51	65	2.07	62	0.17	68	140	208	0.08	5	477	455	3X10	B
13	BED-3	1.51	65	2.07	62	0.17	69	150	219	0.08	5	477	455	3X10	B
14	ENS-3	1.20	52	0.42	13	0.17	54	160	218	0.08	5	382	95	3X10	D
15	BED-4	1.34	58	2.50	75	0.17	61	150	214	0.08	6	296	382	4X10	A
16	BED-4	1.34	58	2.50	75	0.17	64	150	211	0.08	6	296	382	4X10	A
17	BED-4	1.34	58	2.50	75	0.17	64	180	244	0.07	6	296	382	4X10	A
18	ENS-4	0.88	38	0.64	19	0.17	54	120	174	0.1	4	436	218	3X10	B
19	BED-5	1.45	63	2.88	87	0.16	43	130	195	0.09	6	321	444	4X10	A
20	BED-5	1.45	63	2.88	87	0.16	45	150	195	0.08	6	321	444	4X10	A
21	ENS-5	0.73	31	0.44	13	0.17	41	130	171	0.1	4	356	149	3X10	B

SUPPLY AIR TRUNK SIZE														RETURN AIR TRUNK SIZE													
	TRUNK	STATIC	ROUND	RECT		VELOCITY		TRUNK	STATIC	ROUND	RECT		VELOCITY		TRUNK	STATIC	ROUND	RECT		VELOCITY							
	CFM	PRESS.	DUCT	DUCT		(ft/min)		CFM	PRESS.	DUCT	DUCT		(ft/min)		CFM	PRESS.	DUCT	DUCT		(ft/min)							
TRUNK A	300	0.07	9.2	12	x	8	450	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.06	0	0	x	8	0				
TRUNK B	564	0.07	11.7	18	x	8	564	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.06	0	0	x	8	0				
TRUNK C	273	0.06	9.3	10	x	8	491	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.06	0	0	x	8	0				
TRUNK D	480	0.06	11.4	16	x	8	540	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.06	0	0	x	8	0				
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.06	0	0	x	8	0				
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.06	0	0	x	8	0				

RETURN AIR #	1	2	3	4	5	6																BR
AIR VOLUME	260	130	260	130	130	130	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	
ACTUAL DUCT LGH.	50	77	92	72	44	51	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
EQUIVALENT LENGTH	165	180	175	180	175	205	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
TOTAL EFFECTIVE LH	215	257	267	252	219	256	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
ADJUSTED PRESSURE	0.07	0.06	0.06	0.06	0.07	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	
ROUND DUCT SIZE	8.8	7	9.1	7	6.8	7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
INLET GRILL SIZE	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
INLET GRILL SIZE	30	14	30	14	14	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

TYPE: 6003
SITE NAME: VALES OF HUMBER SOUTH

LO # 95293

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐	Other: Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm	<u>42.4</u> cfm
Other Bedrooms	<u>4</u> @ 10.6 cfm	<u>42.4</u> cfm
Kitchen & Bathrooms	<u>7</u> @ 10.6 cfm	<u>74.2</u> cfm
Other Rooms	<u>6</u> @ 10.6 cfm	<u>63.6</u> cfm
Table 9.32.3.A.	TOTAL	<u>222.6</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		<u>95.4</u> cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>222.6</u>	cfm
Less Principal Ventil. Capacity	<u>150</u>	cfm
Required Supplemental Capacity	<u>72.6</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE V150H
Location:	BSMT
<u>150.0</u> cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
150.0 CFM	X 74 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		BY INSTALLING CONTRACTOR		
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-2	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-3	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-4	BY INSTALLING CONTRACTOR	50	☒	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE V150H	INSTALL 2 HRV / ERV's
<u>150</u>	cfm high	<u>35</u> cfm low
<u>75</u>	% Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER:	
ROYAL PINE HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-22

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE

Michael O'Rourke

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																												
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																												
LO#: 95293	Model: 6003	Builder: ROYAL PINE HOMES	Date: 2022-04-06																																																									
Volume Calculation			Air Change & Delta T Data																																																									
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>2342</td> <td>10</td> <td>23420</td> </tr> <tr> <td>First</td> <td>2342</td> <td>11</td> <td>25762</td> </tr> <tr> <td>Second</td> <td>2803</td> <td>9</td> <td>25227</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>74,409.0 ft³</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>2107.0 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	2342	10	23420	First	2342	11	25762	Second	2803	9	25227	Third	0	9	0	Fourth	0	9	0	Total:			74,409.0 ft³	Total:			2107.0 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 80%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 20%;">0.234</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.076</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> </thead> <tbody> <tr> <td>Winter DTDh</td> <td>22</td> <td>-19</td> <td>41</td> <td>74</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>30</td> <td>6</td> <td>11</td> </tr> </tbody> </table>		WINTER NATURAL AIR CHANGE RATE	0.234	SUMMER NATURAL AIR CHANGE RATE	0.076	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-19	41	74	Summer DTDc	24	30	6	11
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																									
Bsmt	2342	10	23420																																																									
First	2342	11	25762																																																									
Second	2803	9	25227																																																									
Third	0	9	0																																																									
Fourth	0	9	0																																																									
Total:			74,409.0 ft³																																																									
Total:			2107.0 m³																																																									
WINTER NATURAL AIR CHANGE RATE	0.234																																																											
SUMMER NATURAL AIR CHANGE RATE	0.076																																																											
Design Temperature Difference																																																												
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																								
Winter DTDh	22	-19	41	74																																																								
Summer DTDc	24	30	6	11																																																								
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																									
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.234 x 585.29 x 41 °C x 1.2 = 6786 W = 23154 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.076 x 585.29 x 6 °C x 1.2 = 327 W = 1116 Btu/h																																																									
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																									
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E) \times 2 \text{ HRV / ERV's}$ 300 CFM x 74 °F x 1.08 x 0.25 = 6010 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 300 CFM x 11 °F x 1.08 x 0.25 = 891 Btu/h																																																									
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																												
$HL_{airr} = Level \ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$																																																												
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{clevel})																																																								
1	0.5	23,154	12,251	0.945																																																								
2	0.3		18,145	0.383																																																								
3	0.2		18,820	0.246																																																								
4	0		0	0.000																																																								
5	0		0	0.000																																																								
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																												
				Michael O'Rourke BCIN# 19669 																																																								

HEAT LOSS AND GAIN SUMMARY SHEET

MODEL: 6003	BUILDER: ROYAL PINE HOMES
SFQT: 5041	SITE: VALES OF HUMBER SOUTH
LO# 95293	

DESIGN ASSUMPTIONS

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-2	OUTDOOR DESIGN TEMP.	86
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.60

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	2.50	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	TIGHT	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft ³):	74409.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	6
INTERIOR LIGHTING LOAD (Btu/h/ft ²):	2.75	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	7.0 ft
LENGTH: 68.0 ft	WIDTH: 52.0 ft	EXPOSED PERIMETER:	240.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package
SB-12 PERFORMANCE****Nominal Min. Eff.**

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22+1.5	21.40
Basement Walls Minimum RSI (R)-Value	20	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	1.6	-
Skylights Maximum U-Value	2.6	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.9	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Brampton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	20.7	 Insulation Configuration
Floor Width (m):	15.8	
Exposed Perimeter (m):	0.0	
Wall Height (m):	3.0	
Depth Below Grade (m):	2.13	
Window Area (m ²):	2.2	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		2558


TYPE: 6003
LO# 95293

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Brampton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.01			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	2107.0			
Air Leakage/Ventilation				
Air Tightness Type:	Energy Star Detached (2.5 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	1966.9 cm ²		
	2.50	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	70.8	70.8		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.234			
Cooling Air Leakage Rate (ACH/H):	0.076			

TYPE: 6003
LO# 95293



FURNACE 1 (F-1)
CARRIER 59SP5A-60-14
78000 BTU/H OUTPUT
3.0 TONS A/C @ 1145 cfm

FURNACE 2 (F-2)
CARRIER 59SP5A-40-12
39000 BTU/H OUTPUT
3.0 TONS A/C @ 1040 cfm

I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

CSA-F280-12


SB-12 PERFORMANCE

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	REVISED TO PERFORMANCE PATH	APR/2022
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title			
ROYAL PINE HOMES			BASEMENT HEATING LAYOUT			
Project Name			Date			
VALES OF HUMBER SOUTH BRAMPTON, ONTARIO			Scale			
6003		5041 sqft	BCIN# 19669			
			LO# 95293			

	S/A	R/A	FANS
2ND	21	6	6
1ST	17	4	3
BAS	8	1	0



CSA-F280-12


SB-12 PERFORMANCE

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	REVISED TO PERFORMANCE PATH	APR/2022
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		HVACDESIGNS LTD. 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title			
ROYAL PINE HOMES			FIRST FLOOR HEATING LAYOUT			
Project Name			Date			
VALES OF HUMBER SOUTH BRAMPTON, ONTARIO			MAR/2022			
			Scale			
			3/16" = 1'-0"			
		BCIN# 19669				
6003		LO#				
5041 sqft		95293				

	S/A	R/A	FANS
2ND	21	6	6
1ST	17	4	3
BAS	8	1	0



I MICHAEL O'ROURKE HAVE REVIEWED AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.

Michael O'Rourke
Michael O'Rourke, BCIN# 19669
HVAC DESIGNS LTD.

CSA-F280-12

SB-12 PERFORMANCE

HVAC LEGEND								3.		
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	2.		
	SUPPLY AIR GRILLE		6" SUPPLY AIR BOOT ABOVE		14"x8" RETURN AIR GRILLE		RETURN AIR STACK ABOVE	1.	REVISED TO PERFORMANCE PATH	APR/2022
	SUPPLY AIR GRILLE 6" BOOT		SUPPLY AIR STACK FROM 2nd FLOOR		30"x8" RETURN AIR GRILLE		RETURN AIR STACK 2nd FLOOR	No.	Description	Date
	SUPPLY AIR BOOT ABOVE		6" SUPPLY AIR STACK 2nd FLOOR		FRA- FLOOR RETURN AIR GRILLE		REDUCER	REVISIONS		

ALL DRAWINGS, CALCULATIONS AND SPECIFICATIONS ARE THE PROPERTY OF HVAC DESIGNS LTD.© AND MAY NOT BE REPRODUCED, MODIFIED OR ALTERED WITHOUT EXPRESSED WRITTEN CONSENT. THE DRAWINGS ARE DATED AND USE OF THESE DRAWINGS AFTER ONE YEAR FROM THE DATED NOTED IS NOT AUTHORIZED. CONTRACTOR SHALL CHECK ALL CONDITIONS BEFORE PROCEEDING WITH WORK. LATEST MUNICIPAL APPROVED DRAWINGS ONLY TO BE USED DURING INSTALLATION OF HEATING SYSTEM. HVAC DESIGNS LTD. IS NOT LIABLE FOR ANY CLAIMS ARISING FROM UNAUTHORIZED USE OF THE DRAWINGS OR FROM ANY CHANGES TO ACCEPTED STANDARDS AND/OR THE ONTARIO BUILDING CODE.

Client		 375 Finley Ave. Suite 202 - Ajax, Ontario L1S 2E2 Tel. 905.619.2300 - 905.420.5300 Fax 905.619.2375 Email: info@hvacdesigns.ca Web: www.hvacdesigns.ca Specializing in Residential Mechanical Design Services Installation to comply with the latest Ontario Building Code. All supply branch outlets shall be equipped with a manual balancing damper. Ductwork which passes through the garage or unheated spaces shall be adequately insulated and be gas-proofed.	Sheet Title			
ROYAL PINE HOMES			SECOND FLOOR HEATING LAYOUT			
Project Name			Date MAR/2022			
VALES OF HUMBER SOUTH BRAMPTON, ONTARIO			Scale 3/16" = 1'-0"			
6003			BCIN# 19669			
5041 sqft			LO# 95293			

	S/A	R/A	FANS
2ND	21	6	6
1ST	17	4	3
BAS	8	1	0