

Schedule 1: Designer Information

Use one form for each individual who reviews and takes responsibility for design activities with respect to the project.

A. Project Information			
Building number, street name		Unit no.	Lot/con.
Municipality BRAMPTON	Postal code	Plan number/ other description	
B. Individual who reviews and takes responsibility for design activities			
Name MICHAEL O'ROURKE		Firm HVAC DESIGNS LTD.	
Street address 375 FINLEY AVE		Unit no. 202	Lot/con. N/A
Municipality AJAX	Postal code L1S 2E2	Province ONTARIO	E-mail info@hvacdesigns.ca
Telephone number (905) 619-2300	Fax number (905) 619-2375	Cell number ()	
C. Design activities undertaken by individual identified in Section B. [Building Code Table 3.5.2.1 OF Division C]			
☐ House ☐ Small Buildings ☐ Large Buildings ☐ Complex Buildings ☒ HVAC – House ☐ Building Services ☐ Detection, Lighting and Power ☐ Fire Protection ☐ Building Structural ☐ Plumbing – House ☐ Plumbing – All Buildings ☐ On-site Sewage Systems			
Description of designer's work HEAT LOSS / GAIN CALCULATIONS DUCT SIZING RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY RESIDENTIAL SYSTEM DESIGN per CSA-F280-12		Model: 7001 Project: VALES OF HUMBER SOUTH	
D. Declaration of Designer			
I, <u>MICHAEL O'ROURKE</u> declare that (choose one as appropriate): (print name)			
☐ I review and take responsibility for the design work on behalf of a firm registered under subsection 3.2.4. of Division C, of the Building Code. I am qualified, and the firm is registered, in the appropriate classes/categories. Individual BCIN: _____ Firm BCIN: _____			
☒ I review and take responsibility for the design and am qualified in the appropriate category as an "other designer" under subsection 3.2.5. of Division C, of the Building Code. Individual BCIN: <u>19669</u> Basis for exemption from registration and qualification: <u>O.B.C SENTENCE 3.2.4.1 (4)</u>			
☐ The design work is exempt from the registration and qualification requirements of the Building Code. Basis for exemption from registration and qualification: _____			
I certify that:			
1. The information contained in this schedule is true to the best of my knowledge. 2. I have submitted this application with the knowledge and consent of the firm.			
April 7, 2022		 Signature of Designer	
Date			

NOTE:

- For the purposes of this form, "individual" means the "person" referred to in Clause 3.2.4.7(1) d) of Division C, Article 3.2.5.1. of Division C, and all other persons who are exempt from qualification under Subsections 3.2.4. and 3.2.5. of Division C.
- Schedule 1 is not required to be completed by a holder of a license, temporary license, or a certificate of authorization, issued by the Ontario Association of Architects. Schedule 1 is also not required to be completed by a holder of a license to practise, a limited license to practise, or a certificate of authorization, issued by the Association of Professional Engineers of Ontario.

Application for a Permit Construct or Demolish – Effective January 1, 2015

SITE NAME: VALES OF HUMBER SOUTH										DATE Apr-22		WINTER NATURAL AIR CHANGE RATE 0.241										HEAT LOSS AT °F. 74		CSA-F280-12					
BUILDER: ROYAL PINE HOMES										TYPE: 7001		GFA: 5543		LO# 95295		SUMMER NATURAL AIR CHANGE RATE 0.078										HEAT GAIN AT °F. 11		SB-12 PERFORMANCE	
ROOM USE		GREAT		KIT		PANT		DIN		LIV		FOY		LIBR		PWD-1		PWD-2		MD/LN									
EXP. WALL		48		32		20		26		30		20		33		3		8		33									
CLG. HT.		21		11		11		11		11		23		11		11		11		12									
FACTORS																													
GRS.WALL AREA		LOSS GAIN		1008		352		220		286		330		460		363		33		88		396							
GLAZING				LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN		LOSS GAIN							
NORTH		20.8	15.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	25	519	387						
EAST		20.8	41.0	0	0	0	0	0	0	0	0	41	852	1683	56	1163	2299	41	852	1683	0	0	0	0	0	0			
SOUTH		20.8	24.4	0	0	0	0	0	0	0	39	810	951	0	0	0	0	0	0	0	0	0	0	0	0	0			
WEST		20.8	41.0	192	3989	7881	112	2327	4597	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
SKYLT.		34.1	100.3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0			
DOORS		24.7	3.7	0	0	0	15	370	55	0	0	0	0	0	0	45	1109	164	0	0	0	0	40	986	146				
NET EXPOSED WALL		3.5	0.5	816	2829	419	225	780	116	220	763	113	247	856	127	289	1002	149	359	1245	185	322	1116	166	33	114	17		
NET EXPOSED BSMT WALL ABOVE GR		3.5	0.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
EXPOSED CLG		1.3	0.6	503	630	280	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
NO ATTIC EXPOSED CLG		2.7	1.2	10	27	12	0	0	0	0	0	0	0	0	0	80	215	95	0	0	0	0	0	0	0	0	0		
EXPOSED FLOOR		2.5	0.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
BASEMENT/CRAWL HEAT LOSS				0		0		0		0		0		0		0		0		0		0		0		0			
SLAB ON GRADE HEAT LOSS				0		0		0		0		0		0		0		0		0		0		0		0			
SUBTOTAL HT LOSS				7475		3477		763		1667		1854		3732		1968		114		305		2653							
SUB TOTAL HT GAIN				8593		4768		113		1078		1832		2743		1848		17		45		703							
LEVEL FACTOR / MULTIPLIER		0.30	0.37			0.30	0.37			0.30	0.37			0.30	0.37			0.30	0.37			0.30	0.37						
AIR CHANGE HEAT LOSS				2737		1273		279		610		679		1366		721		42		112		971							
AIR CHANGE HEAT GAIN				423		235		6		53		90		135		91		1		2		35							
DUCT LOSS				0		0		0		0		0		0		0		0		0		0							
DUCT GAIN				0		0		0		0		0		0		0		0		0		0							
HEAT GAIN PEOPLE		240	0	0		0		0		0		0		0		0		0		0		0							
HEAT GAIN APPLIANCES/LIGHTS				1367		1367		0		1367		1367		0		1367		0		0		1367							
TOTAL HT LOSS BTU/H				10212		4750		1042		2277		2533		5099		2689		156		417		3624							
TOTAL HT GAIN x 1.3 BTU/H				13498		8281		154		3248		4276		3742		4299		23		62		2736							

ROOM USE																					BAS
EXP. WALL																					250
CLG. HT.																					10
FACTORS																					
GRS.WALL AREA	LOSS GAIN																				1750
GLAZING																					LOSS GAIN
NORTH	20.8 15.5																				0 0 0
EAST	20.8 41.0																				0 0 0
SOUTH	20.8 24.4																				12 249 293
WEST	20.8 41.0																				12 249 493
SKYLT.	34.1 100.3																				0 0 0
DOORS	24.7 3.7																				20 493 73
NET EXPOSED WALL	3.5 0.5																				0 0 0
NET EXPOSED BSMT WALL ABOVE GR	3.5 0.5																				750 2635 391
EXPOSED CLG	1.3 0.6																				0 0 0
NO ATTIC EXPOSED CLG	2.7 1.2																				0 0 0
EXPOSED FLOOR	2.5 0.4																				0 0 0
BASEMENT/CRAWL HEAT LOSS																					8939
SLAB ON GRADE HEAT LOSS																					
SUBTOTAL HT LOSS																					12566
SUB TOTAL HT GAIN																					1249
LEVEL FACTOR / MULTIPLIER	0.50 1.17																				
AIR CHANGE HEAT LOSS																					14650
AIR CHANGE HEAT GAIN																					61
DUCT LOSS																					0
DUCT GAIN																					0
HEAT GAIN PEOPLE	240																				0
HEAT GAIN APPLIANCES/LIGHTS																					0
TOTAL HT LOSS BTU/H																					27216
TOTAL HT GAIN x 1.3 BTU/H																					1704

TOTAL HEAT GAIN BTU/H: 76691 TONS: 6.39 LOSS DUE TO VENTILATION LOAD BTU/H: 6010 STRUCTURAL HEAT LOSS: 85143 TOTAL COMBINED HEAT LOSS BTU/H: 91154

SITE NAME: VALES OF HUMBER SOUTH

BUILDER: ROYAL PINE HOMES

TYPE: 7001

GFA: 5543

DATE Apr-22

LO# 95295

WINTER NATURAL AIR CHANGE RATE 0.241

SUMMER NATURAL AIR CHANGE RATE 0.078

HEAT LOSS AT °F. 74

HEAT GAIN AT °F. 11

CSA-F280-12

SB-12 PERFORMANCE

ROOM USE	EXP. WALL	CLG. HT.	PRI	ENS	DRESS	BED-2	BED-3	BED-4	BED-5	RETR	ENS-2	ENS-3		
			25	27	11	13	35	24	30	10	6	8		
			10	10	10	10	11	10	10	10	10	10		
FACTORS														
GRS.WALL AREA	LOSS	GAIN	250	270	110	130	385	240	300	100	60	80		
GLAZING	LOSS	GAIN												
NORTH	20.8	15.5	0	0	0	0	0	0	0	0	9	187	139	0
EAST	20.8	41.0	0	0	0	0	0	0	83	1724	3407	40	831	1642
SOUTH	20.8	24.4	0	0	0	32	665	781	8	166	195	0	0	0
WEST	20.8	41.0	54	1122	2217	23	478	944	0	0	0	0	0	0
SKYLT.	34.1	100.3	0	0	0	0	0	0	0	0	0	0	0	0
DOORS	24.7	3.7	0	0	0	0	0	0	0	0	0	0	0	0
NET EXPOSED WALL	3.5	0.5	196	680	101	215	745	111	102	354	52	103	357	53
NET EXPOSED BSMT WALL ABOVE GR	3.5	0.5	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED CLG	1.3	0.6	546	684	304	180	226	100	165	207	92	325	407	181
NO ATTIC EXPOSED CLG	2.7	1.2	0	0	0	0	0	0	0	0	0	0	0	0
EXPOSED FLOOR	2.5	0.4	0	0	0	0	0	0	20	50	7	418	1041	154
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0	0	0	0	0	0	0
SUBTOTAL HT LOSS			2486		2114	727		1375	4408		2093	2003	1047	611
SUB TOTAL HT GAIN				2622	1936	340	659	3981	1975	1896	654	227		102
LEVEL FACTOR / MULTIPLIER	0.20	0.32			0.20	0.32	0.20	0.32	0.20	0.32	0.20	0.32	0.20	0.32
AIR CHANGE HEAT LOSS			807		686	236		446	1431		679	650	340	198
AIR CHANGE HEAT GAIN				129	95	17		32	196		97	93	32	11
DUCT LOSS			0		0			182	584		277	0		81
DUCT GAIN				0	0			0	230		578	368	0	24
HEAT GAIN PEOPLE	240	2	480	0	0	0	1	240	1	240	0	0	0	0
HEAT GAIN APPLIANCES/LIGHTS			1367		0			1367	1367		1367	1367		0
TOTAL HT LOSS BTU/H			3293		2800	962		2004	6422		3050	2653	1387	890
TOTAL HT GAIN x 1.3 BTU/H			5977		2640	463		3287	8272		5262	4675	2669	340

ROOM USE	EXP. WALL	CLG. HT.	ENS-4	SHARED										
			0	6										
			10	10										
FACTORS														
GRS.WALL AREA	LOSS	GAIN	0	60										
GLAZING	LOSS	GAIN												
NORTH	20.8	15.5	0	0	0	0	0	0						
EAST	20.8	41.0	0	0	0	0	0	0						
SOUTH	20.8	24.4	0	0	0	9	187	220						
WEST	20.8	41.0	0	0	0	0	0	0						
SKYLT.	34.1	100.3	0	0	0	0	0	0						
DOORS	24.7	3.7	0	0	0	0	0	0						
NET EXPOSED WALL	3.5	0.5	0	0	0	51	177	26						
NET EXPOSED BSMT WALL ABOVE GR	3.5	0.5	0	0	0	0	0	0						
EXPOSED CLG	1.3	0.6	70	88	39	90	113	50						
NO ATTIC EXPOSED CLG	2.7	1.2	0	0	0	0	0	0						
EXPOSED FLOOR	2.5	0.4	40	100	15	0	0	0						
BASEMENT/CRAWL HEAT LOSS			0	0	0	0	0	0						
SLAB ON GRADE HEAT LOSS			0	0	0	0	0	0						
SUBTOTAL HT LOSS			187		477									
SUB TOTAL HT GAIN				54	296									
LEVEL FACTOR / MULTIPLIER	0.20	0.32			0.20	0.32								
AIR CHANGE HEAT LOSS			61		155									
AIR CHANGE HEAT GAIN				3	15									
DUCT LOSS			25		0									
DUCT GAIN				6	0									
HEAT GAIN PEOPLE	240	0	0	0	0									
HEAT GAIN APPLIANCES/LIGHTS			0		0									
TOTAL HT LOSS BTU/H			273		631									
TOTAL HT GAIN x 1.3 BTU/H			81		404									

TOTAL HEAT GAIN BTU/H:

76691

TONS: 6.39

LOSS DUE TO VENTILATION LOAD BTU/H: 6010

STRUCTURAL HEAT LOSS: 85143

TOTAL COMBINED HEAT LOSS BTU/H: 91154

SITE NAME: VALES OF HUMBER SOUTH
BUILDER: ROYAL PINE HOMES

TYPE: 7001

DATE: Apr-22

GFA: 5543

LO# 95295

FURNACE 1

HEATING CFM 1370 COOLING CFM 1370
TOTAL HEAT LOSS 60,015 TOTAL HEAT GAIN 42,022
AIR FLOW RATE CFM 22.83 AIR FLOW RATE CFM 32.6

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 63020 BTUH

#CARRIER

59SP5A-80-16

80

AFUE = 97 %

INPUT (BTU/H) = 80,000

OUTPUT (BTU/H) = 78,000

DESIGN CFM = 1370

CFM @ .6" E.S.P.

TEMPERATURE RISE 53 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	0	20	8
R/A	0	0	0	5	1

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
ROOM NAME	GREAT	GREAT	GREAT	GREAT	GREAT	KIT	KIT	KIT	PANT	DIN	DIN	LIV	LIV	FOY	FOY	LIBR	LIBR	PWD-1	PWD-2	MD/LN	BAS	BAS	BAS	BAS
RM LOSS MBH.	2.04	2.04	2.04	2.04	2.04	1.58	1.58	1.58	1.04	1.14	1.14	1.27	1.27	2.55	2.55	1.34	1.34	0.16	0.42	3.62	3.40	3.40	3.40	3.40
CFM PER RUN HEAT	47	47	47	47	47	36	36	36	24	26	26	29	29	58	58	31	31	4	10	83	78	78	78	78
RM GAIN MBH.	2.70	2.70	2.70	2.70	2.70	2.76	2.76	2.76	0.15	1.62	1.62	2.14	2.14	1.87	1.87	2.15	2.15	0.02	0.06	2.74	0.21	0.21	0.21	0.21
CFM PER RUN COOLING	88	88	88	88	88	90	90	90	5	53	53	70	70	61	61	70	70	1	2	89	7	7	7	7
ADJUSTED PRESSURE	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	31	25	21	23	28	35	47	53	55	50	62	78	74	78	82	81	87	31	11	18	53	38	21	25
EQUIVALENT LENGTH	100	100	120	140	120	110	90	110	100	120	110	100	120	150	130	120	130	120	170	140	110	100	130	130
TOTAL EFFECTIVE LENGTH	131	125	141	163	148	145	137	163	155	170	172	178	194	228	212	201	217	151	181	158	163	138	151	155
ADJUSTED PRESSURE	0.12	0.13	0.11	0.1	0.11	0.11	0.12	0.1	0.11	0.1	0.1	0.1	0.09	0.08	0.08	0.09	0.08	0.11	0.1	0.1	0.11	0.12	0.11	0.11
ROUND DUCT SIZE	6	6	6	6	6	6	6	6	4	5	5	5	5	5	5	5	5	4	4	6	5	5	5	5
HEATING VELOCITY (ft/min)	240	240	240	240	240	184	184	184	275	191	191	213	213	426	426	228	228	46	115	423	573	573	573	573
COOLING VELOCITY (ft/min)	449	449	449	449	449	459	459	459	57	389	389	514	514	448	448	514	514	11	23	454	51	51	51	51
OUTLET GRILL SIZE	4X10	4X10	4X10	4X10	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	3X10	3X10	3X10	3X10
TRUNK	F	F	F	E	E	E	E	D	D	C	C	A	A	A	B	B	B	E	E	F	D	E	E	F

RUN #	25	26	27	28
ROOM NAME	BAS	BAS	BAS	BAS
RM LOSS MBH.	3.40	3.40	3.40	3.40
CFM PER RUN HEAT	78	78	78	78
RM GAIN MBH.	0.21	0.21	0.21	0.21
CFM PER RUN COOLING	7	7	7	7
ADJUSTED PRESSURE	0.17	0.17	0.17	0.17
ACTUAL DUCT LGH.	52	58	71	78
EQUIVALENT LENGTH	110	110	110	100
TOTAL EFFECTIVE LENGTH	162	168	181	178
ADJUSTED PRESSURE	0.11	0.1	0.1	0.1
ROUND DUCT SIZE	5	5	5	5
HEATING VELOCITY (ft/min)	573	573	573	573
COOLING VELOCITY (ft/min)	51	51	51	51
OUTLET GRILL SIZE	3X10	3X10	3X10	3X10
TRUNK	C	C	A	B

SUPPLY AIR TRUNK SIZE										RETURN AIR TRUNK SIZE									
TRUNK	STATIC	ROUND	RECT	VELOCITY						TRUNK	STATIC	ROUND	RECT	VELOCITY					
CFM	PRESS.	DUCT	DUCT	(ft/min)						CFM	PRESS.	DUCT	DUCT	(ft/min)					
TRUNK A	194	0.08	7.6	8	x	8	437			TRUNK G	0	0.00	0	0	x	8	0		
TRUNK B	198	0.08	7.6	8	x	8	446			TRUNK H	0	0.00	0	0	x	8	0		
TRUNK C	600	0.08	11.6	16	x	8	675			TRUNK I	0	0.00	0	0	x	8	0		
TRUNK D	138	0.10	6.3	8	x	8	311			TRUNK J	0	0.00	0	0	x	8	0		
TRUNK E	1074	0.08	14.4	24	x	8	806			TRUNK K	0	0.00	0	0	x	8	0		
TRUNK F	302	0.10	8.5	10	x	8	544			TRUNK L	0	0.00	0	0	x	8	0		

RETURN AIR #	1	2	3	4	5	BR									
AIR VOLUME	330	155	360	130	130	0	0	0	0	0	0	0	0	0	265
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
ACTUAL DUCT LGH.	15	55	55	63	60	1	1	1	1	1	1	1	1	1	16
EQUIVALENT LENGTH	145	205	200	205	165	0	0	0	0	0	0	0	0	0	185
TOTAL EFFECTIVE LH	160	260	255	268	225	1	1	1	1	1	1	1	1	1	201
ADJUSTED PRESSURE	0.09	0.06	0.06	0.06	0.07	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	0.07
ROUND DUCT SIZE	9	7.5	10.3	7	6.8	0	0	0	0	0	0	0	0	0	8.8
INLET GRILL SIZE	8	8	8	8	8	0	0	0	0	0	0	0	0	0	8
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X
INLET GRILL SIZE	30	14	30	14	14	0	0	0	0	0	0	0	0	0	30

SITE NAME: VALES OF HUMBER SOUTH
BUILDER: ROYAL PINE HOMES

TYPE: 7001

DATE: Apr-22

GFA: 5543

LO# 95295

FURNACE 2

HEATING CFM 1040 COOLING CFM 1040
TOTAL HEAT LOSS 25,129 TOTAL HEAT GAIN 34,224
AIR FLOW RATE CFM 41.39 AIR FLOW RATE CFM 30.39

furnace pressure 0.6
furnace filter 0.05
a/c coil pressure 0.2
available pressure
for s/a & r/a 0.35

**FURNACE HEAT LOSS +
HRV / ERV HEAT LOSS
= 28134 BTUH**
#*CARRIER
59SP5A-40-12 40
FAN SPEED
LOW 0
MEDLOW 0
MEDIUM 0
MEDIUM HIGH 770
HIGH 1040

AFUE = 97 %
INPUT (BTU/H) = 40,000
OUTPUT (BTU/H) = **39,000**

DESIGN CFM = **1040**
CFM @ .6" E.S.P.

TEMPERATURE RISE 35 °F

RUN COUNT	4th	3rd	2nd	1st	Bas
S/A	0	0	21	0	0
R/A	0	0	7	0	0

All S/A diffusers 4"x10" unless noted otherwise on layout.

All S/A runs 5"Ø unless noted otherwise on layout.

RUN #	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
ROOM NAME	PRI	PRI	PRI	ENS	ENS	DRESS	BED-2	BED-2	ENS-2	BED-3	BED-3	BED-3	BED-3	ENS-3	BED-4	BED-4	ENS-4	BED-5	BED-5	SHARED	RETR
RM LOSS MBH.	1.10	1.10	1.10	2.10	0.70	0.96	1.00	1.00	0.89	1.61	1.61	1.61	1.61	0.76	1.52	1.52	0.27	1.33	1.33	0.63	1.39
CFM PER RUN HEAT	45	45	45	87	29	40	41	41	37	66	66	66	66	32	63	63	11	55	55	26	57
RM GAIN MBH.	1.99	1.99	1.99	1.98	0.66	0.46	1.64	1.64	0.34	2.07	2.07	2.07	2.07	0.15	2.63	2.63	0.08	2.34	2.34	0.40	2.67
CFM PER RUN COOLING	61	61	61	60	20	14	50	50	10	63	63	63	63	5	80	80	2	71	71	12	81
ADJUSTED PRESSURE	0.17	0.17	0.17	0.16	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.17	0.16
ACTUAL DUCT LGH.	84	69	63	90	85	85	43	38	33	41	37	42	49	39	64	58	39	94	88	80	92
EQUIVALENT LENGTH	190	200	210	160	170	200	180	180	110	110	120	130	130	120	190	220	110	170	170	170	190
TOTAL EFFECTIVE LENGTH	274	269	273	250	255	285	223	218	143	151	157	172	179	159	254	278	149	264	258	250	282
ADJUSTED PRESSURE	0.06	0.06	0.06	0.06	0.07	0.06	0.08	0.08	0.12	0.11	0.11	0.1	0.1	0.11	0.07	0.06	0.12	0.07	0.07	0.07	0.06
ROUND DUCT SIZE	6	6	6	6	4	5	5	5	4	5	5	5	5	4	6	6	4	6	6	4	6
HEATING VELOCITY (ft/min)	229	229	229	444	333	294	301	301	424	485	485	485	485	367	321	321	126	280	280	298	291
COOLING VELOCITY (ft/min)	311	311	311	306	229	103	367	367	115	463	463	463	463	57	408	408	23	362	362	138	413
OUTLET GRILL SIZE	4X10	4X10	4X10	4X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	3X10	4X10	4X10	3X10	4X10	4X10	3X10	4X10
TRUNK	A	A	A	A	A	A	B	B	B	D	D	B	B	B	C	C	D	C	C	C	C

RUN #	
ROOM NAME	
RM LOSS MBH.	
CFM PER RUN HEAT	
RM GAIN MBH.	
CFM PER RUN COOLING	
ADJUSTED PRESSURE	
ACTUAL DUCT LGH.	
EQUIVALENT LENGTH	
TOTAL EFFECTIVE LENGTH	
ADJUSTED PRESSURE	
ROUND DUCT SIZE	
HEATING VELOCITY (ft/min)	
COOLING VELOCITY (ft/min)	
OUTLET GRILL SIZE	
TRUNK	

SUPPLY AIR TRUNK SIZE														RETURN AIR TRUNK SIZE													
	TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT			VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)		TRUNK CFM	STATIC PRESS.	ROUND DUCT	RECT DUCT		VELOCITY (ft/min)						
TRUNK A	291	0.06	9.5	10	x	8	524	TRUNK G	0	0.00	0	0	x	8	0	TRUNK O	0	0.05	0	0	x	8	0				
TRUNK B	574	0.06	12.2	18	x	8	574	TRUNK H	0	0.00	0	0	x	8	0	TRUNK P	0	0.05	0	0	x	8	0				
TRUNK C	319	0.06	9.8	14	x	8	410	TRUNK I	0	0.00	0	0	x	8	0	TRUNK Q	0	0.05	0	0	x	8	0				
TRUNK D	462	0.06	11.3	18	x	8	462	TRUNK J	0	0.00	0	0	x	8	0	TRUNK R	0	0.05	0	0	x	8	0				
TRUNK E	0	0.00	0	0	x	8	0	TRUNK K	0	0.00	0	0	x	8	0	TRUNK S	0	0.05	0	0	x	8	0				
TRUNK F	0	0.00	0	0	x	8	0	TRUNK L	0	0.00	0	0	x	8	0	TRUNK T	0	0.05	0	0	x	8	0				

RETURN AIR #	1	2	3	4	5	6	7															BR
AIR VOLUME	280	95	230	115	115	75	130	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
PLENUM PRESSURE	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	
ACTUAL DUCT LGH.	46	42	54	66	89	60	53	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
EQUIVALENT LENGTH	175	165	245	205	210	215	205	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
TOTAL EFFECTIVE LH	221	207	299	271	299	275	258	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
ADJUSTED PRESSURE	0.07	0.07	0.05	0.05	0.05	0.05	0.06	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	14.80	
ROUND DUCT SIZE	9	6	9.1	7	7	6	7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
INLET GRILL SIZE	8	8	8	8	8	8	8	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	
INLET GRILL SIZE	30	14	30	14	14	14	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	

TYPE: 7001
SITE NAME: VALES OF HUMBER SOUTH

LO # 95295

RESIDENTIAL MECHANICAL VENTILATION DESIGN SUMMARY

COMBUSTION APPLIANCES		9.32.3.1(1)
a)	☒ Direct vent (sealed combustion) only	
b)	☐ Positive venting induced draft (except fireplaces)	
c)	☐ Natural draft, B-vent or induced draft gas fireplace	
d)	☐ Solid Fuel (including fireplaces)	
e)	☐ No Combustion Appliances	

HEATING SYSTEM	
☒ Forced Air	☐ Non Forced Air
☐ Electric Space Heat	

HOUSE TYPE		9.32.1(2)
☒ I	Type a) or b) appliance only, no solid fuel	
☐ II	Type I except with solid fuel (including fireplaces)	
☐ III	Any Type c) appliance	
☐ IV	Type I, or II with electric space heat	
☐ Other:	Type I, II or IV no forced air	

SYSTEM DESIGN OPTIONS		O.N.H.W.P.
☐ 1	Exhaust only/Forced Air System	
☐ 2	HRV with Ducting/Forced Air System	
☒ 3	HRV Simplified/connected to forced air system	
☐ 4	HRV with Ducting/non forced air system	
☐	Part 6 Design	

TOTAL VENTILATION CAPACITY		9.32.3.3(1)
Basement + Master Bedroom	<u>2</u> @ 21.2 cfm	<u>42.4</u> cfm
Other Bedrooms	<u>4</u> @ 10.6 cfm	<u>42.4</u> cfm
Kitchen & Bathrooms	<u>8</u> @ 10.6 cfm	<u>84.8</u> cfm
Other Rooms	<u>7</u> @ 10.6 cfm	<u>74.2</u> cfm
Table 9.32.3.A.	TOTAL	<u>243.8</u> cfm

PRINCIPAL VENTILATION CAPACITY REQUIRED		9.32.3.4.(1)
1 Bedroom	31.8	cfm
2 Bedroom	47.7	cfm
3 Bedroom	63.6	cfm
4 Bedroom	79.5	cfm
5 Bedroom	95.4	cfm
TOTAL		<u>95.4</u> cfm

SUPPLEMENTAL VENTILATION CAPACITY		9.32.3.5.
Total Ventilation Capacity	<u>243.8</u>	cfm
Less Principal Ventil. Capacity	<u>150</u>	cfm
Required Supplemental Capacity	<u>93.8</u>	cfm

PRINCIPAL EXHAUST FAN CAPACITY	
Model:	VANEE V150H
Location:	BSMT
<u>150.0</u> cfm	☒ HVI Approved

PRINCIPAL EXHAUST HEAT LOSS CALCULATION				
CFM	ΔT °F	FACTOR	% LOSS	
150.0 CFM	X 74 F	X 1.08	X	0.25

SUPPLEMENTAL FANS		BY INSTALLING CONTRACTOR		
Location	Model	cfm	HVI	Sones
ENS	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-2	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-3	BY INSTALLING CONTRACTOR	50	☒	3.5
ENS-4	BY INSTALLING CONTRACTOR	50	☒	3.5

HEAT RECOVERY VENTILATOR		9.32.3.11.
Model:	VANEE V150H	INSTALL 2 HRV / ERV's
<u>150</u>	cfm high	<u>35</u> cfm low
<u>75</u>	% Sensible Efficiency @ 32 deg F (0 deg C)	☒ HVI Approved

LOCATION OF INSTALLATION	
Lot:	Concession
Township	Plan:
Address	
Roll #	Building Permit #

BUILDER:	
ROYAL PINE HOMES	
Name:	
Address:	
City:	
Telephone #:	Fax #:

INSTALLING CONTRACTOR	
Name:	
Address:	
City:	
Telephone #:	Fax #:

DESIGNER CERTIFICATION	
I hereby certify that this ventilation system has been designed in accordance with the Ontario Building Code.	
Name:	HVAC Designs Ltd.
Signature:	<i>Michael O'Rourke</i>
HRAI #	001820
Date:	April-22

I REVIEW AND TAKE RESPONSIBILITY FOR THE DESIGN WORK AND AM QUALIFIED IN THE APPROPRIATE CATEGORY AS AN "OTHER DESIGNER" UNDER DIVISION C, 3.2.5 OF THE BUILDING CODE.
INDIVIDUAL BCIN: 19669 *Michael O'Rourke* MICHAEL O'ROURKE

CSA F280-12 Residential Heat Loss and Heat Gain Calculations																																																													
Formula Sheet (For Air Leakage / Ventilation Calculation)																																																													
LO#: 95295		Model: 7001		Builder: ROYAL PINE HOMES																																																									
				Date: 2022-04-07																																																									
Volume Calculation			Air Change & Delta T Data																																																										
House Volume <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Level</th> <th>Floor Area (ft²)</th> <th>Floor Height (ft)</th> <th>Volume (ft³)</th> </tr> </thead> <tbody> <tr> <td>Bsmt</td> <td>2786</td> <td>10</td> <td>27860</td> </tr> <tr> <td>First</td> <td>2786</td> <td>11</td> <td>30646</td> </tr> <tr> <td>Second</td> <td>3296</td> <td>10</td> <td>32960</td> </tr> <tr> <td>Third</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td>Fourth</td> <td>0</td> <td>9</td> <td>0</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>91,466.0 ft³</td> </tr> <tr> <td colspan="2" style="text-align: right;">Total:</td> <td></td> <td>2590.0 m³</td> </tr> </tbody> </table>			Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)	Bsmt	2786	10	27860	First	2786	11	30646	Second	3296	10	32960	Third	0	9	0	Fourth	0	9	0	Total:			91,466.0 ft³	Total:			2590.0 m³	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 70%;">WINTER NATURAL AIR CHANGE RATE</td> <td style="width: 30%;">0.241</td> </tr> <tr> <td>SUMMER NATURAL AIR CHANGE RATE</td> <td>0.078</td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5" style="text-align: center;">Design Temperature Difference</th> </tr> <tr> <th></th> <th>Tin °C</th> <th>Tout °C</th> <th>ΔT °C</th> <th>ΔT °F</th> </tr> <tr> <td>Winter DTDh</td> <td>22</td> <td>-19</td> <td>41</td> <td>74</td> </tr> <tr> <td>Summer DTDc</td> <td>24</td> <td>30</td> <td>6</td> <td>11</td> </tr> </table>			WINTER NATURAL AIR CHANGE RATE	0.241	SUMMER NATURAL AIR CHANGE RATE	0.078	Design Temperature Difference						Tin °C	Tout °C	ΔT °C	ΔT °F	Winter DTDh	22	-19	41	74	Summer DTDc	24	30	6	11
Level	Floor Area (ft²)	Floor Height (ft)	Volume (ft³)																																																										
Bsmt	2786	10	27860																																																										
First	2786	11	30646																																																										
Second	3296	10	32960																																																										
Third	0	9	0																																																										
Fourth	0	9	0																																																										
Total:			91,466.0 ft³																																																										
Total:			2590.0 m³																																																										
WINTER NATURAL AIR CHANGE RATE	0.241																																																												
SUMMER NATURAL AIR CHANGE RATE	0.078																																																												
Design Temperature Difference																																																													
	Tin °C	Tout °C	ΔT °C	ΔT °F																																																									
Winter DTDh	22	-19	41	74																																																									
Summer DTDc	24	30	6	11																																																									
5.2.3.1 Heat Loss due to Air Leakage			6.2.6 Sensible Gain due to Air Leakage																																																										
$HL_{airb} = LR_{airh} \times \frac{V_b}{3.6} \times DTD_h \times 1.2$ 0.241 x 719.45 x 41 °C x 1.2 = 8587 W = 29300 Btu/h			$HG_{salb} = LR_{airc} \times \frac{V_b}{3.6} \times DTD_c \times 1.2$ = 0.078 x 719.45 x 6 °C x 1.2 = 414 W = 1412 Btu/h																																																										
5.2.3.2 Heat Loss due to Mechanical Ventilation			6.2.7 Sensible heat Gain due to Ventilation																																																										
$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E) \times 2 \text{ HRV / ERV's}$ 300 CFM x 74 °F x 1.08 x 0.25 = 6010 Btu/h			$HL_{vairb} = PVC \times DTD_h \times 1.08 \times (1 - E)$ 300 CFM x 11 °F x 1.08 x 0.25 = 891 Btu/h																																																										
5.2.3.3 Calculation of Air Change Heat Loss for Each Room (Floor Multiplier Section)																																																													
$HL_{airr} = Level \ Factor \times HL_{airbv} \times \{(HL_{agcr} + HL_{bgcr}) \div (HL_{agclevel} + HL_{bgclevel})\}$																																																													
Level	Level Factor (LF)	HLairve Air Leakage + Ventilation Heat Loss (Btu/h)	Level Conductive Heat Loss: (HL _{clevel})	Air Leakage Heat Loss Multiplier (LF x HLairbv / HL _{clevel})																																																									
1	0.5	29,300	12,566	1.166																																																									
2	0.3		24,009	0.366																																																									
3	0.2		18,050	0.325																																																									
4	0		0	0.000																																																									
5	0		0	0.000																																																									
*HLairbv = Air leakage heat loss + ventilation heat loss *For a balanced or supply only ventilation system HLairve = 0																																																													
				Michael O'Rourke BCIN# 19669 																																																									

HEAT LOSS AND GAIN SUMMARY SHEET**MODEL:** 7001**BUILDER:** ROYAL PINE HOMES**SFQT:** 5543**LO#** 95295**SITE:** VALES OF HUMBER SOUTH**DESIGN ASSUMPTIONS**

HEATING	°F	COOLING	°F
OUTDOOR DESIGN TEMP.	-2	OUTDOOR DESIGN TEMP.	86
INDOOR DESIGN TEMP.	72	INDOOR DESIGN TEMP. (MAX 75°F)	75
		WINDOW SHGC	0.60

BUILDING DATA

ATTACHMENT:	DETACHED	# OF STORIES (+BASEMENT):	3
FRONT FACES:	EAST	ASSUMED (Y/N):	Y
AIR CHANGES PER HOUR:	2.50	ASSUMED (Y/N):	Y
AIR TIGHTNESS CATEGORY:	TIGHT	ASSUMED (Y/N):	Y
WIND EXPOSURE:	SHELTERED	ASSUMED (Y/N):	Y
HOUSE VOLUME (ft ³):	91466.0	ASSUMED (Y/N):	Y
INTERNAL SHADING:	BLINDS/CURTAINS	ASSUMED OCCUPANTS:	6
INTERIOR LIGHTING LOAD (Btu/h/ft ²):	1.85	DC BRUSHLESS MOTOR (Y/N):	Y
FOUNDATION CONFIGURATION	BCIN_1	DEPTH BELOW GRADE:	7.0 ft
LENGTH: 63.0 ft	WIDTH: 62.0 ft	EXPOSED PERIMETER:	250.0 ft

2012 OBC - COMPLIANCE PACKAGE**Component****Compliance Package
SB-12 PERFORMANCE****Nominal Min. Eff.**

Ceiling with Attic Space Minimum RSI (R)-Value	60	59.22
Ceiling Without Attic Space Minimum RSI (R)-Value	31	27.65
Exposed Floor Minimum RSI (R)-Value	31	29.80
Walls Above Grade Minimum RSI (R)-Value	22+1.5	21.40
Basement Walls Minimum RSI (R)-Value	20	21.12
Below Grade Slab Entire surface > 600 mm below grade Minimum RSI (R)-Value	-	-
Edge of Below Grade Slab ≤ 600 mm Below Grade Minimum RSI (R)-Value	10	10
Heated Slab or Slab ≤ 600 mm below grade Minimum RSI (R)-Value	10	11.13
Windows and Sliding Glass Doors Maximum U-Value	1.6	-
Skylights Maximum U-Value	2.6	-
Space Heating Equipment Minimum AFUE	0.96	-
HRV Minimum Efficiency	75%	-
Domestic Hot Water Heater Minimum EF	0.9	-


INDIVIDUAL BCIN: 19669

MICHAEL O'ROURKE



Residential Foundation Thermal Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description		
Province:	Ontario	
Region:	Brampton	
Site Description		
Soil Conductivity:	Normal conductivity: dry sand, loam, clay	
Water Table:	Normal (7-10 m, 23-33 ft)	
Foundation Dimensions		
Floor Length (m):	19.2	
Floor Width (m):	18.9	
Exposed Perimeter (m):	0.0	
Wall Height (m):	3.0	
Depth Below Grade (m):	2.13	
Window Area (m ²):	2.2	
Door Area (m ²):	1.9	
Radiant Slab		
Heated Fraction of the Slab:	0	
Fluid Temperature (°C):	33	
Design Months		
Heating Month	1	
Foundation Loads		
Heating Load (Watts):		2619

TYPE: 7001
LO# 95295

Air Infiltration Residential Load Calculator

Supplemental tool for CAN/CSA-F280

Weather Station Description				
Province:	Ontario			
Region:	Brampton			
Weather Station Location:	Open flat terrain, grass			
Anemometer height (m):	10			
Local Shielding				
Building Site:	Suburban, forest			
Walls:	Heavy			
Flue:	Heavy			
Highest Ceiling Height (m):	7.32			
Building Configuration				
Type:	Detached			
Number of Stories:	Two			
Foundation:	Full			
House Volume (m ³):	2590.0			
Air Leakage/Ventilation				
Air Tightness Type:	Energy Star Detached (2.5 ACH)			
Custom BDT Data:	ELA @ 10 Pa.	2417.8 cm ²		
	2.50	ACH @ 50 Pa		
Mechanical Ventilation (L/s):	Total Supply	Total Exhaust		
	70.8	70.8		
Flue Size				
Flue #:	#1	#2	#3	#4
Diameter (mm):	0	0	0	0
Natural Infiltration Rates				
Heating Air Leakage Rate (ACH/H):	0.241			
Cooling Air Leakage Rate (ACH/H):	0.078			

TYPE: 7001
LO# 95295