



Service Completion Status Report

Zancor

Date : Aug 19, 2021

Fax :

Phone :

ZAN08 – ZANCOR HOMES (COOKSTOWN) LTD.

Report To: Site

Lot Number	Work Description	Status Status Date	Builder Ref #
22	2 BRICKS NEED TO BE REPLACED CLOSE TO FIREPLACE VENT, DAMAGED BY THE LANDSCAPERS NOTE: 2 BRICKS REPLACED	Completed 08/19/2021	144268 S-061252
15	AS PER INSPECTION -- PORTICO, RIGHT SIDE --- STONE LOOSE AND MOTAR CRACKED NOTE: STONE AND MULTIPLE JOINTS REPOINTED	Completed 08/19/2021	142803 S-061252