

Adam Cramm

TRUDEL & SONS ROOFING LTD.

5 Paisley Lane
Stouffville, ONT L4A7X4

Service Work Order

Number: 35640
Entered: 8/11/2021

Duplicate

Service

Location:

Zancor Homes- TRILLIUM FOREST PH 3
BLK 143 UNIT 6
49 BIANCA CRES
WASAGA BE/ONT

Contacts:

Phone:
Mobile:

Bill To:

Zancor Homes
221 North Rivermede Rd.
Concord, ONT L4K 3N7

PO Number:

Payment Method: Bill Out
Customer Code: ZANC

Call Type:

Repair

Est. Hours/Priority:

1.00

Problem:

Builder Work Order See Attached

Permission Code:

Homeowner

Scheduled:

8/11/2021

Scheduled Time:

8:00 am

Technician:

Adam Cramm

Job Priority:

High

Fax Back No:

Service Dept Comments:

GARAGE LOWER ROOF LEAK- DRYWALL DAMAGED AT CEILING ABOVE RIGHT GARAGE DOOR-
ZANCOR SERVICE DID WATER TEST- LOOKS AS THOUGH THIS IS AT FRONT LEFTCORNER OF
THE GABLE- PLYWOOD VISIBLE, NO FLASHING SEEN. SHINGLE/BROKEN TAB AT REAR WHEN
STANDING IN REAR LEFT

Parts:

(To Be Filled In By Technician)

Labour:

(To Be Filled In By Technician)

Comments & Notes: (Technician)

To Do Items:

Work Order Notes:

INSTALLED MISSING METAL IN FRONT. REPLACED WIND DAMAGED SHINGLES ON BACK OF HOUSE. PLEASE
ISSUE A PURCHASE ORDER FOR \$160.00 + HST FOR THE SHINGLE REPAIRS.

COMPLETED AUG. 25/21
BLK 143 UNIT 6 - TRILLILUM FOREST PH3