



Zancor North Inc.
Warranty Services
Phone: (905) 738-7010
Fax: (905) 738-5948

Work Order

Closing Date: 30Jul21

Address: 17 Bianca Crescent
Wasaga Beach

Location: The Village of Trillium Forest - Phase: 3 - Lot: Block 140 Unit 5

Today's Date: 20Sep21

Contact(s): Henning, A Hoffschmidt - Home: (647) 274-1771

Lysiane Hoffschmidt -

Email: lysiane.hoffschmidt@rogers.com

Company: Icon Plumbing & Heating

Attention:

Telephone: (647) 526-0027

Fax:

Please Complete the following items:

DAI	Type	Issue	Appt. Date/Time	Notes
145656	Emergency	Basement- General- Sump pump is not working correctly; float to be adjusted or unit to be changed. going off when the pit is 1/4 full---zancor service could not fix the issue---schedule right away please	07Oct21 /am	
145780	30-Day	Other- General- Item #7- unfinished area- sump pump always running- lawn soaked and smelling	07Oct21 /am	
145793	30-Day	Exterior- General- item #19- yard- the water sprout is placed along the house and when it rains the water is gushing out along the side of the house it should be directed to the back	07Oct21 /am	

Date Completed: _____

Homeowner Signature: _____
The Homeowner acknowledges and accepts all work has been completed in a workman like manner.

Date Completed: _____

Trade &/or Service Tech.

Signature: _____

Print Name: _____

Please schedule your Service Department to complete work on the above Lot. Should no appointment time or date appear (below) on this form, it is your responsibility to arrange and adhere to the appointment you have scheduled. Your service representative must have this form signed by homeowner on completion. Please fax the signed form to our office (905) 833-4367.

Failure to comply with this request within 10 business days will give Zancor Homes (and it's group of companies) the right to carry out any and all repairs. All costs incurred will be applied to the Company listed above.

PUT BLINDS
UNDER SUMP
PUMP. AS
PER
ZANCOR
HOMES

100%

Done -
RYAN F
08/26