

☒ **A Warning Tag**

For your safety, your natural gas service has been temporarily disconnected.

Enbridge has issued an "A" Warning Tag identifying a serious safety issue with one or more of your natural gas appliances, indoor natural gas piping, exhaust vents or chimneys, or your existing "B" tag has expired and been replaced with an "A" tag. Your affected appliance(s) or natural gas service has been turned off and will need to remain that way until the issue is corrected. Please contact your heating contractor to have the corrective work completed. Please follow the directions left with your Warning Tag.

See reverse for more detail ►

☐ **B Warning Tag**

Identified repairs need to be made within 42 days.

Enbridge has issued a "B" Warning Tag identifying a potential safety issue with one or more of your natural gas appliances, indoor natural gas piping or exhaust vents or chimneys. Please contact a heating contractor to have the corrective work completed. You will need to have this issue corrected within 42 days or the affected appliance(s) will be disconnected until the issue is resolved. If access is not available to the appliance at that time, your natural gas service will be disconnected at your meter.

See reverse for more detail ►

WARNING

ENBRIDGE

<input checked="" type="checkbox"/> A	The appliance and/or piping is unsafe – the appliance has been disconnected and capped (or the meter shut off) for the reasons listed below.
	<input checked="" type="checkbox"/> Shut off at Meter <input type="checkbox"/> Shut off at Appliance
<input type="checkbox"/> B	The appliance and/or piping is safe at this time – however, corrections are required for your protection. To comply with Government Regulations the corrections listed below must be completed within 42 days, or the gas supply will be disconnected and capped (or meter shut off).
<input type="checkbox"/>	TSSA NOTIFIED – DO NOT REPAIR UNTIL NOTIFIED BY TSSA.
<input type="checkbox"/>	I have advised the customer of mailing / scanning / e-mail instructions and that a service charge may apply if Enbridge Gas Distribution must attend to inspect and pick-up the tag.

For instructions on clearing this safety notation please see attached "Your Safety and Our Regulatory Responsibility".

Code Reference

Supply line leaking at CSST	4.37
Customer's Signature: C-49	Date: 1-11-22

THIS TAG MUST BE ATTACHED TO APPLIANCE - ONLY TO BE REMOVED BY A QUALIFIED TECHNICIAN

104342

WARNING

ENBRIDGE

Name: Zaleena Bacchus	<input checked="" type="checkbox"/> Res.	<input type="checkbox"/> Apt./Suite	Date: 1-11-22
Street: Bianca Cr	<input type="checkbox"/> Comm.	<input type="checkbox"/> Floor	
Municipality: Wasega B	Home No: 6-624-438	Bus. No.:	
Customer's Signature: C-19	Gas Company Representative: L631236	<input checked="" type="checkbox"/> A Tag	<input type="checkbox"/> B Tag
Appliance Type, Manufacturer, Brand, Model: Supply line	Serial Number: N/A	Meter Number: 4287859	
WORK COMPLETED BY			
Name (Print): John Guinyou	Gas Technician's Certificate No.: 000741784		
Company Name: TriFlame Gas	Contractor's Business Address: 34 Leading Rd Etoh. Ont		
Date Completed: Jan. 11/22	Phone No.: 416 7463371	Signature: [Signature]	Appliance is code compliant
Description of Condition Corrected: Tighten CSST nut on meter caulk hole in top of Ottawa Box			
A service charge may apply if re-inspection is required. <input type="checkbox"/> TSSA NOTIFIED – DO NOT REPAIR UNTIL NOTIFIED BY TSSA			

TO BE COMPLETED BY SERVICE REPRESENTATIVE AND RETURNED BY CONTRACTOR (POSTAGE PAID)