



Zancor Homes (Wasaga) Ltd.
Warranty Services
Phone: (905) 738-7010
Fax: (905) 738-5948

Work Order

Closing Date: 17Nov22

Address: 35 Simona Avenue

Wasaga Beach, Ontario

Location: Shoreline Point - Phase: 1 - Lot: 143

Today's Date: 03Feb23

Contact(s): Marina Rogachevsky - Home: (416) 878-8141 - (marinar8141@gmail.com)
creativehockey@hotmail.com

Email: marinar8141@gmail.com creativehockey@hotmail.com

Company: National Air

Attention: Ron Lochhead / Alex (Service)

Telephone: (416) 532-0654

Fax: (416) 532-3811

Please Complete the following items:

DAI	Type	Issue	Appt. Date/Time	Notes
154403	Interval	Bedroom 2- General- no heat in bedroom- conduct heat balance		

Date Completed: Feb 16/23

Homeowner Signature: 
The Homeowner acknowledges and accepts all work
has been completed in a workman like manner.

Date Completed: Feb 16/23

Trade &/or Service Tech

Signature: 

Print Name: Ryan

Please schedule your Service Department to complete work on the above Lot. Should no appointment time or date appear (below) on this form, it is your responsibility to arrange and adhere to the appointment you have scheduled. Your service representative must have this form signed by homeowner on completion. Please fax the signed form to our office (905) 833-4367.

Failure to comply with this request within 10 business days will give Zancor Homes (and it's group of companies) the right to carry out any and all repairs. All costs incurred will be applied to the Company listed above.

u



IN-SERVICE Work Order

WO No: **W-203886**WO Date: **02/03/2023**Contractor: **RYAN WALL**Builder : **ZANCOR HOMES**Project : **R-ZAN525 - ZANCOR-SHORELINE POINT**Address : **35 Simona Avenue**City : **Wasaga Beach**

Contact :

Phone :

Cell:

Lot No: **143**Model: **40-05**

Block:

Phase:

Name:

Closing:

PDI Date:

Sch'd Date

Start Date

Comp Date

Unit Model

Serial No

02/16/2023**ML196UH070XE36B-19A****1722E24262**

QTY

MATERIAL & WORK REQUIRED

SERIAL NO

Airflow in cold Room
94,94

- Found excessive Airflow to 2nd floor. All main floor and BSM registers closed.
- Balanced whole House.
- Airflow good everywhere

WO Notes :

** Please arrive 9-1
Call prior
(416)878-8141

One bedroom is significantly colder. Heat balance

Contractor

Invoice No

Invoice Amt

Date

Site Super Sign