



Zancor Homes (Caledon) Ltd.
Warranty Services
Phone: (905) 738-7010
Fax: (905) 738-5948

Work Order

Closing Date: 18Aug22

Address:

Location: Caledon Club - Phase: 1 - Lot: 107A

Today's Date: 15Nov22

Contact(s): Fraz Tabassam - Work: (647) 210-0667 - (fraztabassam@gmail.com)

Iqra Shahid - Work: (647) 293-5669 - (iqrafraz24@gmail.com)

Email: fraztabassam@gmail.com

Company: National Air

Attention: Ron Lochhead / Alex (Service)

Telephone: (416) 532-0654

Fax: (416) 532-3811

Please Complete the following items:

DAI	Type	Issue	Appt. Date/Time	Notes
151013	30-Day ✓	Bedroom 2- General-Item #14 inspect if air return required at bedroom by master bedroom	14Oct22 /pm	
152190	Interval ✓	Throughout- General-conduct a heat balance test to ensure all venting is connected properly		

Date Completed: Dec 5/22

Homeowner Signature: [Signature]
The Homeowner acknowledges and accepts all work has been completed in a workman like manner.

Date Completed: Dec 5/22

Trade &/or Service Tech.

Signature: [Signature]

Print Name: Ryan

Please schedule your Service Department to complete work on the above Lot. Should no appointment time or date appear (below) on this form, it is your responsibility to arrange and adhere to the appointment you have scheduled. Your service representative must have this form signed by homeowner on completion. Please fax the signed form to our office (905) 833-4367.



IN-SERVICE Work Order

WO No: **W-198326**WO Date: **11/16/2022**Contractor: **RYAN WALL**

Builder : ZANCOR HOMES

Project : R-ZAN522 - ZANCOR HOMES-CALEDON

Address : 30 Del Grappa St

City : CALEDON

Contact :

Phone :

Cell:

Lot No: 107A

Model: 30-03 OPT

Block:

Phase:

Name:

Closing:

PDI Date:

Sch'd Date

Start Date

Comp Date

Unit Model

Serial No

12/05/2022**ML196UH070XE36B-19A****1722B33794**

QTY

MATERIAL & WORK REQUIRED

SERIAL NO

- O Airflow to 30% of House.
- BSM Pro Dumper closed. Connected.
- Balanced House.
- Airflow now ok.

WO Notes :

** Please arrive 12-4
Call prior
(647) 210-0667
(647) 293-5669
Book w/ builder

Throughout- Generalconduct a heat balance test to ensure all venting is connected properly

Contractor

Invoice No

Invoice Amt

Date

Site Super Sign