



Zancor Homes (Innisfil) Ltd.
Warranty Services
Phone: (905) 738-7010
Fax: (905) 738-5948

Work Order

Closing Date: 15Dec22

Address:

Location: Belle Aire Shores - Phase: 3 - Lot: 28W

Today's Date: 27Feb23

Contact(s): Abramo Pozzebon - Home: (416) 460-8605 - (a.pozzebon@bell.net)

Antonieta Pozzebon - Home: (416) 460-0497 - (a.pozzebon@bell.net)

Email: a.pozzebon@bell.net

Company: National Air

Attention: Ron Lochhead / Alex (Service)

Telephone: (416) 532-0654

Fax: (416) 532-3811

Please Complete the following items:

DAI	Type	Issue	Appt. Date/Time	Notes
154840	30-Day	Master Bedroom- General- Item #52 ticking noising comes through vent when furnace runs - inspect		

Date Completed: March 21/23

Homeowner Signature: X J. Pozzebon
The Homeowner acknowledges and accepts all work
has been completed in a workman like manner.

Date Completed: March 21/23

Trade &/or Service Tech.

Signature: [Signature]

Print Name: Pozzebon

Please schedule your Service Department to complete work on the above Lot. Should no appointment time or date appear (below) on this form, it is your responsibility to arrange and adhere to the appointment you have scheduled. Your service representative must have this form signed by homeowner on completion. Please fax the signed form to our office (905) 833-4367.

Failure to comply with this request within 10 business days will give Zancor Homes (and it's group of companies) the right to carry out any and all repairs. All costs incurred will be applied to the Company listed above.



IN-SERVICE Work Order

WO No: W-205617

WO Date: 03/02/2023

Contractor: RYAN WALL

Builder : ZANCOR HOMES

Project : R-ZAN523 - ZANCOR HOMES-INNISFIL-42'+1

Address : 1465 BRODERICK STREET

City :

Contact :

Phone :

Cell:

Lot No: 028W

Model: 50-07

Block:

Phase:

Name:

Closing:

PDI Date:

Sch'd Date

Start Date

Comp Date

Unit Model

Serial No

03/21/2023

ML196UH070XE36B-19A

1722G05293

QTY

MATERIAL & WORK REQUIRED

SERIAL NO

- normal operation: Expansion / contraction of
sheet metal Heating & cooling

* Recommend NOT using 3" filters

WO Notes :

** Please arrive 9-1
Booked with builder

Master Bedroom- General- Item #52 ticking noising comes through vent when furnace runs - inspect

Contractor

Invoice No

Invoice Amt

Date

Site Super Sign