



Zancor Homes (Parkview) Ltd.  
Warranty Services  
Phone: (905) 738-7010  
Fax: (905) 738-5948

Work Order

Closing Date: 25Aug22

Address:

Location: Now Towns In Brooklin - Phase: 1 - Lot: Unit 56 (Block 9)

Today's Date: 03May23

Contact(s): Ryan Jim Hei Li - Cell: (905) 621-2828 - (ryan6@hotmail.ca)

Email: ryan6@hotmail.ca

Company: Brooklin Zancor Warranty Service

Attention:

Telephone: (905) 655-2028

Fax: (905) 655-7371

Please Complete the following items:

DAI	Type	Issue	Appt. Date/Time	Notes
156589	Emergency	Bedroom 2- General- SVC TO INSPECT - ADJUST SIDING AT BEDROOM 2 HITTING WINDOW.	08May23 /am	

Date Completed: May 8/23

Homeowner Signature: [Signature]  
The Homeowner acknowledges and accepts all work  
has been completed in a workman like manner.

Date Completed: May 8/23

Trade &/or Service Tech.

Signature: [Signature]


Print Name: [Signature]

Please schedule your Service Department to complete work on the above Lot. Should no  
appointment time or date appear (below) on this form, it is your responsibility to arrange and  
adhere to the appointment you have scheduled. Your service representative must have this form  
signed by homeowner on completion. Please fax the signed form to our office (905) 833-4367.

Failure to comply with this request within 10 business days will give Zancor Homes (and  
it's group of companies) the right to carry out any and all repairs. All costs incurred will be  
applied to the Company listed above.

Outstanding Deficiencies  
Now Towns In Brooklyn - Phase: 1 - Lot: Unit 56 (Block 9)

Date Reported	Type	Number	Deficiency Description	Trade Assigned	Add Trade	Appointment Date	Item Completed	Initial
21Apr23	Interval	4	Main Hall- General- window leaking due to siding not sealed at 2nd level south window	Promark Aluminum LTD. 152698	Add	08May23	✓	AD
21Apr23	Interval	6	Foyer- General- Dent on man door- NOTED AT PDI	Newmar 154192	Add	08May23		AD
21Apr23	Interval	8	Bedroom 2- General- ADJUST SIDING AT BEDROOM 2 HITTING WINDOW.	Promark Aluminum LTD. 155034	Add	08May23	✓	AD
22Apr23	Emergency	1	Bedroom 2- General- SVC TO INSPECT - ADJUST SIDING AT BEDROOM 2 HITTING WINDOW.	Brooklyn Zancoor Warranty Service 156589	Add	08May23	✓	AD

Homeowner Signature: 

The Homeowner acknowledges and accepts that all installed work has been completed in a workman like manner to their satisfaction.

Date: 05/08/23

Zancoor Service Technician: KOUTHE