

QC Zancor Caledon

130B

Preet
Aug 22
key

Done

QUALITY ASSURANCE CERTIFICATE			
PROJECT: CALEDON CLUB	DATE: AUG 10	PHASE: 1B	
COMPLETED BY: LAURA	PDI DATE: AUG 23	LOT: 130B	
MASTER ENSUITE			
ROOM & AREA	ITEMS TO BE CHECKED	NOTES	TRADE
NEEDS TO BE STRIPPED AND CLEANED			
PLUMBING	TUB-SCRATCHES/CHIPS REPAIRED		
	TUB-FAUCETT COMPLETE C/W DRAIN CAP	HAND HELD DOES NOT STAY ON	EP
	TUB-HOT & COLD RUNNING & LABELLED	HOT WATER NOT WORKING	EP
	TUB-RUN WATER FOR 10 MIN & CHECK FOR LEAKS	LOW WATER PRESSURE AT TUB	EP
	SHWR/TUB-HOT & COLD RUNNING & LABELLED	HOT WATER NOT WORKING	EP
	SHWR/TUB SHOWER HEAD WORKING		
	SHWR/TUB-RUN WATER FOR 10 MIN & CHECK FOR LEAKS		
	SHWR/TUB-SHOWER DOOR/ROD	NO GLASS INSTALLED	MP
	TOILET-INSTALLED		
	TOILET-FLUSH 5 TIMES & CHECK FOR LEAKS		
ELECTRICAL	TOILET-TANK LID, SEAT COVER & SCREW CAPS INSTALLED		
	SINK-INSTALLED & SILICONED	NOT INSTALLED	EP
	SINK-HOT & COLD WATER RUNNING		
	SINK-FAUCETT COMPLETE C/W DRAIN CAP	NOT INSTALLED	EP
	SINK-RUN WATER FOR 10 MIN & CHECK FOR LEAKS		
	LIGHTS WORKING		
	STRIP LIGHTS INSTALLED, LEVELLED & CENTERED		
	CEILING FAN WORKING & COVER PLATE TIGHT TO CEILING		
	GFI PLUG WORKING		
	PLUG/SWITCH PLATES INSTALLED LEVELLED & PLUMB		
TRIM	CASINGS, BASEBOARDS & 1/4 ROUND COMPLETE	TRIM JOINTS + NAIL HOLES	VIA TRIM
	DOORSTOPS INSTALLED		
	PRIVACY DOOR LOCKS INSTALLED & WORKING		
DRYWALL	DOUBLE DOOR POSITION LOCK		
	TAPE JOINTS SANDED & DONE WELL	GREEN TAPE	P.T & ZANCOR
	OVERCUTS AT ELECTRICAL BOXES & FIXTURES		
WINDOWS	CEILING DEFECT & SCRATCH FREE	LINE @ SHOWER TO BE MADE NEAT	ZANCOR
	CHECK ALL WALLS & REPAIR KNICKS & DENTS	GREEN TAPE	P.T & ZANCOR
	CRANKS, SCREENS INSTALLED & WORKING	CRANKS AND SCREENS NOT INSTALLED	
PAINTING	FRAMES FREE OF CRACKS AND DAMAGE		
	CHECK FOR SCRATCHED WINDOWS		
	CHECK FOR GAPS WHERE VINYL & WOOD MEET AND DAP	NEEDS DAP	ZANCOR
CABINETRY	WALL PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
	TRIM PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
	TOUCH UPS COMPLETE	GREEN TAPE	P.T & ZANCOR
FLOORING	OVERSPILLS REMOVED FROM FLOOR, WINDOWS ETC.	GREEN TAPE	P.T & ZANCOR
	CABINETS INSTALLED COMPLETE C/W KNOBS	NO HARDWARE NEEDED	N/A
	COUNTERTOP COMPLETE AND DEFECT FREE	NOT INSTALLED	AV
OTHER	DOORS/DRAWERS OPERATING W/ BUMPERS	MARBLE JAMB AT SHOWER NEEDS TO BE REPLACED***LARGE DAMAGE***	
	DOORS, DRAWERS LINE UP & EVEN GAPS		
	KICKPLATES INSTALLED		
FLOORING	CABINETS FREE FROM KNICKS, SCRATCHES & DENTS	X3 CHIPS	NZ
	CERAMICS COMPLETE & DEFECT FREE	OVERCUT @ SHOWER CONTROL	AV
	GROUT COMPLETE & UNSTAINED	OVERCUT @ HOSE	
OTHER	SILICONE COMPLETED THROUGHOUT		
	REGISTERS & GRILLS INSTALLED & LEVELLED	REGISTER COVERS NOT INSTALLED	NZ
	TOILET PAPER HOLDER INSTALLED, LEVEL & SILICONED	DO NOT INSTALL	
OTHER	TOWEL BAR INSTALLED, LEVEL & SILICONE	DO NOT INSTALL	
	SOAP DISHES INSTALLED, LEVEL & SILICONED	DO NOT INSTALL	
	MIRRORS INSTALLED, DEFECT FREE & CENTERED	NOT INSTALLED	MP
MASTER BEDROOM			
ROOM & AREA	ITEMS TO BE CHECKED	NOTES	TRADE
NEEDS TO BE STRIPPED AND CLEANED			
FLOORING	COMPLETE, DEFECT, STAIN FREE, TIGHT @ BASEBOARDS	CARPET NOT INSTALLED	SS
	REGISTERS & GRILLS INSTALLED & LEVELLED	NOT INSTALLED	NZ
	NOTICABLE SQUEAKS OR CRACKS		
TRIM	CASINGS, BASEBOARDS & 1/4 ROUND COMPLETE	TRIM JOINTS + NAIL HOLES	VIA TRIM
	DOORSTOPS INSTALLED		
	PASSAGE DOOR LOCKS INSTALLED & WORKING		
DRYWALL	DUMMY DOOR LOCKS INSTALLED & WORKING		
	ATTIC HATCH INSTALLED & WORKING	PAINT TOUCH-UP NEEDED + SECURE AFTER OCCUPANCY	ZANCOR
	CHECK FOR ATTIC INSULATION STICKER	CANNOT REACH	N/A
WINDOWS	CHECK ATTIC WITH LIGHT TO ENSURE NO INSULATION BLOWBACK	CANNOT REACH	N/A
	CHECK DOUBLE DOOR POSITION LOCK (IF APPLICABLE)		
	TAPE JOINTS SANDED & DONE WELL	GREEN TAPE	P.T & ZANCOR
PAINTING	STUCCO CEILING DEFECT & SCRATCH FREE		
	OVERCUTS AT ELECTRICAL BOXES & FIXTURES		
	CHECK ALL WALLS & REPAIR KNICKS & DENTS	GREEN TAPE	P.T & ZANCOR
OTHER	CRANKS, SCREENS INSTALLED & WORKING	SCREENS AND CRANKS NOT INSTALLED	NZ
	FRAMES FREE OF CRACKS AND DAMAGE		
	CHECK FOR SCRATCHED WINDOWS		
FLOORING	CHECK FOR GAPS WHERE VINYL & WOOD MEET AND DAP	NEEDS DAP	ZANCOR
	WALL PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
	TRIM PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
OTHER	TOUCH UPS COMPLETE	GREEN TAPE	P.T & ZANCOR
	OVERSPILLS REMOVED FROM FLOOR, WINDOWS ETC.	GREEN TAPE	P.T & ZANCOR
	LIGHTS WORKING		
ELECTRICAL	PLUG/SWITCH PLATES INSTALLED LEVELLED & PLUMB		
	VAC PLATES INSTALLED	LOW VOLTAGE NOT COMPLETED	HH
	SHELVING INSTALLED & SUPPORTED PROPERLY	NOT INSTALLED	VT

UPPER HALLWAY			
ROOM & AREA	ITEMS TO BE CHECKED	NOTES	TRADE
NEEDS TO BE STRIPPED AND CLEANED			
DRYWALL	TAPE JOINTS SANDED & DONE WELL	GREEN TAPE	P.T & ZANCOR
	OVERCUTS AT ELECTRICAL BOXES & FIXTURES	GREEN TAPE	P.T & ZANCOR
	CHECK ALL WALLS & REPAIR KNICKS & DENTS		
FLOORING	STUCCO CEILING DEFECT & SCRATCH FREE		
	COMPLETE, DEFECT, STAIN FREE, TIGHT @ BASEBOARDS		
	REGISTERS & GRILLS INSTALLED & LEVELLED	NOT INSTALLED	NA
TRIM	NOTICABLE SQUEAKS OR CRACKS		
	CASINGS, BASEBOARDS & 1/4 ROUND COMPLETE	TRIM JOINTS + NAIL HOLES	VIA TRIM
	DOORSTOPS INSTALLED		
SHELVING	PASSAGE DOOR LOCKS INSTALLED & WORKING		
	DUMMY DOOR LOCKS INSTALLED & WORKING		
	CHECK DOUBLE DOOR POSITION LOCK (IF APPLICABLE)		
PAINTING	SHELVING INSTALLED & SUPPORTED PROPERLY	NOT INSTALLED	
	WALL PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
	TRIM PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
ELECTRICAL	TOUCH UPS COMPLETE	GREEN TAPE	P.T & ZANCOR
	OVERSPILLS REMOVED FROM FLOOR, WINDOWS ETC.	GREEN TAPE	P.T & ZANCOR
	LIGHTS WORKING		
	PLUG/SWITCH PLATES INSTALLED LEVELLED & PLUMB		
	VAC PLATES INSTALLED	NOT INSTALLED	P.H.
MAIN/SHARED BATH			
ROOM & AREA	ITEMS TO BE CHECKED	NOTES	TRADE
NEEDS TO BE STRIPPED AND CLEANED			
PLUMBING	TUB-SCRATCHES/CHIPS REPAIRED		
	TUB-FAUCETT COMPLETE C/W DRAIN CAP		
	TUB-HOT & COLD RUNNING & LABELLED	HOT WATER NOT WORKING	PAV
	TUB-RUN WATER FOR 10 MIN & CHECK FOR LEAKS	LOW WATER PRESSURE	IP
	SHWR/TUB-HOT & COLD RUNNING & LABELLED	HOT WATER NOT WORKING	PAV
	SHWR/TUB-SHOWER HEAD WORKING	SHOWER CONTROL STICKING WHEN BEING TURNED OFF	IP
	SHWR/TUB-RUN WATER FOR 10 MIN & CHECK FOR LEAKS		
	SHWR/TUB-SHOWER DOOR/ROD		
	TOILET-INSTALLED		
	TOILET-FLUSH 5 TIMES & CHECK FOR LEAKS		
	TOILET-TANK LID, SEAT COVER & SCREW CAPS INSTALLED		
	SINK-INSTALLED & SILICONED	SILICONE NOT DONE	PAV
	SINK-HOT & COLD WATER RUNNING	HOT WATER NOT WORKING	PAV
	SINK-FAUCETT COMPLETE C/W DRAIN CAP		
	SINK-RUN WATER FOR 10 MIN & CHECK FOR LEAKS		
ELECTRICAL	LIGHTS WORKING		
	STRIP LIGHTS INSTALLED, LEVELLED & CENTERED		
	CEILING FAN WORKING & COVER PLATE TIGHT TO CEILING		
TRIM	GFI PLUG WORKING		
	PLUG/SWITCH PLATES INSTALLED LEVELLED & PLUMB		
	CASINGS, BASEBOARDS & 1/4 ROUND COMPLETE	TRIM JOINTS + NAIL HOLES	VIA TRIM
DRYWALL	DOORSTOPS INSTALLED		
	PRIVACY DOOR LOCKS INSTALLED & WORKING		
	DOUBLE DOOR POSITION LOCK		
WINDOWS	TAPE JOINTS SANDED & DONE WELL	GREEN TAPE	P.T & ZANCOR
	OVERCUTS AT ELECTRICAL BOXES & FIXTURES		
	CEILING DEFECT & SCRATCH FREE	LINE @ SHOWER TO BE MADE NEAT	ZANCOR
PAINTING	CHECK ALL WALLS & REPAIR KNICKS & DENTS		
	CRANKS, SCREENS INSTALLED & WORKING	SCREENS AND CRANKS NOT INSTALLED	NW
	FRAMES FREE OF CRACKS AND DAMAGE		
CABINETRY	CHECK FOR SCRATCHED WINDOWS		
	CHECK FOR GAPS WHERE VINYL & WOOD MEET AND DAP		
	WALL PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
FLOORING	TRIM PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
	TOUCH UPS COMPLETE	GREEN TAPE	P.T & ZANCOR
	OVERSPILLS REMOVED FROM FLOOR, WINDOWS ETC.	GREEN TAPE	P.T & ZANCOR
OTHER	CABINETS INSTALLED COMPLETE C/W KNOBS		
	COUNTERTOP COMPLETE AND DEFECT FREE		
	DOORS/DRAWERS OPERATING W/ BUMPERS		
	DOORS, DRAWERS LINE UP & EVEN GAPS		
	KICKPLATES INSTALLED		
	CABINETS FREE FROM KNICKS, SCRATCHES & DENTS	(X1) CHIP	NA
	CERAMICS COMPLETE & DEFECT FREE	OVERCUT @ SHOWER HEAD	PAV
	GROUT COMPLETE & UNSTAINED		
	SILICONE COMPLETED THROUGHOUT		
	REGISTERS & GRILLS INSTALLED & LEVELLED	NOT INSTALLED	NA
	TOILET PAPER HOLDER INSTALLED, LEVEL & SILICONED	DO NOT INSTALL	
	TOWEL BAR INSTALLED, LEVEL & SILICONE	DO NOT INSTALL	
	SOAP DISHES INSTALLED, LEVEL & SILICONED	DO NOT INSTALL	
	MIRRORS INSTALLED, DEFECT FREE & CENTERED	NOT INSTALLED	PAV

LAUNDRY ROOM			
ROOM & AREA	ITEMS TO BE CHECKED	NOTES	TRADE
NEEDS TO BE STRIPPED AND CLEANED			
CABINETRY	CABINETS INSTALLED COMPLETE C/W KNOBS		
	COUNTERTOP COMPLETE AND DEFECT FREE		
	DOORS/DRAWERS OPERATING /W BUMPERS		
	DOORS, DRAWERS LINE UP & EVEN GAPS		
	KICKPLATES INSTALLED		
PLUMBING	CABINETS FREE FROM KNICKS, SCRATCHES & DENTS	(X3) CHIPS	NA
	LAUNDRY TUB & FAUCET INSTALLED	SILICONE NOT DONE	ZAN
	DRAIN STOPS INSTALLED/PROVIDED		
	RUN WATER FOR 10 MINUTES & CHECK FOR LEAKS		
	HOT & COLD RUNNING & LABELLED	HOT WATER NOT WORKING	ZAN
FLOORING	DRYER VENT INSTALLED & PIPED TO EXTERIOR	VENT TO BE EXTENDED	ZAN
		VENT BLOCKED-REMOVE BLOCKAGE	ZAN
	CERAMICS COMPLETE & DEFECT FREE		
	GROUT COMPLETE & UNSTAINED		
	SILICONE COMPLETED THROUGHOUT		
TRIM	REGISTERS & GRILLS INSTALLED & LEVELLED	NOT INSTALLED	NA
	CHECK FLOORS FOR NOTICABLE SQUEAKS OR CRACKS		
	CASINGS, BASEBOARDS & 1/4 ROUND COMPLETE	TRIM JOINTS + NAIL HOLES	VIA TRIM
	DOORSTOPS INSTALLED		
	PASSAGE DOOR LOCKS INSTALLED & WORKING		
SHELVING	SHELVING INSTALLED & SUPPORTED PROPERLY	NOT INSTALLED	UT
	LIGHTS WORKING		
	PLUG/SWITCH PLATES INSTALLED LEVELLED & PLUMB		
	VAC PLATES INSTALLED		
	EXHAUST FAN INSTALLED & VENTED C/W WITH LIGHT		
WINDOWS	CRANKS, SCREENS INSTALLED & WORKING		
	FRAMES FREE OF CRACKS AND DAMAGE		
	CHECK FOR SCRATCHED WINDOWS		
	CHECK FOR GAPS WHERE VINYL & WOOD MEET AND DAP	NEEDS DAP	ZANCOR
	WALL PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
PAINTING	TRIM PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
	TOUCH UPS COMPLETE	GREEN TAPE	P.T & ZANCOR
	OVERSPILLS REMOVED FROM FLOOR, WINDOWS ETC.	GREEN TAPE	P.T & ZANCOR
	TAPE JOINTS SANDED & DONE WELL	GREEN TAPE	P.T & ZANCOR
	CEILING DEFECT & SCRATCH FREE		
DRYWALL	OVERCUTS AT ELECTRICAL BOXES & FIXTURES		
	CHECK ALL WALLS & REPAIR KNICKS & DENTS	GREEN TAPE	P.T & ZANCOR

POWDER ROOM GROUND FLOOR			
ROOM & AREA	ITEMS TO BE CHECKED	NOTES	TRADE
NEEDS TO BE STRIPPED AND CLEANED			
PLUMBING	TOILET-INSTALLED		
	TOILET-FLUSH 5 TIMES & CHECK FOR LEAKS		
	TOILET-TANK LID, SEAT COVER & SCREW CAPS INSTALLED		
	SINK-INSTALLED & SILICONED	NOT INSTALLED	JP.
	SINK-HOT & COLD WATER RUNNING	HOT WATER NOT WORKING	JP.
ELECTRICAL	SINK-FAUCETT COMPLETE C/W DRAIN CAP	NOT INSTALLED	JP.
	SINK-RUN WATER FOR 10 MIN & CHECK FOR LEAKS	NOT INSTALLED	JP.
	LIGHTS WORKING		
	STRIP LIGHTS INSTALLED, LEVELLED & CENTERED		
	CEILING FAN WORKING & COVER PLATE TIGHT TO CEILING		
TRIM	GFI PLUG WORKING		
	PLUG/SWITCH PLATES INSTALLED LEVELLED & PLUMB		
	CASINGS, BASEBOARDS & 1/4 ROUND COMPLETE	TRIM JOINTS + NAIL HOLES	VIA TRIM
	DOORSTOPS INSTALLED		
	PRIVACY DOOR LOCKS INSTALLED & WORKING	LOCK WORKS BACKWARDS	MT.
DRYWALL	DOUBLE DOOR POSITION LOCK		
	TAPE JOINTS SANDED & DONE WELL	GREEN TAPE + BAD TAPE JOB @ CEILING	P.T & ZANCOR
	OVERCUTS AT ELECTRICAL BOXES & FIXTURES		
	CEILING DEFECT & SCRATCH FREE		
	CHECK ALL WALLS & REPAIR KNICKS & DENTS	GREEN TAPE	P.T & ZANCOR
WINDOWS	CRANKS, SCREENS INSTALLED & WORKING	SCREEN AND CRANKS NOT INSTALLED	
	FRAMES FREE OF CRACKS AND DAMAGE		
	CHECK FOR SCRATCHED WINDOWS		
	CHECK FOR GAPS WHERE VINYL & WOOD MEET AND DAP	NEEDS DAP	ZANCOR
	WALL PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
PAINTING	TRIM PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
	TOUCH UPS COMPLETE	GREEN TAPE	P.T & ZANCOR
	OVERSPILLS REMOVED FROM FLOOR, WINDOWS ETC.	GREEN TAPE	P.T & ZANCOR
	CABINETS INSTALLED COMPLETE C/W KNOBS		
	COUNTERTOP COMPLETE AND DEFECT FREE	NOT INSTALLED	R.S.
CABINETS	DOORS/DRAWERS OPERATING W/ BUMPERS		
	DOORS, DRAWERS LINE UP & EVEN GAPS		
	KICKPLATES INSTALLED		
	CABINETS FREE FROM KNICKS, SCRATCHES & DENTS	ROUGH EDGE	MT.
	CERAMICS COMPLETE & DEFECT FREE		
FLOORING	GROUT COMPLETE & UNSTAINED		
	SILICONE COMPLETED THROUGHOUT		
	REGISTERS & GRILLS INSTALLED & LEVELLED	NOT INSTALLED	MT.
	TOILET PAPER HOLDER INSTALLED, LEVEL & SILICONED	DO NOT INSTALL	N/A
	TOWEL BAR INSTALLED, LEVEL & SILICONE	DO NOT INSTALL	N/A
OTHER	SOAP DISHES INSTALLED, LEVEL & SILICONED	DO NOT INSTALL	N/A
	MIRRORS INSTALLED, DEFECT FREE & CENTERED	NOT INSTALLED	MT.

KITCHEN			
ROOM & AREA	ITEMS TO BE CHECKED	NOTES	TRADE
NEEDS TO BE STRIPPED AND CLEANED			
CABINETRY	CABINETS INSTALLED COMPLETE C/W KNOBS		
	COUNTERTOP COMPLETE AND DEFECT FREE		
	DOORS/DRAWERS OPERATING /W BUMPERS	MISSING (X2) BUMPERS	NIK
	DOORS, DRAWERS LINE UP & EVEN GAPS	ADJUSTMENTS NEEDED	NIK
	KICKPLATES INSTALLED		
CABINETRY		(X18) CHIPS @ UPPERS	NIK
		(X6) CHIPS @ LOWERS	
		(X2) CHIPS @ ISLAND	
		(X8) CHIPS @ DRAWERS	
	CABINETS FREE FROM KNICKS, SCRATCHES & DENTS	(X6) NAIL HOLES @ ISLAND (X3) ROUGH EDGES AT SHELVES GLUE LEFT THROUGHTOUT LOWER SHELF NO LEVEL	
PLUMBING	SINK FAUCETT COMPLETE C/W DRAIN CAP		
	DISHWASHER R/I OFF HOT WATER INSTALLED C/W DRAIN R/I		
	DRAIN STOPS INSTALLED/PROVIDED		
	RUN WATER FOR 10 MINUTES & CHECK FOR LEAKS		
	HOT & COLD RUNNING & LABELLED	HOT WATER NOT WORKING	ZAW
FLOORING	CERAMICS/HARDWOOD COMPLETE & DEFECT FREE		
	GROUT COMPLETE & UNSTAINED		
	SILICONE COMPLETED THROUGHOUT		
	REGISTERS & GRILLS INSTALLED & LEVELLED	NOT INSTALLED	NA
	LIGHTS WORKING		
ELECTRICAL	DISHWASHER R/I INSTALLED CLOSE TO LOCATION & MARKED		
	HOOD FAN INSTALLED & VENTED C/W WITH LIGHT	NOT CONNECTED	NA
	PLUG/SWITCH PLATES INSTALLED LEVELLED & PLUMB TO WALL		
	ALL SHELIVING INSTALLED & SUPPORTED PROPERLY		
	CRANKS, SCREENS INSTALLED & WORKING		
WINDOWS	FRAMES FREE OF CRACKS AND DAMAGE	NEEDS DAP	ZANCOR
	CHECK FOR SCRATCHED WINDOWS		
	WORKING PROPERLY	DOES NOT CLOSE	N.W.
	GLASS FREE FROM SCRATCHES	SECURE FOR OCCUPANCY	
	SCREEN INSTALLED		
PATIO DOOR	HANDLES IN LOCK POSITION AND LOCKED INSTALLED		
PAINTING	WALL PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
	TRIM PAINT HAS GOOD COVERAGE & NO RUNS	GREEN TAPE	P.T & ZANCOR
	TOUCH UPS COMPLETE	GREEN TAPE	P.T & ZANCOR
	OVERSPILLS REMOVED FROM FLOOR, WINDOWS ETC.	GREEN TAPE	P.T & ZANCOR
	TAPE JOINTS SANDED & DONE WELL		
DRYWALL	OVERCUTS AT ELECTRICAL BOXES & FIXTURES		
	CEILING DEFECT & SCRATCH FREE		
	CHECK ALL WALLS & REPAIR KNICKS & DENTS	GREEN TAPE	P.T & ZANCOR